



Alachua County  
Department of Growth Management  
10 SW 2nd Ave., Gainesville, FL 32601  
<http://growth-management.alachuacounty.us>

Submit to: Building Division

Tel. 352.374.5243  
Fax. 352.491.4510

## INSPECTION AFFIDAVIT

RE: Permit # 0000413648

Jobsite Address: 467 SW Heflin Ave  
Fort White, FL. 32038

I Bryan Greenlee, licensed as a(n) ☐ Contractor\* /Engineer/Architect, ☐ FS 468 Building Inspector\*  
(please print name and check License Type)

License # CCC042888 On or about 02/14/22, I did personally  
(Date & time)

inspect the ☒ roof deck nailing and/or ☒ secondary water barrier work at \_\_\_\_\_  
(Job Site Address)

Roof Deck: OSB \_\_\_\_\_ Thickness \_\_\_\_\_ Plywood X Thickness 1/2"

Replaced any rotten wood per FBEC 611 and added crickets or saddles on ridge side of any chimney over 30 inches in width per FRBC 905.2.8.3.

Based upon that examination I have determined the installation was done according to the Hurricane Mitigation Retrofit Manual (Based on 553.844 F.S.)

Bryan Greenlee

Signature of Contractor, Contractor designee or FS 468 Building Inspector

STATE OF FLORIDA  
COUNTY OF ALACHUA  
Suzanne E. St. Onge  
NOTARY PUBLIC  
STATE OF FLORIDA  
Comm# GG962810  
Expires 4/4/2024

(SEAL ABOVE)

Suzanne E St Onge  
Suzanne St. Onge

SWORN AND SUBSCRIBED BEFORE ME

THIS 14th DAY OF February, 2022  
BY Bryan Greenlee

WHO IS/ARE PERSONALLY KNOWN TO ME OR HAS/HAVE PRODUCED AS IDENTIFICATION

\_\_\_\_\_  
(TYPE OF IDENTIFICATION)

Notary Public, Commission No. GG962810  
(Name of Notary typed, printed, or stamped)

\* General, Building, Residential, or Roofing Contractor or any individual certified under 468 F.S. to make such an inspection.