

March 10, 2023

Robert Hartley Hartley Brothers Custom Home Builder 1325 NW 53<sup>rd</sup> Ave, Suite D Gainesville, FI 32609

Via email: robert@hartleybrothers.com

Re: Mahn Property – Tax Parcel No 18-7S-17-10021-024. Forth White, Florida.

Dear Mr. Hartley:

This letter is regarding Tax Parcel No 18-7S-17-10021-024, Forth White, Florida. The proposed minimum finish floor elevation for the proposed structure will be 63.70, NAVD 88.

The area for the structure drains NW and SW away from the proposed structure and there is no risk of flooding as showing in the attached insert of the Columbia County elevation map.

Also, according to the official FEMA Flood Hazard Panel 532 of 552, Columbia County, Florida, the above-referenced property is located entirely with Zone X, which is identified as an area of minimal flood hazard and is not within an identified area of flood hazard. Attached is the FEMA map for your reference.

I certify that the proposed Minimum Finish Floor of the proposed structure as listed above, will protect the structure against flooding from a base flood event, as defined in article 8 of the Colombia County Land Development Regulations.

If you have any questions, please feel free to contact our office.

Sincerely,



Sergio Reyes, P.E.

## President





