

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

June 28, 2022

Twilla & Art Mckibbin

twillamyfirealtor@gmail.com

re: ROOF FRAMING LETTER

Revisions & additions to the plans dated February 4, 2022:

- Install ridge strap @ every rafter
- Collar ties shall be install @ 48" maximum spacing
- Fasten block connecting rafter and ceiling joist to top plate with 16-16d common nails, both sides (40d box nails can be substituted for 16d common nails)

In my professional opinion, this structure meets the requirements for a residential dwelling per the Florida Building Code 2020, 7th Edition, Residential. Should you have any questions, please don't hesitate to contact me.

Respectfully,

Carol Chadwick, P.E.



Digitally signed
by Carol
Chadwick
DN: c=US,
o=Florida,
dnQualifier=A014
10D0000017EB6D
924CE0005954C,
cn=Carol
Chadwick
Date: 2022.06.28
16:12:32 -04'00'

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

CC Job #FL22026

