

Notice of Prevention for Subterranean Termites (As required by Florida Building Code (FBC) 104.2.6)

17856 U.S. 129 • McALPIN, FLORIDA 32062
(386) 362-3887 • 1-800-771-3887 • Fax: (386) 364-3529

A locally owned
company serving
you since 1972



Address of Treatment or Lot/Block of Treatment

1802 NW Fontaine Drive Lake City FL

Date 8-10-24
Time 11:00 am
Applicator Lee

Product Used Retraz
Chemical used (active ingredient) Imidacloprid
Number of gallons applied 115

Percent Concentration .051
Area treated (square feet) N/A
Linear feet treated 280

Stage of treatment (Horizontal, Vertical, Adjoining Slab, retreat of disturbed area)

As per 104.2.6 - If soil chemical barrier method for Subterranean termite prevention is used, final exterior treatment shall be completed prior to final building approval.

The building has received a complete treatment for the prevention of subterranean termites. Treatment is in accordance with rules & laws established by the Florida Department of Agriculture & Consumer Services. Initial and date this line.

If this notice is for the final exterior treatment initial and date this line.

8-10-24
8-10-24