

14



10 JUNE 2013

BUILDING OFFICIAL
COLUMBIA COUNTY BUILDING DEPARTMENT
COLUMBIA COUNTY COURTHOUSE ANNEX
LAKE CITY, FLORIDA

RE: KASAK RESIDENCE
PERMIT Nr.: 31108

DEAR SIR:

PLEASE BE ADVISED THAT IT IS PERMISSIBLE TO USE PLASTIC REBAR
SUPPORTS IN LIEU OF THE WIRE CHAIR REBAR SUPPORTS AS CALLED FOR
IN THE CONSTRUCTION DOCUMENTS.

SHOULD YOU HAVE ANY FURTHER QUESTIONS WITH THIS, PLEASE CALL FOR
ASSISTANCE.

YOURS TRULY,
NICHOLAS PAUL GEISLER, ARCHITECT AR0001005

OK
T.C.
6-11-13