

## **ROOFING AFFIDAVIT**

Columbia County, Florida Building Department 135 NE Hernando Avenue Lake City, Florida 32055 Phone: 386-758-1008

www.columbiacountyfla.com

JOB ADDRESS: 2 48 SW Bunstead tell lake lity
I ( <u>Print Name</u> ) Robert 09/e5 licensed under Chapter 468, Florida Statutes as a(n):  ( <u>Check One</u> ) Contractor Engineer Architect
License Number: [11] 132 8 699
On this (Date) 6-/3-2022 did personally examine the roof at the above address for regulatory compliance as required for: (Check all that apply)
Roof Deck Attachment Secondary Water Barrier Roof to Wall Connection
Attic Venting has been maintained and complies with Florida Building Code R-806.
Based on my examination, I have determined and affirm the installation is in accordance with the Florida Building Code 2020 7th Edition and 2020 Florida Statute (553.844).
(Affiant Signature)
COUNTY Sarannee
The foregoing instrument acknowledged before me by means of physical presence or online notarization, this 3 day of 1000 2012 by ROUNT 0005 who is personally known to me or has provided the following identification
Notary Public Signature Stuly Stuly (Seal)  Notary Printed Name ASMLY Brully  ASHLEY K. STALEY MY COMMISSION # GG 923118 EXPIRES: October 15, 2023

## FINAL INSPECTION & CERTIFICATE OF COMPLETION:

This completed form and photographs must be uploaded to your permit via online at the Application Submission login (link) Welcome to Columbia County Online (columbiacountyfla.com).

Clearly visible in the Photographs must be the permit number or address, must include a ruler or measuring device to confirm nail spacing and overlaps including drip edge, valley flashing and attic venting.



## **ROOFING UNDERLAYMENT AFFIDAVIT**

Columbia County, Florida Building Department 135 NE Hernando Avenue Lake City, Florida 32055 Phone: 386-758-1008

www.columbiacountyfla.com

REQUIRED FOR WALK-IN OR PAPER SUBMITTALS
Job Address: 250 SW Bunston terr lake ciry
Job Address: 250 SW Bunstrad terr lane Cirx  I (Print Name) Robert Oglest as a Florida license Roofing Contractor or an Owner
Builder, I understand to comply with the 2020 Florida Building Code 7th Edition underlayment requirements, I
must select an option for sealing the roof deck.
The options are summarized below
a self-adhering polymer-modified bitumen underlayment complying with ASTM D1970 applied over the entire roof.
a minimum 4-inch wide strip of selfadhering polymer-modified bitumen complying with ASTM D1970 or a minimum 3 % - inch wide strip of selfadhering flexible flashing tape complying with AAMA 711, applied over all joints in the roof decking. A felt underlayment complying with ASTM D226 Type II, ASTM D4869 Type III or IV, or ASTM D6757, or a synthetic underlayment meeting the performance requirements specified, is required to be applied over the strips/tape over the entire roof.
two layers of felt underlayment comply ASTM 0226 Type II or ASTM D4869 Type III or IV, or two layers of a synthetic underlayment meeting the performance requirements specified, lapped and fastened as specified.
J Other (explain) Roof over with meral

## FINAL INSPECTION & CERTIFICATE OF COMPLETION:

This completed form and photographs must be uploaded to your permit via online at the Application Submission login (link) Welcome to Columbia County Online (columbia countyfla.com).

Clearly visible in the Photographs must be the permit number or address and must include a ruler or measuring device to confirm nail spacing and overlaps including drip edge and valley flashing.