CAROL CHADWICK, P.E.

Civil Engineer
1208 S.W. Fairfax Glen
Lake City, FL 32025
307.680.1772
ccpewyo@gmail.com
www.carolchadwickpe.com

November 7, 2023

Larry \$ Linda Laird 618.697.6438 Idlaird | @gmail.com

re: ENGINEER'S REPORT: 280 SW GRAPEVINE COURT, FORT WHITE, FL

Dear Larry & Linda:

I inspected the construction of the metal building construction at the above referenced address. Two anchor bolts in the pictured supports will be sufficient for the structural stability of the building.

In my professional experience, the framing meets or exceeds the requirements as set forth in the 2020 Florida Building Code - Residential, $7^{\rm th}$ edition.

Please contact me at 307.680.1772 if you have any questions.

Respectfully,

1. CHAO CENSE ML 22800 STALL OF STALL OF STALL OF MINIMUM Digitally signed by Carol Chadwick DN: c=US, o=Florida, dnQualifier=A014 10D0000017EB6D 924CE0005954C, cn=Carol Chadwick Date: 2023.11.07 18:52:58 -05'00'

Carol Chadwick, P.E.



Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies. CC Job FL23393