

05 JANUARY 2023

BUILDER: IC CONSTRUCTION

ADDRESS: CHRIS & TERESA WILKEY, SW DYAL RD, COLUMBIA COUNTY, FLORIDA

BUILDING DEPARTMENT: COLUMBIA COUNTY BUILDING DEPARTMENT

TO WHOM IT MAY CONCERN,

IN LIEU OF DETAIL 'G', SHEET S.4, THE ALTERANTE 'TITAN' BOLT (THREADED ROD) ANCHOR SYSTEM CAN BE USED AS FOLLOWS: (1) 5/8" 'TITAN' BOLT ON EACH SIDE OF GARAGE OPENING, MIN. 4" EMBED, WITH EPOXY SET. (SEE DETAIL BELOW FOR FURTHER CLARIFICATION)

IF YOU HAVE ANY FURTHER QUESTIONS, OR IF WE MAY BE OF FURTHER SERVICE, PLEASE CONTACT MY PERSONAL REPRESENTATIVE FOR THIS PROJECT:


WILL MYERS
WM DESIGN & ASSOCIATES, INC.
426 SW COMMERCE DR. STE 130
LAKE CITY, FLORIDA 32025
PHONE: 386.867.1394
EMAIL: will@willmyers.net

THANK YOU,
SINCERELY,

NICHOLAS PAUL GEISLER, ARCHITECT AR0007005

**N. P.
GEISLER**

Digitally signed by: N. P. GEISLER
DN: CN = N. P. GEISLER
C = US O = AR0007005
OU = ARCHITECT
Date: 2023.01.13 17:26:38 -05'00'



Garage End Wall Threaded anchor detail

SCALE: NTS