



Britt Surveying and Mapping, LLC

1438 SW Main Blvd • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

10/04/2022

Permit # 000045257

L-28690


Re: Lot 12 Stonehenge Phase 2

Cornerstone Developers

To Whom It May Concern:

The finished floor elevation on Lot 12 is found to be 102.53 feet. The minimum floor elevation is determined to be 102.7 feet per the building permit. All elevations are shown in NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757

