



Britt Surveying and Mapping, LLC

1438 SW Main Blvd • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

09/30/2025

L-31747

Permit # 000053462

Re: Lot 42 Meadowlands Phase 3

Americas Home Place

To Whom It May Concern:

The finished floor elevation is found to be 81.9 feet. The center line elevation of SW Colony Glen is determined to be 80.2 feet. The plat of record shows a minimum floor elevation to be 82.0 feet. The elevations shown hereon are based on NGVD 29 datum per the plat datum.

Sincerely,


L. Scott Britt

LS 5757