



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

02/17/2020

Permit # 000038985

L-26377

Re: Lot 2 Creek Run Plantation **21-4S-17-08631-102**

Peter Lev

To Whom It May Concern:

The slab found on said Lot 2 has a finished floor elevation of 105.09 feet. The highest adjacent grade is 104.3 feet. The lowest adjacent grade is 102.6 feet. The minimum floor elevation as per the building permit and the plat of record is 100.00 feet. The elevations shown hereon are based on plat datum.

Sincerely,



L. Scott Britt
LS 5757

