

J & M TESTING LAB, INC.

Consulting Geotechnical & Materials Engineers

MATERIALS TESTING

Main Office: 1053 Commerce Avenue • Chipley, FL 32428•850-638-1506

Branch Offices: 1255 Aenon Church Road • Tallahassee, FL 32304

Email: jmtestinglab@bellsouth.net

FIELD DENSITY REPORT

CONTRACTOR:

ADDRESS:

PROJECT:

LOCATION:

LAB NO:

TYPE CONSTRUCTION:

COPY TO:

MATERIAL:

DATE TESTED:

Maximum Density Determined in Accordance with: ASTM D

Method:

Field Density Determined in Accordance with: ASTM D

Method:

TEST DATA


TEST NO	Test Location	Depth Of Test	Opt. Moist. %	Maximum Density Lbs/cu/ft	Field Density Lbs/cu/ft	Moisture At Time Of Test	% MAX Dens.	Job Spec.

Tested By:

This item has been signed and sealed by Ezzeldin Benghuzzi, P.E on **/**/** using a Digital Signature. Printed copies of this document are not considered signed and sealed and the signature and authentication code must be verified on any electronic copies

***IN-PLACE DENSITY DOES NOT MEET REQUIREMENTS**

****RETEST DENSITY MEETS REQUIREMENTS**



Ezzeldin M. Benghuzzi, P.E.