

To: All Concerned Parties

Project No.
21-0536.13

From: Austin Blazs

Date: January 13, 2023

RE: Foundation Elevation & Setback Certification Letter for Lot 13, Forest Country 6th Addition

Please accept this memorandum as my certification that the foundation constructed on Lot 13, Forest Country 6th Addition, as per plat recorded in Plat Book 9, Pages 66-67, Public Records of Columbia County, FL are in compliance with the Zoning setback requirements. In addition, the elevation of the foundations of the residence currently under construction on said Lot 6, was field measured on January 31, 2023 to be **110.57** feet. The benchmark used as a basis for this measurement is based on The North American Vertical Datum of 1988 and was derived National Geodetic Survey Monument "STEINRIED AZIMUTH" (P.I.D. BD1035).

The minimum finished floor elevation, per Elevation Letter – 491 SW Pinehurst Drive, Lake City provided by Carol Chadwick, P.E., for Lot 13 is **107.00** feet.

Austin Blazs

Digitally signed by Austin Blazs
DN: E=austinb@chw-inc.com,
CN=Austin Blazs,
O="Causseaux, Hewett, &
Walpole, Inc.", L=Alachua,
S=Florida, C=US
Date: 2023.02.01 16:01:48-05'00'

Austin Blazs, PSM

Registered Florida Surveyor and Mapper Certificate Number 7401

