



Southeast Building Engineers, LLC

3578 Rolling Acres Road
Pace, FL 32571
772-774-9086
s.sanders@sebenineers.com

May 19, 2025

Subject: **Slab composition revision**
 144 SW Beacon Way
 Lake City, FL 32025
 Permit/Application #: 68190

To Whom It May Concern:

Please be advised that the slab-on-grade reinforcement previously specified as **#10 welded wire mesh (WWM)** in the approved construction documents for the above-referenced project may be substituted with **fibermesh reinforcement added at a dosage rate of 1.5 pounds per cubic yard**.

This change is being made at the request of the owner. The substitution of fibermesh reinforcement in place of welded wire mesh is acceptable for this slab-on-grade application, provided all other slab thicknesses, concrete strengths, and construction details remain as originally specified. Fibermesh is recognized as an alternative means of controlling shrinkage and temperature-related cracking in slab construction.

This letter is intended to document this substitution and confirm that it is acceptable for permitting and inspection purposes.

Sincerely,

scott r
sanderson

Digitally signed
by scott r
sanderson
Date: 2025.05.19
15:16:45 -05'00'



Scott R. Sanders, P.E.
Southeast Building Engineers, LLC

This report has been electronically signed
and sealed using a Digital Signature.
Printed copies of this document are not
considered signed and sealed and the
signature must be verified on any electronic
copies.