



12/12/13

#31578

014 7c

12-12-13

Columbia County
Building & Zoning Dept.
135 NE Hernando Street,
Lake City, FL. 32055

To Whom It May Concern:

Please find the revised drawing indicating the locations of threaded rod. Openings 3'-0" and less will do not require all thread hold downs when windstorm full height structural panels are used and installed according to the details shown on the plans. If you have any questions, please call me at (386) 965-0644.

Sincerely,

William H. Freeman 12/12/13

William H. Freeman
PE #56001
CA # 8701



