



SCANNED

Britt Surveying and Mapping, LLC
1438 SW Main Boulevard • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

05/06/2022

Permit # 000043546

L-28553


Woodman Park Builders

Re: Lot 11 Magnolia Place

To Whom It May Concern:

The top of the finished slab on Lot 11 is found to be 127.01 feet. The highest adjacent grade is 125.4 feet. The building permit shows the minimum floor elevation to be one foot above the road whose elevation is 125.5 feet for SW Cedarwood Glen or 116.0 feet or 8" above grade whichever is greater. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,



L. Scott Britt
LS 5757