



---

**Britt Surveying and Mapping, LLC**

2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

01/29/2021

Permit # 000039098

Lot 12 of Hills at Rose Creek Phase 1

L-27167

Tom Cushman

To whom it may concern,

The elevation of the top of the slab on Lot 12 is found to be 95.76 feet. The lowest adjacent grade is 92.8 feet and the highest adjacent grade is 94.7 feet. The Elevations shown hereon are based on NAVD 88 Datum. The permit shows a required MFE of 91.50 feet.

Sincerely,

A handwritten signature in blue ink, appearing to read "L. Scott Britt", is written over the printed name.

L. Scott Britt  
LS 5757