



**momentum**  
**SOLAR**

5/9/2022

Columbia County Building Department

RE: Permit revision for 54351

Dear Plans Examiner,

Enclosed are stamped plans for the above noted permit. Revisions to plans have been made as follows: **from tap box to line side tap and installed an interior disco 125a with 60a installed breaker.** Please let us know when this revision is approved.

Please advise if anything else is needed.

Sincerely,

Julia Urbanski  
321-247-6073  
flpermits@Momentumsolar.com