



April 25, 2018

Aaron Simque Homes
Lake City, FL 32025

Subject: Permit # 36219 - Lot 66 Preserve at Laurel Lakes Elevation Letter

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lot 66, Preserve at Laurel Lakes, Unit 1, Columbia County, Florida from a benchmark being a 60d nail at the common lot line between Lots 8 & 9 (elevation – 116.12', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 118.3'.
- The top of the foundation is at 119.7', being the 1.4' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM

