

ENERGY PERFORMANCE LEVEL (EPL) DISPLAY CARD

ESTIMATED ENERGY PERFORMANCE INDEX* = 100

The lower the EnergyPerformance Index, the more efficient the home.

232 Cedarwood Glen, Lake City, FL, 32024

1. New construction or existing	New (From Plans)	10. Wall Type and Insulation	Insulation	Area
2. Single family or multiple family	Detached	a. Frame - Wood, Exterior	R=13.0	1914.00 ft²
3. Number of units, if multiple family	1	b. N/A	R=	ft²
4. Number of Bedrooms	4	c. N/A	R=	ft²
5. Is this a worst case?	No	d. N/A	R=	ft²
6. Conditioned floor area (ft²)	2436	11. Ceiling Type and insulation level	Insulation	Area
7. Windows**	Description	a. Under Attic (Vented)	R=38.0	2436.00 ft²
a. U-Factor:	Dbl, U=0.36	b. N/A	R=	ft²
SHGC:	SHGC=0.19	c. N/A	R=	ft²
b. U-Factor:	Dbl, U=0.36	12. Ducts, location & insulation level	R	ft²
SHGC:	SHGC=0.25	a. Sup: Attic, Ret: Attic, AH: Main	6	487.2
c. U-Factor:	Dbl, U=0.27	13. Cooling systems	kBtu/hr	Efficiency
SHGC:	SHGC=0.24	a. Central Unit	44.0	SEER:14.00
d. U-Factor:	other (see details)	14. Heating systems	kBtu/hr	Efficiency
SHGC:	other (see details)	a. Electric Heat Pump	46.0	HSPF:8.50
Area Weighted Average Overhang Depth:	6.888 ft.	15. Hot water systems	Cap: 50 gallons	
Area Weighted Average SHGC:	0.221	a. Electric	EF: 0.95	
8. Skylights	Description	b. Conservation features		
a. U-Factor(AVG):	N/A	None		
SHGC(AVG):	N/A	Credits (Performance method)		CF, Pstat
9. Floor Types	Insulation	Area		
a. Slab-On-Grade Edge Insulation	R=0.0	2436.00 ft²		
b. N/A	R=	ft²		
c. N/A	R=	ft²		

I certify that this home has complied with the Florida Energy Efficiency Code for Building Construction through the above energy saving features which will be installed (or exceeded) in this home before final inspection. Otherwise, a new EPL Display Card will be completed based on installed Code compliant features.

Builder Signature: _____ Date: _____

Address of New Home: _____ City/FL Zip: _____



*Note: This is not a Building Energy Rating. If your Index is below 70, your home may qualify for energy efficient mortgage (EEM) incentives if you obtain a Florida Energy Rating. For information about the Florida Building Code, Energy Conservation, contact the Florida Building Commission's support staff.

**Label required by Section R303.1.3 of the Florida Building Code, Energy Conservation, if not DEFAULT.