Inspection Checklist for Permit #000054159

Notes:

Order	Category	Inspection	Requirements
1	Electrical	Temporary Power Service Allows temporary power for construction use. Ref: NEC Art. 230	
2	Building	Footer Inspects footing size, depth, and reinforcing steel before concrete placement. Ref: FBC 110.3(1)	
3	Building	Monolithic Slab Inspects reinforcement, vapor barrier, termite treatment, and plumbing prior to pour. Ref: FBC 110.3(1)	
4	Engineering	Setbacks Confirms buildings, structures, and improvements are within required property setbacks. Columbia County LDR 4.1	
5	Electrical	Footer Steel & Grounding Confirms bonding and grounding electrode conductor in foundation steel. Ref: NEC Art. 250.52	
6	Building	Slab Ensures proper base, vapor barrier, reinforcing, and termite treatment before pour. Ref: FBC 110.3(1)	
7	Electrical	1st Underground Rough–In Verifies conduit, wiring, and grounding prior to backfill. Ref: NEC Art. 300.5	
8	Plumbing/Gas	1st Underground Rough–In Inspects drainage and water piping before backfill. Ref: FBC-P 312	
9	Building	Roof Decking Checks roof sheathing attachment and fastener pattern per FBC wind zones. Ref: FBC 110.3(3)	Requires Document Surveyor Letter Confirming Finished Floor Elevation.
10	Building	Wall Sheathing Confirms nail/screw spacing and panel installation per plans. Ref: FBC 110.3(3)	Requires Document Surveyor Letter Confirming Finished Floor Elevation.
11	Building	Ext Strapping/Wall Sheathing Verifies wall sheathing, nailing, and exterior strapping per wind-load requirements. Ref: FBC 110.3, 1609	Requires Document Surveyor Letter Confirming Finished Floor Elevation.

12	Building	Lintel/Tie Beam Ensures lintel/tie beam reinforcing steel and anchorage are correct before pour. Ref: FBC 110.3	Requires Document Surveyor Letter Confirming Finished Floor Elevation.
13	Building	Lath/Stucco Checks stucco lath, weep screeds, and moisture barriers before application. Ref: FBC 110.3	Requires Document Surveyor Letter Confirming Finished Floor Elevation.
14	Building	Vertical Cells/Columns Checks filled masonry cells or columns for reinforcing and grout. Ref: FBC 2122.2	Requires Document Surveyor Letter Confirming Finished Floor Elevation.
15	Building	Framing Reviews structural framing, load paths, fire blocking, and MEP rough- ins prior to insulation. Ref: FBC 110.3(3)	Requires Document Surveyor Letter Confirming Finished Floor Elevation.
16	Building	Window Attachment Verifies fastening of windows/doors for impact and wind load compliance. Ref: FBCR 609	Requires Document Surveyor Letter Confirming Finished Floor Elevation.
17	Plumbing/Gas	2nd Rough-In Reviews piping, venting, and fixtures before wall close. Ref: FBC-P 312	Requires Framing.Requires Document Surveyor Letter Confirming Finished Floor Elevation.
18	Plumbing/Gas	Tub Set/Shower Pan Verifies water-tightness and slope before tile. Ref: FBC-P 312.9	Requires Framing.Requires Document Surveyor Letter Confirming Finished Floor Elevation.
19	Mechanical	Rough In Checks ductwork, equipment location, and condensate before covering. Ref: FBC-M 603	Requires Framing.Requires Document Surveyor Letter Confirming Finished Floor Elevation.
20	Electrical	2nd Rough-In Checks wiring, panel placement, and boxes before cover-up. Ref: NEC Art. 110.3	Requires Framing.Requires Document Surveyor Letter Confirming Finished Floor Elevation.
21	Building	Insulation Verifies insulation type, R-value, and installation before drywall. Ref: FBC Energy C101.5	Requires Framing.Requires Document Surveyor Letter Confirming Finished Floor Elevation.
22	Electrical	Permanent Power Releases power once service equipment is complete and safe. Ref: NEC Art. 230	Requires Document Surveyor Letter Confirming Finished Floor Elevation.
23	City of Lake City Utilities	Lake City Utilities Tap Inspection Conducted when required by the City to verify proper connection and availability of utility services. Ref: City of Lake City	

24	Building	Final Ensures structure is complete, safe, and code-compliant before Certificate of Occupancy. Ref: FBC 110.5	
25	Certificate	Release Certificate Official Release for CO or final completion. Ref: FBC 110.5	Requires Final .