


From: [Isaiah Cully](#)
To: [Gary Pitzer](#)
Subject: Fwd: Electrical concern
Date: Tuesday, August 15, 2023 6:03:03 PM

Response from client out at 523 SW. upstage Glen

Isaiah Cully
Owner
IC CONSTRUCTION LLC

■ [3868670086](tel:3868670086)
■ isaiah@nflbuild.com
■ nflbuild.com
■ 818 W Duval St



Begin forwarded message:

From: Darren Knoll <knolldgk@gmail.com>
Date: August 15, 2023 at 5:44:31 PM EDT
To: Isaiah Cully <isaiah@nflbuild.com>
Subject: Re: Electrical concern

Yes, we are fine with the current outlet configuration and location. No need to add a second outlet.

Darren Knoll

On Tue, Aug 15, 2023 at 2:43 PM Isaiah Cully <isaiah@nflbuild.com> wrote:
Per final building inspection on 8/14/2023 note “need outlet added to countertop under window”
Building inspector would like acknowledgment that building code states outlet every 2 feet. Outlet location has been reviewed with homeowner and homeowner is OK with current outlet locations.
24 inch outlet spacing is not available due to window, and window trim location.

Isaiah Cully
Owner
IC CONSTRUCTION LLC

- 3868670086
- isaiah@nflbuild.com
- nflbuild.com
- [818 W Duval St](#)

