



Project Summary

Entire House


Job: J-11120 - C-1635
Date: Aug 29, 2024
By: LaNiika Stewart

31

Project Information

For: Jairo Aguledo
312 SW Hammock Hill Circle, Lake County, FL 32034

Notes:



Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Outside db 33 °F
Inside db 70 °F
Design TD 37 °F

Ventilation Method MJ8

Heating Summary

Structure 16896 Btuh
Ducts (R-6.0) 3421 Btuh
Central vent (0 cfm) 0 Btuh

Humidification 0 Btuh
Piping 0 Btuh
Equipment load 20317 Btuh

Infiltration

Method Simplified
Construction quality Average
Fireplaces 0

	Heating	Cooling
Area (ft ²)	1100	1100
Volume (ft ³)	10354	10354
Air changes/hour	0.45	0.23
Equiv. AVF (cfm)	78	40

Heating Equipment Summary

Make Daikin
Trade DAIKIN
Model DZ6VSA3010A
AHRI ref 210791258

Efficiency 8.2 HSPF2
Heating input
Heating output 22800 Btuh @ 47°F
Temperature rise 25 °F
Actual air flow 833 cfm
Air flow factor 0.041 cfm/Btuh
Static pressure 0.53 in H2O
Space thermostat
Capacity balance point = 28 °F

Backup:
Input = 6 kW, Output = 19703 Btuh, 100 AFUE

Summer Design Conditions

Outside db 92 °F
Inside db 75 °F
Design TD 17 °F
Daily range M
Relative humidity 50 %
Moisture difference 43 gr/lb

Sensible Cooling Equipment Load Sizing

Structure 13442 Btuh
Ducts (R-6.0) 4760 Btuh
Central vent (0 cfm) 0 Btuh

Blower 0 Btuh

Use manufacturer's data y
Rate/swing multiplier 1.00
Equipment sensible load 18202 Btuh

Latent Cooling Equipment Load Sizing

Structure 1968 Btuh
Ducts 972 Btuh
Central vent (0 cfm) 0 Btuh

Equipment latent load 2940 Btuh

Equipment Total Load (Sen+Lat) 21142 Btuh
Req. total capacity at 0.80 SHR 1.9 ton

Cooling Equipment Summary

Make Daikin
Trade DAIKIN
Cond DZ6VSA3010A
Coil DV35FECC14A
AHRI ref 210791258
Efficiency 9.9 EER2, 17.1 SEER2
Sensible cooling 20000 Btuh
Latent cooling 5000 Btuh
Total cooling 25000 Btuh
Actual air flow 833 cfm
Air flow factor 0.046 cfm/Btuh
Static pressure 0.53 in H2O
Load sensible heat ratio 0.86

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2024 24.0.02 RSU11033

...eted JobsJ-11120 - C-1635J-11120 - C-1635.rup Calc = MJ8 Front Door faces: N

2024-Aug-29 16:18:53

Page 1



Manual S Compliance Report

Entire House

Job: J-11120 - C-1635
Date: Aug 29, 2024
By: LaNiika Stewart

Project Information

For: Jairo Aguledo
312 SW Hammock Hill Circle, Lake County, FL 32034

Cooling Equipment

Design Conditions

Outdoor design DB:	92.4°F	Sensible gain:	18202	Btuh	Entering coil DB:	77.6°F
Outdoor design WB:	75.8°F	Latent gain:	2940	Btuh	Entering coil WB:	63.7°F
Indoor design DB:	75.0°F	Total gain:	21142	Btuh		
Indoor RH:	50%	Estimated airflow:	833	cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Daikin	Model:	DZ6VSA3010A+DV35FECC14A		
Actual airflow:	833	cfm			
Sensible capacity:	19900	Btuh	109%	of load	
Latent capacity:	4331	Btuh	147%	of load	
Total capacity:	24231	Btuh	115%	of load	SHR: 82%

Heating Equipment

Design Conditions

Outdoor design DB:	33.3°F	Heat loss:	20317	Btuh	Entering coil DB:	68.7°F
Indoor design DB:	70.0°F					

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Daikin	Model:	DZ6VSA3010A+DV35FECC14A		
Actual airflow:	833	cfm			
Output capacity:	22283	Btuh	110%	of load	Capacity balance: 28 °F
Supplemental heat required:	0	Btuh			Economic balance: -99 °F

Backup equipment type:	Elec strip				
Manufacturer:		Model:			
Actual airflow:	833	cfm			
Output capacity:	5.8	kW	97%	of load	Temp. rise: 50 °F

Meets all requirements of ACCA Manual S.



Right-Suite® Universal 2024 24.0.02 RSU11033
...eted JobsJ-11120 - C-1635J-11120 - C-1635.rup Calc = MJ8 Front Door faces: N

2024-Aug-29 16:18:53

Page 1



Duct System Summary

Entire House

Job: J-11120 - C-1635
Date: Aug 29, 2024
By: LaNiika Stewart

Project Information

For: Jairo Aguledo
312 SW Hammock Hill Circle, Lake County, FL 32034

	Heating	Cooling
External static pressure	0.53 in H2O	0.53 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.53 in H2O	0.53 in H2O
Supply / return available pressure	0.444 / 0.086 in H2O	0.444 / 0.086 in H2O
Lowest friction rate	0.219 in/100ft	0.219 in/100ft
Actual air flow	833 cfm	833 cfm
Total effective length (TEL)	242 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Bath 2	c 94	2	4	0.251	4.0	0x0	VIFx	6.7	170.0	st1
Bed 2	h 4316	177	93	0.225	8.0	0x0	VIFx	22.6	175.0	st1
Bed 3	h 1939	80	63	0.225	6.0	0x0	VIFx	17.5	180.0	st1A
Great Room	c 3483	123	159	0.224	7.0	0x0	VIFx	28.0	170.0	st1A
Great Room-A	c 3483	123	159	0.219	7.0	0x0	VIFx	13.0	190.0	st1A
Kitchen	c 4433	128	203	0.219	8.0	0x0	VIFx	33.0	170.0	st1A
M Bath	h 1226	50	37	0.291	4.0	0x0	VIFx	12.5	140.0	st1
Master	h 3660	150	115	0.333	7.0	0x0	VIFx	8.5	125.0	st1

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1A	Peak AVF	453	584	0.219	601	10.1	14 x 10	RectFbg	st1
st1	Peak AVF	833	833	0.219	536	11.6	16 x 14	RectFbg	


Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb2	0x0	177	93	37.3	0.230	507	8.0	0x 0		VIFx	
rb3	0x0	456	589	39.2	0.219	551	14.0	0x 0		VIFx	
rb1	0x0	200	152	35.4	0.242	574	8.0	0x 0		VIFx	





Duct Layout



Job #: J-11120 - C-1635
Performed by LaNiika Stewart for:
Jairo Agüedo
312 SW Hammock Hill Circle
Lake County, FL 32034

Scale: 1 : 67
Page 1
Right-Suite® Universal 2024
24.0.02 RSU11033
2024-Aug-29 16:19:13
...20 - C-1635\J-11120 - C-1635.rup