



City of Lake City Accessibility Letter Required before Building Permit Issuance



Service Representatives :

Growth Management: growthmanagement@lcfla.com,

Utilities: PelhamS@lcfla.com, MedearisK@lcfla.com, McGhinB@lcfla.com

Date: 10/7/2024

County Application # 67390

Applicant Name: PATEL

Phone:

Email: PJPATEL@ATLANTIC.NET

Site Address: 545 NW FAIRWAY DR LAKE CITY, FL 32055

Parcel: 26-3S-16-02309-013

Acres: 0.60

Project Description: Generator

Existing Structures on Property:

Any tree removal:

Number of trees removed:

Trees remaining:

Utilities:

Utility Accessibility: Water: Available Sewer: Available Gas: Available City Letter of Accessibility Required: No

Utility Active: Water: Active Sewer: Active Gas: Active Has Impact Fee: No Impact Fees paid:

Customer service official's name: **Shasta Pelham**

Reviewed: 10/11/2024

Requires Tap Inspection: No

Customer service official's notes: The Gas Department increased the meter pressure to accommodate the additional demand.

Zoning:

Minimum Setback Requirements: Font: Side: Rear:

Landscape Requirements:

Flood Zone: B.F.E.: Finished Floor Elevation Requirement:

Site Approval Plan:

Special Exception: Variance:

Documents Required:

Needed Before Power: No

Needed Before CO: No

Zoning official clearance

Date Reviewed:

Access:

Permit Issued: Needed Before CO:

Access official clearance

Date Reviewed:

Code Enforcement:

Code Enforcement Cases: None Case Notes:

Code Enforcement clearance

Date Reviewed:

Special Notes to be noted on permit