



NFPS



PO BOX 3823
LAKE CITY, FL 32056



PHONE (386) 752-4675
FAX (386) 752-4674



www.nfps.net

September 29, 2021

Josh Sparks
4974 SW 114 Street Road
Ocala, FL 34476

SUBJECT: ELEVATION LETTER
Parcel No. 22-4S-16-03087-117
372 SW Blackpine Terrace

To Whom It May Concern:


Parcel No. 22-4S-16-03087-117 is located in Flood Zone X. The property naturally slopes northwest toward SW Shortleaf Drive. The structure will be elevated on a stem wall. Stormwater will flow around the structure to the northwest.

Requirements for Structure to Be Protected from the Base Flood Event:

The finished floor elevation for the foundation of the structure shall be at 106 feet NAVD and at least one (1) ft. above the highest adjacent natural grade at the proposed building site. Any disturbed area around the proposed structure shall be graded to direct all runoff to the northwest.

Sincerely,

Terry R. White, Jr., P.E.
Water Resources Engineer



I certify that the finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Digitally signed by Terry R White
Date: 2021.09.29 10:29:00-04'00'

Terry R. White, Jr., P.E.

9/29/21

Date