

# Florida Building Code, Sixth Edition (2017) - Energy Conservation

EnergyGauge Summit® Fla/Com-2017, Effective Date: Dec 31, 2017

ASHRAE 90.1-2013 - Energy Cost Budget Option

## Check List

Applications for compliance with the Florida Building Code, Energy Conservation shall include:

- This Checklist
- The full compliance report generated by the software that contains the project summary, compliance summary, certifications and detailed component compliance reports.
- The compliance report must include the full input report generated by the software as contiguous part of the compliance report.
- Boxes appropriately checked in the Mandatory Section of the compliance report.

## PROJECT SUMMARY

<p><b>Short Desc:</b> 20031</p> <p><b>Owner:</b> Belmont Academy</p> <p><b>Address1:</b> 5037 SR 240</p> <p><b>Address2:</b></p> <p><b>Type:</b> School/University</p> <p><b>Jurisdiction:</b> LAKE CITY, COLUMBIA COUNTY, FL (221200)</p> <p><b>Conditioned Area:</b> 17248 SF</p> <p><b>No of Stories:</b> 2</p> <p><b>Permit No:</b> 0</p>	<p><b>Description:</b> 2nd Floor Build-Out</p> <p><b>City:</b> Lake City</p> <p><b>State:</b> FL</p> <p><b>Zip:</b> 32024</p> <p><b>Class:</b> Addition to existing Building</p> <p><b>Conditioned &amp; UnConditioned Area:</b> 17248 SF</p> <p><b>Area entered from Plans:</b> 17332 SF</p> <p><b>Max Tonnage:</b> 99.3</p> <p><b>If different, write in:</b> _____</p>
---	---

Registered Professionals:		
	Name	Registration/License No.
<b>Owner/Agent:</b>		
<b>Prepared By:</b>		
<b>Licensee:</b>	John W. Wells, III, P.E.	PE49347
<b>Engineering Business:</b>	Consulting Engineering Associates, Inc.	Registry 3962
<b>Architect:</b>		
<b>Licensee:</b>	Nicholas Paul Geisler Architect	AR0007005
<b>Engineering Business:</b>	Nicholas Paul Geisler Architect	AR0007005
<b>Electrical Designer:</b>		
<b>Licensee:</b>	David D. Patton, Jr., P.E.	PE52909
<b>Engineering Business:</b>	Consulting Engineering Group	PE52909
<b>Lighting Designer:</b>		
<b>Licensee:</b>	David D. Patton, Jr., P.E.	PE52909
<b>Engineering Business:</b>	Consulting Engineering Group	PE52909
<b>Mechanical Designer:</b>		
<b>Licensee:</b>	John W. Wells, III, P.E.	PE49347
<b>Engineering Business:</b>	Consulting Engineering Associates, Inc.	Registry 3962

## Compliance Summary

Component	Design	Criteria	Result
Gross Energy Cost (in \$)	10,227.0	12,569.0	<b>PASSED</b>
LIGHTING CONTROLS			<b>PASSES</b>
EXTERNAL LIGHTING			<b>No Entry</b>
HVAC SYSTEM			<b>PASSES</b>
PLANT			<b>PASSES</b>
WATER HEATING SYSTEMS			<b>PASSES</b>
PIPING SYSTEMS			<b>PASSES</b>
Met all required compliance from Check List?			<b>Yes/No/NA</b>
 <b>IMPORTANT MESSAGE</b>			
Info 5009 -- -- -- An input report of this design building must be submitted along with this Compliance Report			

## CERTIFICATIONS

I hereby certify that the plans and specifications covered by this calculation are in compliance with the Florida Energy Code

Prepared By: John W. Wells, III, PE

Building Official: \_\_\_\_\_

Date: \_\_\_\_\_

Date: \_\_\_\_\_

I certify that this building is in compliance with the FLorida Energy Efficiency Code

Owner Agent: \_\_\_\_\_

Date: \_\_\_\_\_

If Required by Florida law, I hereby certify (\*) that the system design is in compliance with the Florida Energy Efficiency Code

Architect: Nicholas Paul Geisler Architec

Reg No: AR0007005

Electrical Designer: Consulting Engineering Group

Reg No: PE52909

Lighting Designer: Consulting Engineering Group

Reg No: PE52909

Mechanical Designer: Consulting Engineering Assoc:

Reg No: PE49347

Plumbing Designer: Consulting Engineering Assoc:

Reg No: PE49347

(\*) Signature is required where Florida Law requires design to be performed by registered design professionals. Typed names and registration numbers may be used where all relevant information is contained on signed/sealed plans.

Project: 20031  
 Title: 2nd Floor Build-Out  
 Type: School/University  
 (WEA File: FL\_JACKSONVILLE\_INTL\_ARPT.tm3)

**Building End Uses**

	1) Proposed	2) Baseline
<b>Total</b>	<b>645.20</b>	<b>794.33</b>
	<b>\$10,227</b>	<b>\$12,569</b>
ELECTRICITY(MBtu/kWh/\$)	645.20	794.33
	189048	232751
	<b>\$10,227</b>	<b>\$12,569</b>
AREA LIGHTS	82.80	181.20
	24251	53079
	<b>\$1,312</b>	<b>\$2,866</b>
DOMHOT WATER	77.20	77.20
	22629	22629
	<b>\$1,224</b>	<b>\$1,222</b>
MISC EQUIPMT	115.40	115.40
	33821	33821
	<b>\$1,830</b>	<b>\$1,826</b>
PUMPS & MISC	15.10	0.38
	4411	115
	<b>\$239</b>	<b>\$6</b>
SPACE COOL	306.90	318.33
	89935	93275
	<b>\$4,865</b>	<b>\$5,037</b>
SPACE HEAT	9.90	12.78
	2903	3741
	<b>\$157</b>	<b>\$202</b>
VENT FANS	37.90	89.05
	11098	26092
	<b>\$600</b>	<b>\$1,409</b>

Credits Applied: None

Passing Criteria = 12569

Design (including any credits) = 10227

Passing requires Proposed Building cost to be at most 100% of Baseline cost. This Proposed Building is at 81.4%

**PASSES**

--

<b>External Lighting Compliance</b>						
<b>Description</b>	<b>Category</b>	<b>Tradable?</b>	<b>Allowance (W/Unit)</b>	<b>Area or Length or No. of Units (Sqft or ft)</b>	<b>ELPA (W)</b>	<b>CLP (W)</b>
						<b>None</b>

**Project: 20031**  
**Title: 2nd Floor Build-Out**  
**Type: School/University**  
**(WEA File: FL JACKSONVILLE INTL ARPT.tm3)**

### Lighting Controls Compliance

Acronym	Ashrae ID	Description	Area (sq.ft)	Design CP	Min CP	Compliance
classroom #1	14	Classroom/Lecture Hall	582	1	1	PASSES
storage	3	Storage & Warehouse - Bulky Active Storage	40	1	1	PASSES
classroom #2	14	Classroom/Lecture Hall	678	1	1	PASSES
classroom #3	14	Classroom/Lecture Hall	697	1	1	PASSES
classroom #4	14	Classroom/Lecture Hall	666	1	1	PASSES
corridors	5	Corridor	4,283	3	2	PASSES
classroom #5	14	Classroom/Lecture Hall	782	1	1	PASSES
classroom #6	14	Classroom/Lecture Hall	783	1	1	PASSES
classroom #7	14	Classroom/Lecture Hall	795	2	1	PASSES
classroom	14	Classroom/Lecture Hall	618	1	1	PASSES
janitor	3	Storage & Warehouse - Bulky Active Storage	155	2	2	PASSES
classroom #9	14	Classroom/Lecture Hall	782	1	1	PASSES
classroom #10	14	Classroom/Lecture Hall	783	1	1	PASSES
classroom #11	14	Classroom/Lecture Hall	793	2	1	PASSES
Men's rr	6	Toilet and Washroom	468	2	1	PASSES
women's rr	6	Toilet and Washroom	469	2	1	PASSES
electrical room	1	Electrical Mechanical Equipment Room - General	169	1	1	PASSES
classroom	14	Classroom/Lecture Hall	656	1	1	PASSES
classroom #13	14	Classroom/Lecture Hall	611	1	1	PASSES
Flex Space	15	Conference/meeting (Multiple Functions)	322	1	1	PASSES
Flex Space	15	Conference/meeting (Multiple Functions)	226	1	1	PASSES
Restroom	6	Toilet and Washroom	43	1	1	PASSES
Restroom	6	Toilet and Washroom	43	1	1	PASSES
Storage	2	Storage & Warehouse - Inactive Storage	50	1	1	PASSES
west stair	4	Stair - Active Traffic	89	1	1	PASSES
Elev Mach Rm	1	Electrical Mechanical Equipment Room - General	50	1	1	PASSES
east stair 1st fl	4	Stair - Active Traffic	310	1	1	PASSES
E stair corr 1st FL	5	Corridor	824	1	1	PASSES
east stair 2nd FL	4	Stair - Active Traffic	326	1	1	PASSES

**PASSES**

Project: 20031  
 Title: 2nd Floor Build-Out  
 Type: School/University  
 (WEA File: FL JACKSONVILLE\_INTL\_ARPT.tm3)

### System Report Compliance

**AHU-2 System 1** Variable Air Volume Built-up System No. of Units 1

Component	Category	Capacity	Design Eff	Eff Criteria	Design IPLV	IPLV Criteria	Compliance
Cooling System	Compliance Not Applicable	784700					PASSES
Heating System	Electric Furnace	432362	1.00	1.00			PASSES
Air Handling System -Supply	Air Handler (Supply) - Variable Volume	12200	0.75	0.97			PASSES

**PTAC System 2** Room Units (Airconditioners & Heat pumps) No. of Units 1

Component	Category	Capacity	Design Eff	Eff Criteria	Design IPLV	IPLV Criteria	Compliance
Cooling System	Room Airconditioners Casement Only	18000	9.50	8.70			PASSES
Heating System	PTHP All Capacities (Heating Mode)	16400	2.92	2.92			PASSES
Air Handling System -Supply	Air Handler (Supply) - Constant Volume	400	0.80	0.82			PASSES

**ACU-1 System 3** Constant Volume Air Cooled Split System < 65000 Btu/hr No. of Units 1

Component	Category	Capacity	Design Eff	Eff Criteria	Design IPLV	IPLV Criteria	Compliance
Cooling System	Air Conditioners Air Cooled Split System < 65000 Btu/h Cooling Capacity	18000	14.20	13.00	8.00		PASSES
Heating System	Heat Pumps Air Cooled (Heating Mode) Split System < 65000 Btu/h Cooling Capacity	19000	9.80	8.20			PASSES
Air Handling System -Supply	Air Handler (Supply) - Constant Volume	710	0.10	0.82			PASSES

**ACU-2 System 4** Constant Volume Air Cooled Split System < 65000 Btu/hr No. of Units 1

Component	Category	Capacity	Design Eff	Eff Criteria	Design IPLV	IPLV Criteria	Compliance
-----------	----------	----------	------------	--------------	-------------	---------------	------------



Cooling System	Air Conditioners Air Cooled Split System < 65000 Btu/h Cooling Capacity	9000	24.60	13.00	8.00	<b>PASSES</b>
Heating System	Heat Pumps Air Cooled (Heating Mode) Split System < 65000 Btu/h Cooling Capacity	10900	12.80	8.20		<b>PASSES</b>
Air Handling System -Supply	Air Handler (Supply) - Constant Volume	307	0.10	0.82		<b>PASSES</b>
<b>PASSES</b>						

<b>Plant Compliance</b>								
Description	Installed No	Size	Design Eff	Min Eff	Design IPLV	Min IPLV	Category	Compliance
Hermetic screw or scroll chiller	1	99	2.990	2.960	4.510	4.015	Water Chilling Packages (Elec), Air Cooled (Pos Displ) < 150 Tons	<b>PASSES</b>
<b>PASSES</b>								

**Project: 20031**  
**Title: 2nd Floor Build-Out**  
**Type: School/University**  
**(WEA File: FL\_JACKSONVILLE\_INTL\_ARPT.tm3)**

<b>Water Heater Compliance</b>								
Description	Type	Category	Design Eff	Min Eff	Design Loss	Max Loss	Compliance	
Water Heater 1	Electric water heater	<= 12 [kW]	0.96	0.95			<b>PASSES</b>	
<b>PASSES</b>								

**Project: 20031**  
**Title: 2nd Floor Build-Out**  
**Type: School/University**  
**(WEA File: FL\_JACKSONVILLE\_INTL\_ARPT.tm3)**

**Piping System Compliance**

Category	Pipe Dia [inches]	Is Runout?	Operating Temp [F]	Ins Cond [Btu-in/hr .SF.F]	Ins Thick [in]	Req Ins Thick [in]	Compliance
Domestic and Service Hot Water Systems	1.00	False	120.00	0.28	1.00	0.50	<b>PASSES</b>

**PASSES**

# Mandatory Requirements (as applicable)

Mandatory requirements compiled by US Department of Energy and Pacific Northwest National Laboratory. Adopted with permission

Topic	Section	Component	Description	Yes	N/A	Exempt
<b>1. To be checked by Designer or Engineer</b>						
Insulation	5.8.1.2	Envelope	Below-grade wall insulation installed per manufacturer's instructions.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.2	Envelope	Slab edge insulation installed per manufacturer's instructions.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Insulation	5.5.3.5	Envelope	Slab edge insulation depth/length.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Insulation	6.4.4.1.5	Envelope	Bottom surface of floor structures incorporating radiant heating insulated to $\geq R-3.5$ .	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Fenestration	5.5.3.6	Envelope	U-factor of opaque doors associated with the building thermal envelope meets requirements.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.1, 6.5.1.1, 6.5.1.3, 6.5.1.4	Mechanical	Air economizers provided where required (and not exempted), meet the requirements for design capacity, control signal, ventilation controls, high-limit shut-off, integrated economizer control, and provide a means to relieve excess outside air during operation.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.1, 6.5.1.2, 6.5.1.3	Mechanical	Water economizers provided where required, meet the requirements for design capacity, maximum pressure drop and integrated economizer control.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.1.5	Mechanical	Economizer operation will not increase heating energy use during normal operation.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.2.2.1	Mechanical	Three-pipe hydronic systems using a common return for hot and chilled water are not used.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.2.2.3	Mechanical	Hydronic heat pump systems connected to a common water loop meet heat rejection and heat addition requirements.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.1.6	Mechanical	Water economizer specified on hydronic cooling and humidification systems designed to maintain inside humidity at $>35$ °F dewpoint if an economizer is required.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.3.1.1	Mechanical	HVAC fan systems at design conditions do not exceed allowable fan system motor nameplate hp or fan system bhp.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.3.1.2	Mechanical	HVAC fan motors not larger than the first available motor size greater than the bhp.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.5.6.1	Mechanical	Exhaust air energy recovery on systems meeting Tables 6.5.6.1-1, and 6.5.6.1-2.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.2	Mechanical	Service water heating equipment meets efficiency requirements.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.5.2	Mechanical	Service water heating equipment used for space heating complies with the service water heating equipment requirements.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.2	Envelope	Above-grade wall insulation installed per manufacturer's instructions.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.2	Envelope	Floor insulation installed per manufacturer's instructions.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Controls	10.4.3	Mechanical	Elevators are designed with the proper lighting, ventilation power, and standby mode.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.1.1, 6.8.1-7a	Mechanical	Heat Rejection Equipment: Minimum Efficiency Requirement Table 6.8.1-7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.1.1, 6.8.1-7b	Mechanical	Heat Rejection Equipment: Minimum Efficiency Requirement Table 6.8.1-7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.1.1, 6.8.1-7c	Mechanical	Heat Rejection Equipment: Minimum Efficiency Requirement Table 6.8.1-7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

SYSTEM_SPECIFIC	6.4.1.1, 6.8.1-7d	Mechanical	Heat Rejection Equipment: Minimum Efficiency Requirement Table 6.8.1-7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.5.3	Mechanical	Centrifugal fan open-circuit cooling towers having combined rated capacity >= 1100 gpm meets minimum efficiency requirement: Table 6.8.1-7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.1.1, 6.8.1-7e	Mechanical	Heat Rejection Equipment: Minimum Efficiency Requirement Table 6.8.1-7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.1.1, 6.8.1-7f	Mechanical	Heat Rejection Equipment: Minimum Efficiency Requirement Table 6.8.1-7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.1.1, 6.8.1-7g	Mechanical	Heat Rejection Equipment: Minimum Efficiency Requirement Table 6.8.1-7.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.1.1, 6.8.1-7h	Mechanical	Heat Rejection Equipment: Minimum Efficiency Requirement Table 6.8.1-7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.1.1, 6.8.1-7i	Mechanical	Heat Rejection Equipment: Minimum Efficiency Requirement Table 6.8.1-7	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.5.3	Mechanical	Gas-fired water-heating equipment installed in new buildings: where a singular piece of water-heating equipment >= 1,000 kBtu/h serves the entire building, thermal efficiency must be >= 90 Et. Where multiple pieces of water-heating equipment serve the building with combined rating is >= 1,000 kBtu/h, the combined input-capacity-weighted-average thermal efficiency, thermal efficiency must be >= 90 Et. Exclude input rating of equipment in individual dwelling units and equipment <= 100 kBtu/h.	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

## 2. To be checked by Plan Reviewer

Plan Review	4.2.2, 5.4.3.1.1, 5.7	Envelope	Plans and/or specifications provide all information with which compliance can be determined for the building envelope and document where exceptions to the standard are claimed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Plan Review	4.2.2, 6.4.4.2.1, 6.7.2	Mechanical	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the mechanical systems and equipment and document where exceptions to the standard are claimed. Load calculations per acceptable engineering standards and handbooks.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Plan Review	4.2.2, 7.7.1, 10.4.2	Mechanical	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the service water heating systems and equipment and document where exceptions to the standard are claimed. Hot water system sized per manufacturer's sizing guide.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Plan Review	4.2.2, 8.4.1.1, 8.4.1.2, 8.7	Project	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the electrical systems and equipment and document where exceptions are claimed. Feeder connectors sized in accordance with approved plans and branch circuits sized for maximum drop of 3%.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Plan Review	4.2.2, 9.4.3, 9.7	Interior Lighting	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the interior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided should include interior lighting power calculations, wattage of bulbs and ballasts, transformers and control devices.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Plan Review	9.7	Exterior Lighting	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the exterior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided should include exterior lighting power calculations, wattage of bulbs and ballasts, transformers and control devices.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Insulation	5.8.1.7.3	Envelope	Insulation in contact with the ground has $\leq 0.3\%$ water absorption rate per ASTM C272.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Air Leakage	5.4.3.4	Envelope	Vestibules are installed where building entrances separate conditioned space from the exterior, and meet exterior envelope requirements. Doors have self-closing devices, and are $\geq 7$ ft apart ( $\geq 16$ ft apart for adjoining floor area $\geq 40000$ sq.ft.). Vestibule floor area $\leq 750$ sq.ft. or 2 percent of the adjoining conditioned floor area.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.4.4	Mechanical	Ventilation fans $> 0.75$ hp have automatic controls to shut off fan when not required.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.8	Mechanical	Demand control ventilation provided for spaces $> 500$ ft <sup>2</sup> and $> 25$ people/1000 ft <sup>2</sup> occupant density and served by systems with air side economizer, auto modulating outside air damper control, or design airflow $> 3,000$ cfm.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.4.1.4	Mechanical	Thermally ineffective panel surfaces of sensible heating panels have insulation $\geq R-3.5$ .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.5.2.3	Mechanical	Dehumidification controls provided to prevent reheating, recooling, mixing of hot and cold airstreams or concurrent heating and cooling of the same airstream.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.3.1.3	Mechanical	Fans have efficiency grade (FEG) $\geq 67$ . The total efficiency of the fan at the design point of operation $\leq 15\%$ of maximum total efficiency of the fan.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.3.5	Mechanical	Motors for fans $\geq 1/12$ hp and $< 1$ hp are electronically-commutated motors or have a minimum motor efficiency of 70%. These motors are also speed adjustable for either balancing or remote control.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.3.10	Mechanical	DDC system installed and capable of providing control logic including monitoring zone and system demand for fan pressure, pump pressure, heating, and cooling; transferring zone and system demand information from zones to air distribution system controllers and from air distribution systems to heating and cooling plant controllers; automatically detecting and alerting system operator when zones and systems excessively drive the reset logic; allow operator removal of zone(s) from the reset algorithm; AND capable of trending and graphically displaying input and output points.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.3.2.3	Mechanical	Reset static pressure setpoint for DDC controlled VAV boxes reporting to central controller based on the zones requiring the most pressure. Controls provide: zone damper monitoring or indicator of static pressure need; autodetection, alarm, and operator override of zones excessively triggering reset logic.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.3.3	Mechanical	Multiple zone VAV systems with DDC of individual zone boxes have static pressure setpoint reset controls.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.3.4	Mechanical	Multiple zone HVAC systems have supply air temperature reset controls.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.4.1	Mechanical	System turndown requirement met through multiple single-input boilers, one or more modulating boilers, or a combination of single-input and modulating boilers. Boiler input between 1.0 MBtu/h and 5 MBtu/h has 3:1 turndown ratio, boiler input between 5.0 MBtu/h and 10 MBtu/h has 4:1 turndown ratio, boiler input $> 10.0$ MBtu/h has 5:1 turndown ratio.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.5.4.2	Mechanical	HVAC pumping systems $> 10$ hp designed for variable fluid flow.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.4.3, 6.5.4.3.1, 6.5.4.3.2	Mechanical	Fluid flow shutdown in pumping systems to multiple chillers or boilers when systems are shut down.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

SYSTEM_SPECIFIC	6.5.4.4	Mechanical	Temperature reset by representative building loads in pumping systems >10 hp for chiller and boiler systems >300,000 Btu/h.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.4.5.2	Mechanical	Hydronic heat pumps and water-cooled unitary air conditioners with pump systems >5 hp have controls or devices to reduce pump motor demand.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.4.6	Mechanical	Chilled-water and condenser water piping sized according to design flow rate and total annual hours of operation (Table 6.5.4.6).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.5.2.1	Mechanical	Fan systems with motors >=7.5 hp associated with heat rejection equipment to have capability to operate at 2/3 of full-speed and auto speed controls to control the leaving fluid temperature or condensing temp/pressure of heat rejection device.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.5.2.2	Mechanical	Multicell heat rejection equipment with variable-speed fan drives installed that operate the maximum number of fans allowed that comply with manufacturers specs and control all fans to the same fan speed required for the instantaneous cooling duty.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.5.2.3	Mechanical	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.5.7.1.1	Mechanical	Kitchen hoods >5,000 cfm have make up air >=50% of exhaust air volume.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.5.7.1.1	Mechanical	Kitchen hoods >5,000 cfm have make up air >=50% of exhaust air volume.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.7.1.2	Mechanical	Conditioned supply air to space with a kitchen hood shall not exceed the greater of a) supply flow required to meet space heating or cooling, or b) hood exhaust flow minus the available air transfer from available spaces.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.7.1.3	Mechanical	Kitchen hoods with a total exhaust airflow rate >5000 cfm meet replacement air, ventilation system, or energy recovery requirements shown in Table 6.5.7.1.3.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.7.1.4	Mechanical	Kitchen hoods with a total exhaust airflow rate >5000 cfm meet replacement air, ventilation system, or energy recovery requirements.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.5.7.2	Mechanical	Fume hoods exhaust systems >=5,000 cfm have VAV hood exhaust and supply systems, direct make-up air or heat recovery.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.5.8.1	Mechanical	Unenclosed spaces that are heated use only radiant heat.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.5.1	Mechanical	Combined space and water heating system not allowed unless standby loss less than calculated maximum. AHJ has approved or combined connected load <150 kBtu/h.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Controls	8.4.2	Project	At least 50% of all 125 volt 15- and 20-Amp receptacles are controlled by an automatic control device.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Other Equipment	10.4.1	Mechanical	Electric motors meet requirements where applicable.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.3.2	Mechanical	Setback controls allow automatic restart and temporary operation as required for maintenance.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.3.3.3	Mechanical	Systems with setback controls and DDC include optimum start controls. Optimum start algorithm considers mass radiant slab floor temperature.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.3.3.4	Mechanical	Zone isolation devices and controls.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wattage	9.4.2	Exterior Lighting	Exterior lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

### 3. To be checked by Inspector

Insulation	5.8.1.7	Envelope	Exterior insulation protected against damage, sunlight, moisture, wind, landscaping and equipment maintenance activities.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.7	Mechanical	Freeze protection and snow/ice melting system sensors for future connection to controls.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Air Leakage	5.4.3.1	Envelope	Continuous air barrier is wrapped, sealed, caulked, gasketed, and/or taped in an approved manner, except in semiheated spaces in climate zones 1-6.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Air Leakage	5.4.3.2	Envelope	Factory-built and site-assembled fenestration and doors are labeled or certified as meeting air leakage requirements.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fenestration	5.8.2.1, 5.8.2.3, 5.8.2.4, 5.8.2.5	Envelope	Fenestration products rated (U-factor, SHGC, and VT) in accordance with NFRC or energy code defaults are used.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fenestration	5.8.2.2	Envelope	Fenestration and door products are labeled, or a signed and dated certificate listing the U-factor, SHGC, VT, and air leakage rate has been provided by the manufacturer.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.4.1	Mechanical	Temperature controls installed on service water heating systems ( $\leq 120^{\circ}\text{F}$ to maximum temperature for intended use).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.4.2	Mechanical	Automatic time switches installed to automatically switch off the recirculating hot-water system or heat trace.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.6	Mechanical	Heat traps installed on non-circulating storage water tanks.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.1.4, 6.4.1.5	Mechanical	HVAC equipment efficiency verified. Non-NAECA HVAC equipment labeled as meeting 90.1.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.1.5.2	Mechanical	PTAC and PTHP with sleeves 16 in. by 42 in. labeled for replacement only.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.4.1	Mechanical	Stair and elevator shaft vents have motorized dampers that automatically close.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.4.2, 6.4.3.4.3	Mechanical	Outdoor air and exhaust systems have motorized dampers that automatically shut when not in use and meet maximum leakage rates. Check gravity dampers where allowed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.4.5	Mechanical	Enclosed parking garage ventilation has automatic contaminant detection and capacity to stage or modulate fans to 50% or less of design capacity.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.5.3.2.1	Mechanical	DX cooling systems $\geq 75$ kBtu/h ( $\geq 65$ kBtu/h effective 1/2016) and chilled-water and evaporative cooling fan motor hp $\geq \frac{1}{4}$ designed to vary indoor fan airflow as a function of load and comply with operational requirements.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.4.1.1	Mechanical	Insulation exposed to weather protected from damage. Insulation outside of the conditioned space and associated with cooling systems is vapor retardant.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.4.1.2	Mechanical	HVAC ducts and plenums insulated. Where ducts or plenums are installed in or under a slab, verification may need to occur during Foundation Inspection.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.4.1.3	Mechanical	HVAC piping insulation thickness. Where piping is installed in or under a slab, verification may need to occur during Foundation Inspection.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.4.2.1	Mechanical	Ducts and plenums sealed based on static pressure and location.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.4.2.2	Mechanical	Ductwork operating $>3$ in. water column requires air leakage testing.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.2.1	Mechanical	Zone controls can limit simultaneous heating and cooling and sequence heating and cooling to each zone.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.2.2.2	Mechanical	Two-pipe hydronic systems using a common distribution system have controls to allow a deadband $\geq 15^{\circ}\text{F}$ , allow operation in one mode for at least 4 hrs before changeover, and have rest controls to limit heating and cooling supply temperature to $\leq 30^{\circ}\text{F}$ .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

HVAC	6.5.2.4.1	Mechanical	Humidifiers with airstream mounted preheating jackets have preheat auto-shutoff value set to activate when humidification is not required.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.5.2.4.2	Mechanical	Humidification system dispersion tube hot surfaces in the airstreams of ducts or air-handling units insulated $\geq R-0.5$ .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.3.2.2	Mechanical	VAV fans have static pressure sensors positioned so setpoint $\leq 1.2$ in. w.c. design pressure.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.4.5.1	Mechanical	Two-position automatic valve interlocked to shut off water flow when hydronic heat pump with pumping system $>10$ hp is off.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.6.2	Mechanical	Condenser heat recovery system that can heat water to 85 $^{\circ}$ F or provide 60% of peak heat rejection is installed for preheating of service hot water.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.5.7.1.5	Mechanical	Approved field test used to evaluate design air flow rates and demonstrate proper capture and containment of kitchen exhaust systems.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.5.9	Mechanical	Hot gas bypass limited to: $\leq 240$ kBtu/h $\hat{a}$ 15% $>240$ kBtu/h $\hat{a}$ 10%	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.9	Mechanical	Heating for vestibules and air curtains include automatic controls that shut off the heating system when outdoor air temperatures $> 45$ F. Vestibule heating systems controlled by a thermostat in the vestibule with setpoint $\leq 60$ F.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Controls	6.5.10	Mechanical	Doors separating conditioned space from the outdoors have controls that disable/reset heating and cooling system when open.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Controls	9.4.1.1	Interior Lighting	Automatic control requirements prescribed in Table 9.6.1, for the appropriate space type, are installed. Mandatory lighting controls (labeled as 'REQ') and optional choice controls (labeled as 'ADD1' and 'ADD2') are implemented.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Controls	9.4.1.1	Interior Lighting	Independent lighting controls installed per approved lighting plans and all manual controls readily accessible and visible to occupants.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Controls	9.4.1.2	Interior Lighting	Parking garage lighting is equipped with required lighting controls and daylight transition zone lighting.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Controls	9.4.1.1f	Interior Lighting	Daylight areas under skylights and roof monitors that have more than 150 W combined input power for general lighting are controlled by photocontrols.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Controls	9.4.1.4	Exterior Lighting	Automatic lighting controls for exterior lighting installed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Controls	9.4.1.3	Interior Lighting	Separate lighting control devices for specific uses installed per approved lighting plans.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wattage	9.6.2	Interior Lighting	Additional interior lighting power allowed for special functions per the approved lighting plans and is automatically controlled and separated from general lighting.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wattage	9.6.4	Interior Lighting	Where space LPD requirements are adjusted based on room cavity ratios, dimensions are consistent with approved plans.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation	5.5.3.1	Envelope	Roof R-value. For some ceiling systems, verification may need to occur during Framing Inspection.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.2, 5.8.1.3	Envelope	Roof insulation installed per manufacturer's instructions. Blown or poured loose-fill insulation is installed only where the roof slope is $\leq 3$ in 12.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.1	Envelope	Building envelope insulation is labeled with R-value or insulation certificate has been provided listing R-value and other relevant data.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.9	Envelope	Building envelope insulation extends over the full area of the component at the proposed rated R or U value.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.4	Envelope	Eaves are baffled to deflect air to above the insulation.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.5	Envelope	Insulation is installed in substantial contact with the inside surface separating conditioned space from unconditional space.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



Insulation	5.8.1.6	Envelope	Recessed equipment installed in building envelope assemblies does not compress the adjacent insulation.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.7.1	Envelope	Attics and mechanical rooms have insulation protected where adjacent to attic or equipment access.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.7.2	Envelope	Foundation vents do not interfere with insulation.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Insulation	5.8.1.8	Envelope	Insulation intended to meet the roof insulation requirements cannot be installed on top of a suspended ceiling. Mark this requirement compliant if insulation is installed accordingly.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.3.1.1	Mechanical	Heating and cooling to each zone is controlled by a thermostat control.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.1.2	Mechanical	Thermostatic controls have a 5 Å°F deadband.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.2	Mechanical	Temperature controls have setpoint overlap restrictions.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.3.1	Mechanical	HVAC systems equipped with at least one automatic shutdown control.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	6.4.3.5	Mechanical	Heat pump controls prevent supplemental electric resistance heat from coming on when not needed.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.6	Mechanical	When humidification and dehumidification are provided to a zone, simultaneous operation is prohibited. Humidity control prohibits the use of fossil fuel or electricity to produce RH > 30% in the warmest zone humidified and RH < 60% in the coldest zone dehumidified.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.4.3.6	Mechanical	When humidification and dehumidification are provided to a zone, simultaneous operation is prohibited. Humidity control prohibits the use of fossil fuel or electricity to produce RH > 30% in the warmest zone humidified and RH < 60% in the coldest zone dehumidified.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.4.3	Mechanical	Public lavatory faucet water temperature <=110Å°F.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.4.4	Mechanical	Controls are installed that limit the operation of a recirculation pump installed to maintain temperature of a storage tank.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.5.1	Mechanical	Pool heaters are equipped with on/off switch and no continuously burning pilot light.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.5.2	Mechanical	Pool covers are provided for heated pools and pools heated to >90Å°F have a cover >=R-12.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.5.3	Mechanical	Time switches are installed on all pool heaters and pumps.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wattage	9.2.2.3	Interior Lighting	Interior installed lamp and fixture lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.3	Mechanical	All piping in circulating system insulated	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.3	Mechanical	First 8 ft of outlet piping is insulated	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM_SPECIFIC	7.4.3	Mechanical	All heat traced or externally heated piping insulated	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

#### 4. To be checked by Inspector at Project Completion and Prior to Issuance of Certificate of Occupancy

Plan Review	6.7.2.4	Mechanical	Detailed instructions for HVAC systems commissioning included on the plans or specifications for projects >=50,000 ft2.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Plan Review	6.7.2.4	Mechanical	Detailed instructions for HVAC systems commissioning included on the plans or specifications for projects >=50,000 ft2.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Post Construction	6.7.2.1	Mechanical	Furnished HVAC as-built drawings submitted within 90 days of system acceptance.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Post Construction	6.7.2.2	Mechanical	Furnished O&M manuals for HVAC systems within 90 days of system acceptance.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Post Construction	6.7.2.3	Mechanical	An air and/or hydronic system balancing report is provided for HVAC systems serving zones >5,000 ft2 of conditioned area.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HVAC	6.7.2.4	Mechanical	HVAC control systems have been tested to ensure proper operation, calibration and adjustment of controls.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Post Construction	8.7.1	Interior Lighting	Furnished as-built drawings for electric power systems within 30 days of system acceptance.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Post Construction	8.7.2	Interior Lighting	Furnished O&M instructions for systems and equipment to the building owner or designated representative.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

# Input Data Report

## Project Information

**Project Name:** 20031

**Project Title:** 2nd Floor Build-Out

**Address:** 5037 SR 240

**State:** FL

**Zip:** 32024

**Owner:** Belmont Academy

**Building Type:** School/University

**Building Classification:** Addition to existing Building

**No. of Stories:** 2

**GrossArea (SF):** 17,248

**Bldg. Rotation:** None

### **Zones**

No	Acronym	Description	Type	Area [sf]	Multi	Total Area [sf]	
1	AHU-2	Zone 1	CONDITIONED	15738.0	1	15738.0	<input type="checkbox"/>
2	PTAC	Zone 2	CONDITIONED	50.0	1	50.0	<input type="checkbox"/>
3	ACU-1	Zone 3	CONDITIONED	1134.0	1	1134.0	<input type="checkbox"/>
4	ACU-2	Zone 4	CONDITIONED	326.0	1	326.0	<input type="checkbox"/>

## Spaces

No	Acronym	Description	Type	Depth [ft]	Width [ft]	Height [ft]	Mult	Total Area [sf]	Total Vol[cf]	
<b>In Zone: AHU-2</b>										
1	classroom #1	Zo0Sp1	Classroom/Lecture Hall	1.00	582.00	10.00	1	582.0	5820.0	<input type="checkbox"/>
2	storage	Zo0Sp2	Storage & Warehouse - Bulky Active Storage	1.00	40.00	10.00	1	40.0	400.0	<input type="checkbox"/>
3	classroom #2	Zo0Sp3	Classroom/Lecture Hall	1.00	678.00	10.00	1	678.0	6780.0	<input type="checkbox"/>
4	classroom #3	Zo0Sp4	Classroom/Lecture Hall	1.00	697.00	10.00	1	697.0	6970.0	<input type="checkbox"/>
5	classroom #4	Zo0Sp5	Classroom/Lecture Hall	1.00	666.00	10.00	1	666.0	6660.0	<input type="checkbox"/>
6	corridors	Zo0Sp6	Corridor	1.00	4283.00	10.00	1	4283.0	42830.0	<input type="checkbox"/>
7	classroom #5	Zo0Sp7	Classroom/Lecture Hall	1.00	782.00	10.00	1	782.0	7820.0	<input type="checkbox"/>
8	classroom #6	Zo0Sp8	Classroom/Lecture Hall	1.00	783.00	10.00	1	783.0	7830.0	<input type="checkbox"/>
9	classroom #7	Zo0Sp9	Classroom/Lecture Hall	1.00	795.00	10.00	1	795.0	7950.0	<input type="checkbox"/>
10	classroom	Zo0Sp10	Classroom/Lecture Hall	1.00	618.00	10.00	1	618.0	6180.0	<input type="checkbox"/>
11	janitor	Zo0Sp11	Storage & Warehouse - Bulky Active Storage	1.00	155.00	10.00	2	310.0	3100.0	<input type="checkbox"/>
12	classroom #9	Zo0Sp12	Classroom/Lecture Hall	1.00	782.00	10.00	1	782.0	7820.0	<input type="checkbox"/>
13	classroom #10	Zo0Sp13	Classroom/Lecture Hall	1.00	783.00	10.00	1	783.0	7830.0	<input type="checkbox"/>
14	classroom #11	Zo0Sp14	Classroom/Lecture Hall	1.00	793.00	10.00	1	793.0	7930.0	<input type="checkbox"/>
15	Men's rr	Zo0Sp18	Toilet and Washroom	1.00	468.00	10.00	1	468.0	4680.0	<input type="checkbox"/>
16	women's rr	Zo0Sp20	Toilet and Washroom	1.00	469.00	10.00	1	469.0	4690.0	<input type="checkbox"/>
17	electrical room	Zo0Sp22	Electrical Mechanical Equipment Room - General	1.00	169.00	10.00	1	169.0	1690.0	<input type="checkbox"/>
18	classroom	Zo1Sp27	Classroom/Lecture Hall	1.00	656.00	10.00	1	656.0	6560.0	<input type="checkbox"/>
19	classroom #13	Zo1Sp28	Classroom/Lecture Hall	1.00	611.00	10.00	1	611.0	6110.0	<input type="checkbox"/>
20	Flex Space	Zo1Sp29	Conference/meeting (Multiple Functions)	1.00	322.00	10.00	1	322.0	3220.0	<input type="checkbox"/>
21	Flex Space	Zo1Sp30	Conference/meeting (Multiple Functions)	1.00	226.00	10.00	1	226.0	2260.0	<input type="checkbox"/>
22	Restroom	Zo1Sp32	Toilet and Washroom	1.00	43.00	10.00	1	43.0	430.0	<input type="checkbox"/>
23	Restroom	Zo1Sp32	Toilet and Washroom	1.00	43.00	10.00	1	43.0	430.0	<input type="checkbox"/>
24	Storage	Zo1Sp34	Storage & Warehouse - Inactive Storage	1.00	50.00	10.00	1	50.0	500.0	<input type="checkbox"/>
25	west stair	Zo1Sp35	Stair - Active Traffic	1.00	89.00	10.00	1	89.0	890.0	<input type="checkbox"/>
<b>In Zone: PTAC</b>										
1	Elev Mach Rm	Zo0Sp1	Electrical Mechanical Equipment Room - General	1.00	50.00	10.00	1	50.0	500.0	<input type="checkbox"/>
<b>In Zone: ACU-1</b>										
1	east stair 1st fl	Zo0Sp1	Stair - Active Traffic	1.00	310.00	10.00	1	310.0	3100.0	<input type="checkbox"/>
2	E stair corr 1st	Zo0Sp2	Corridor	1.00	824.00	10.00	1	824.0	8240.0	<input type="checkbox"/>
<b>In Zone: ACU-2</b>										
1	east stair 2nd F	Zo0Sp1	Stair - Active Traffic	1.00	326.00	10.00	1	326.0	3260.0	<input type="checkbox"/>



## Lighting

No	Type	Category	No. of Luminaires	Watts per Luminaire	Power [W]	Control Type	No. of Ctrl pts	
<b>In Zone: AHU-2</b>								
<b>In Space: classroom #1</b>								
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: storage</b>								
1	LED	General Lighting	1	34	34	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: classroom #2</b>								
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: classroom #3</b>								
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: classroom #4</b>								
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: corridors</b>								
1	LED	General Lighting	35	34	1190	Occupancy sensor without Daylighting	2	<input type="checkbox"/>
2	LED	General Lighting	13	11	143	Occupancy sensor with Daylighting On/Off	1	<input type="checkbox"/>
<b>In Space: classroom #5</b>								
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: classroom #6</b>								
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: classroom #7</b>								
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
2	LED	General Lighting	1	20	20	Occupancy Sensor with Timer without Daylighting	1	<input type="checkbox"/>
<b>In Space: classroom</b>								
1	LED	General Lighting	8	34	272	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: janitor</b>								
1	LED	General Lighting	2	34	68	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: classroom #9</b>								
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: classroom #10</b>								
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
<b>In Space: classroom #11</b>								
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>
2	LED	General Lighting	1	20	20	Occupancy sensor with Daylighting On/Off	1	<input type="checkbox"/>

<b>In Space: Men's rr</b>									
1	LED	General Lighting	5	29	145	Occupancy sensor without Daylighting	1	<input type="checkbox"/>	
2	LED	General Lighting	2	20	40	Occupancy sensor with Daylighting On/Off	1	<input type="checkbox"/>	
<b>In Space: women's rr</b>									
1	LED	General Lighting	4	34	136	Occupancy sensor without Daylighting	1	<input type="checkbox"/>	
2	LED	General Lighting	3	20	60	Occupancy sensor with Daylighting On/Off	1	<input type="checkbox"/>	
<b>In Space: electrical room</b>									
1	LED	General Lighting	2	34	68	Manual On/Off	1	<input type="checkbox"/>	
<b>In Space: classroom</b>									
1	LED	General Lighting	11	34	374	Occupancy sensor without Daylighting	1	<input type="checkbox"/>	
<b>In Space: classroom #13</b>									
1	LED	General Lighting	9	34	306	Occupancy sensor without Daylighting	1	<input type="checkbox"/>	
<b>In Space: Flex Space</b>									
1	LED	General Lighting	6	34	204	Occupancy sensor without Daylighting	1	<input type="checkbox"/>	
<b>In Space: Flex Space</b>									
1	LED	General Lighting	5	34	170	Occupancy sensor without Daylighting	1	<input type="checkbox"/>	
<b>In Space: Restroom</b>									
1	LED	General Lighting	1	20	20	Occupancy sensor with Daylighting On/Off	1	<input type="checkbox"/>	
<b>In Space: Restroom</b>									
1	LED	General Lighting	1	20	20	Occupancy sensor with Daylighting On/Off	1	<input type="checkbox"/>	
<b>In Space: Storage</b>									
1	LED	General Lighting	1	20	20	Occupancy sensor with Daylighting On/Off	1	<input type="checkbox"/>	
<b>In Space: west stair</b>									
1	LED	General Lighting	1	29	29	Manual On/Off	1	<input type="checkbox"/>	
<b>In Zone: PTAC</b>									
<b>In Space: Elev Mach Rm</b>									
1	Compact Fluorescent	General Lighting	1	64	64	Manual On/Off	1	<input type="checkbox"/>	
<b>In Zone: ACU-1</b>									
<b>In Space: east stair 1st fl</b>									
1	Compact Fluorescent	General Lighting	2	64	128	Manual On/Off	1	<input type="checkbox"/>	
<b>In Space: E stair corr 1st FL</b>									
1	Compact Fluorescent	General Lighting	8	64	512	Programmable timer with Daylighting 3 step	1	<input type="checkbox"/>	
<b>In Zone: ACU-2</b>									
<b>In Space: east stair 2nd FL</b>									
1	LED	General Lighting	2	34	68	Occupancy sensor without Daylighting	1	<input type="checkbox"/>	

## Walls (Walls will be rotated clockwise by building rotation value)

No	Description	Type	Width [ft]	H (Effec) [ft]	Multi plier	Area [sf]	Orient ation	Cond- uctance [Btu/h.sf.F]	Heat Capacity [Btu/sf.F]	Dens. [lb/cf]	R-Value [h.sf.F/Btu]	
<b>In Zone: AHU-2</b>												
1	Pr0Zo1Wa5	8" CMU, R-13 Ins., Gyp. Brd	163.00	10.00	1	1630.0	North	0.0607	6.434	32.43	16.5	<input type="checkbox"/>
2	Pr0Zo1Wa6	8" CMU, R-13 Ins., Gyp. Brd	163.00	10.00	1	1630.0	South	0.0607	6.434	32.43	16.5	<input type="checkbox"/>
3	Pr0Zo1Wa8	8" CMU, R-13 Ins., Gyp. Brd	68.00	10.00	1	680.0	East	0.0607	6.434	32.43	16.5	<input type="checkbox"/>
4	Pr0Zo1Wa8	8" CMU, R-13 Ins., Gyp. Brd	119.00	10.00	1	1190.0	West	0.0607	6.434	32.43	16.5	<input type="checkbox"/>
<b>In Zone: PTAC</b>												
1	Pr0Zo2Wa1	8" CMU, R-13 Ins., Gyp. Brd	6.00	10.00	1	60.0	East	0.0607	6.434	32.43	16.5	<input type="checkbox"/>
2	Pr0Zo2Wa2	8" CMU, R-13 Ins., Gyp. Brd	12.00	10.00	1	120.0	South	0.0607	6.434	32.43	16.5	<input type="checkbox"/>
<b>In Zone: ACU-1</b>												
1	Pr0Zo3Wa1	8" CMU, R-13 Ins., Gyp. Brd	11.00	10.00	1	110.0	North	0.0607	6.434	32.43	16.5	<input type="checkbox"/>
2	Pr0Zo3Wa3	8" CMU, R-13 Ins., Gyp. Brd	38.00	10.00	1	380.0	East	0.0607	6.434	32.43	16.5	<input type="checkbox"/>
<b>In Zone: ACU-2</b>												
1	Pr0Zo4Wa2	8" CMU, R-13 Ins., Gyp. Brd	38.00	10.00	1	380.0	East	0.0607	6.434	32.43	16.5	<input type="checkbox"/>

## Windows (Windows will be rotated clockwise by building rotation value)

No	Description	Orientation	Shaded	U [Btu/hr sf F]	SHGC	Vis.Tra	W [ft]	H (Effec) [ft]	Multi plier	Total Area [sf]	
<b>In Zone: ACU-1</b>											
<b>In Wall: east</b>											
1	Pr0Zo3Wa3Wi1	East	No	0.5000	0.44	0.76	4.00	4.00	2	32.0	<input type="checkbox"/>
2	Pr0Zo3Wa3Wi2	East	No	0.5000	0.44	0.76	7.00	3.00	1	21.0	<input type="checkbox"/>
<b>In Zone: AHU-2</b>											
<b>In Wall: east</b>											
1	Pr0Zo1Wa8Wi1	East	No	0.5000	0.44	0.76	8.00	4.00	2	64.0	<input type="checkbox"/>
<b>In Wall: north</b>											
1	Pr0Zo1Wa5Wi1	North	No	0.5000	0.44	0.76	10.00	9.60	1	96.0	<input type="checkbox"/>
<b>In Wall: south</b>											
1	Pr0Zo1Wa6Wi1	South	No	0.5000	0.44	0.76	10.00	4.80	1	48.0	<input type="checkbox"/>
<b>In Wall: west</b>											
1	Pr0Zo1Wa8Wi1	West	No	0.5000	0.44	0.76	8.00	4.00	2	64.0	<input type="checkbox"/>



## Doors

No	Description	Type	Shade?	Width [ft]	H (Effec) [ft]	Multi plier	Area [sf]	Cond. [Btu/h.sf.F]	Dens. [lb/cf]	Ht Cap. [Btu/sf. F]	R [h.sf.F/ Btu]
----	-------------	------	--------	---------------	-------------------	----------------	--------------	-----------------------	------------------	---------------------------	-----------------------

In Zone:

In Wall:

## Roofs

No	Description	Type	Width [ft]	H (Effec) [ft]	Multi plier	Area [sf]	Tilt [deg]	Cond. [Btu/h.Sf. F]	Heat Cap [Btu/sf. F]	Dens. [lb/cf]	R-Value [h.sf.F/Btu]
----	-------------	------	---------------	-------------------	----------------	--------------	---------------	------------------------	-------------------------	------------------	-------------------------

In Zone: AHU-2

1	Pr0Zo1Rf1	Shingles, R-25 Ins, Mtl Deck	188.10	100.00	1	18810.0	0.00	0.0378	0.27	4.66	26.5	<input type="checkbox"/>
---	-----------	---------------------------------	--------	--------	---	---------	------	--------	------	------	------	--------------------------

In Zone: ACU-2

1	Pr0Zo4Rf1	Shingles, R-25 Ins, Mtl Deck	32.60	10.00	1	326.0	0.00	0.0378	0.27	4.66	26.5	<input type="checkbox"/>
---	-----------	---------------------------------	-------	-------	---	-------	------	--------	------	------	------	--------------------------

## Skylights

No	Description	Type	U [Btu/hr sf F]	SHGC	Vis.Trans	W [ft]	H (Effec) [ft]	Multi- plier	Area [Sf]	Total Area [Sf]
----	-------------	------	--------------------	------	-----------	-----------	-------------------	-----------------	--------------	--------------------

In Zone:

In Roof:

## Floors

No	Description	Type	Width [ft]	H (Effec) [ft]	Multi plier	Area [sf]	Cond. [Btu/h.sf.F]	Heat Cap. [Btu/sf. F]	Dens. [lb/cf]	R-Value [h.sf.F/Btu]
----	-------------	------	---------------	-------------------	----------------	--------------	-----------------------	--------------------------	------------------	-------------------------

In Zone:

## Systems

<b>AHU-2</b>	<b>System 1</b>	<b>Variable Air Volume Built-up System</b>	<b>No. Of Units</b>
			<b>1</b>

Component	Category	Capacity	Efficiency	IPLV	<input type="checkbox"/>
1	Cooling System	784700.00			<input type="checkbox"/>
2	Heating System	432362.00	1.00		<input type="checkbox"/>
3	Air Handling System -Supply	12200.00	0.75		<input type="checkbox"/>

<b>PTAC</b>	<b>System 2</b>	<b>Room Units (Airconditioners &amp; Heat pumps)</b>	<b>No. Of Units</b>
			<b>1</b>

Component	Category	Capacity	Efficiency	IPLV	<input type="checkbox"/>
1	Cooling System	18000.00	9.50		<input type="checkbox"/>
2	Heating System	16400.00	2.92		<input type="checkbox"/>
3	Air Handling System -Supply	400.00	0.80		<input type="checkbox"/>

<b>ACU-1</b>	<b>System 3</b>	<b>Constant Volume Air Cooled Split System &lt; 65000 Btu/hr</b>	<b>No. Of Units</b>
			<b>1</b>

Component	Category	Capacity	Efficiency	IPLV	<input type="checkbox"/>
1	Cooling System	18000.00	14.20	8.00	<input type="checkbox"/>
2	Heating System	19000.00	9.80		<input type="checkbox"/>
3	Air Handling System -Supply	710.00	0.10		<input type="checkbox"/>

<b>ACU-2</b>	<b>System 4</b>	<b>Constant Volume Air Cooled Split System &lt; 65000 Btu/hr</b>	<b>No. Of Units</b>
			<b>1</b>

Component	Category	Capacity	Efficiency	IPLV	<input type="checkbox"/>
1	Cooling System	9000.00	24.60	8.00	<input type="checkbox"/>
2	Heating System	10900.00	12.80		<input type="checkbox"/>
3	Air Handling System -Supply	307.00	0.10		<input type="checkbox"/>

### Plant

Equipment	Category	Size	Inst.No	Eff.	IPLV	
1	Hermetic screw or scroll chiller	Cooling Equipment	99.3[Tons]	1	2.99[COP]	4.51

### Water Heaters

W-Heater Description	Capacity	Cap.Unit	I/P Rt.	Efficiency	Loss
1 Electric water heater	50 [Gal]		10 [kW]	0.9600 [Ef]	[Btu/h] <input type="checkbox"/>

### Ext-Lighting

Description	Category	No. of Luminaires	Watts per Luminaires	Area/Len/No [sf/ft/No]	Control Type	Wattage [W]
<input type="checkbox"/>						

### Piping

No	Type	Operating Temp [F]	Insulation Conductivity [ Btu-in/h.sf.F]	Nomonal pipe Diameter [in]	Insulation Thickness [in]	Is Runout?
1	Domestic and Service Hot Water Systems	120.00	0.28	1.00	1.00	No <input type="checkbox"/>

### Fenestration Used

Name	Glass Type	No. of Panes	Glass Conductance [Btu/h.sf.F]	SHGC	VLT
ApLbWnd13	User Defined	2	0.5000	0.4350	0.7600

## Materials Used

Mat No	Acronym	Description	Only R-Value Used	RValue [h.sf.F/Btu]	Thick [ft]	Cond- uctivity [Btu/h.ft.F]	Density [lb/cf]	Sp. Heat [Btu/lb.F]	<input type="checkbox"/>
187	Mat187	GYP OR PLAS BOARD,1/2IN	No	0.4533	0.0417	0.0920	50.00	0.2000	<input type="checkbox"/>
4	Mat4	Steel siding	No	0.0002	0.0050	26.0000	480.00	0.1000	<input type="checkbox"/>
1001	ApLbMat1001	Outside surface resistance	Yes	0.3300					<input type="checkbox"/>
1002	ApLbMat1002	Inside surface resistance	Yes	0.6900					<input type="checkbox"/>
1003	ApLbMat1003	ASPHALT-SHINGLE AND SIDING	Yes	0.4400					<input type="checkbox"/>
1005	ApLbMat1005	R-25 Generic Insulation	No	25.0000	0.5450	0.0218	0.30	0.2000	<input type="checkbox"/>
1006	ApLbMat1006	R-13 Generic Insulation	No	13.0000	0.2837	0.0218	0.30	0.2000	<input type="checkbox"/>
1007	ApLbMat1007	CC BLK LW,8IN,HOLLOW	No	2.0021	0.6667	0.3330	45.00	0.2000	<input type="checkbox"/>

## Constructs Used

No	Name	Simple Construct	Massless Construct	Conductance [Btu/h.sf.F]	Heat Cap [Btu/sf.F]	Density [lb/cf]	RValue [h.sf.F/Btu]	<input type="checkbox"/>
1060	Shingles, R-25 Ins, Mtl Deck	No	No	0.04	0.27	4.66	26.5	<input type="checkbox"/>

Layer	Material No.	Material	Thickness [ft]	Framing Factor	<input type="checkbox"/>
1	1001	Outside surface resistance		0.000	<input type="checkbox"/>
2	1003	ASPHALT-SHINGLE AND SIDING		0.000	<input type="checkbox"/>
3	4	Steel siding	0.0050	0.000	<input type="checkbox"/>
4	1005	R-25 Generic Insulation	0.5450	0.000	<input type="checkbox"/>
5	1002	Inside surface resistance		0.000	<input type="checkbox"/>

No	Name	Simple Construct	Massless Construct	Conductance [Btu/h.sf.F]	Heat Cap [Btu/sf.F]	Density [lb/cf]	RValue [h.sf.F/Btu]	<input type="checkbox"/>
1062	8" CMU, R-13 Ins., Gyp. Brd	No	No	0.06	6.43	32.43	16.5	<input type="checkbox"/>

Layer	Material No.	Material	Thickness [ft]	Framing Factor	<input type="checkbox"/>
1	1001	Outside surface resistance		0.000	<input type="checkbox"/>
2	1007	CC BLK LW,8IN,HOLLOW	0.6667	0.000	<input type="checkbox"/>
3	1006	R-13 Generic Insulation	0.2837	0.000	<input type="checkbox"/>
4	187	GYP OR PLAS BOARD,1/2IN	0.0417	0.000	<input type="checkbox"/>
5	1002	Inside surface resistance		0.000	<input type="checkbox"/>

LOAD SUMMARY CALCULATIONS

**TABLE OF CONTENTS**

Load Summary Calculation, AHU-2.....Page 1  
Load Summary Calculation, PTAC.....Page 2  
Load Summary Calculation, ACU-1.....Page 3  
Load Summary Calculation, ACU-2.....Page 4

---

John W. Wells, III, PE  
FL49347  
Consulting Engineering Associates, Inc.  
CA3962  
8365 Gunn Highway  
Tampa, FL 33626

Project Name: Belmont Academy 2<sup>nd</sup> Floor Expansion  
Project Address: 1476 SW Walter Ave, Lake City, FL 32024

<p><b>CODES APPLICABLE TO THESE LOAD CALCULATIONS:</b> Florida Building Code, Sixth Edition (2017):     Building     Energy Conservation     Mechanical</p> <p>Calculations produced using Elite Software – CHVAC Commercial HVAC Loads, Version 8.02.37</p>
--



## Air Handler #1 - AHU-2 - Total Load Summary

Air Handler Description: AHU-2 Variable Air Volume  
 Supply Air Fan: Draw-Thru with program estimated horsepower of 4.15 HP  
 Fan Input: 90% motor and fan efficiency with 2 in. water across the fan  
 Sensible Heat Ratio: 0.74 --- This system occurs 1 time(s) in the building. ---  
 Air System Peak Time: 5pm in July.  
 Outdoor Conditions: Clg: 95° DB, 78° WB, 117.45 grains, Htg: 29° DB  
 Indoor Conditions: Clg: 75° DB, 50% RH, Htg: 70° DB

Because of the diversity in room, plenum and ventilation loads, the room sensible peak time in July at 6pm is different from the total system peak time, hence the air system CFM was computed using a room sensible load of 250,470.

Summer: Ventilation controls outside air, ---- Winter: Ventilation controls outside air.

Room Space sensible loss:	66,670 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	269,412 Btuh	6,090 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
<b>Total System sensible loss:</b>		<b>336,082 Btuh</b>

Heating Supply Air: $66,670 / (.999 \times 1.08 \times 10) =$	6,090 CFM
Winter Vent Outside Air (100.0% of supply) =	6,090 CFM

Room space sensible gain:	249,140 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	10,527 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	0 Btuh	
<b>Total sensible gain on supply side of coil:</b>		<b>259,667 Btuh</b>

Cooling Supply Air: $260,996 / (.999 \times 1.1 \times 20) =$	11,875 CFM
Summer Vent Outside Air (51.3% of supply) =	6,090 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	133,854 Btuh	6,090 CFM
Blow-thru fan sensible gain:	0 Btuh	
<b>Total sensible gain on return side of coil:</b>		<b>133,854 Btuh</b>
<b>Total sensible gain on air handling system:</b>		<b>393,521 Btuh</b>

Room space latent gain:	89,930 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	218,919 Btuh	
<b>Total latent gain on air handling system:</b>		<b>308,849 Btuh</b>
<b>Total system sensible and latent gain:</b>		<b>702,370 Btuh</b>

### Check Figures

Total Air Handler Supply Air (based on a 20° TD):	11,875 CFM
Total Air Handler Vent. Air (51.29% of Supply):	6,090 CFM
Total Conditioned Air Space:	15,444 Sq.ft
Supply Air Per Unit Area:	0.7689 CFM/Sq.ft
Area Per Cooling Capacity:	263.9 Sq.ft/Ton
Cooling Capacity Per Area:	0.0038 Tons/Sq.ft
Heating Capacity Per Area:	21.76 Btuh/Sq.ft
<b>Total Heating Required With Outside Air:</b>	<b>336,082 Btuh</b>
<b>Total Cooling Required With Outside Air:</b>	<b>58.53 Tons</b>









## Air Handler #1 - PTAC - Total Load Summary

Air Handler Description: PTAC Constant Volume - Proportion  
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.05 HP  
 Fan Input: 80% motor and fan efficiency with 0.75 in. water across the fan  
 Sensible Heat Ratio: 1.00 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 6pm in August.  
 Outdoor Conditions: Clg: 92° DB, 77° WB, 116.35 grains, Htg: 29° DB  
 Indoor Conditions: Clg: 75° DB, 50% RH, Htg: 70° DB

Summer: Exhaust controls outside air, ---- Winter: Exhaust controls outside air.

Room Space sensible loss:	1,358 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	0 Btuh	0 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		1,358 Btuh

Heating Supply Air: $1,358 / (.999 \times 1.08 \times 25) =$	50 CFM
Winter Vent Outside Air (0.0% of supply) =	0 CFM

Room space sensible gain:	6,904 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	126 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	0 Btuh	
Total sensible gain on supply side of coil:		7,030 Btuh

Cooling Supply Air: $7,030 / (.999 \times 1.1 \times 19) =$	337 CFM
Summer Vent Outside Air (0.0% of supply) =	0 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	0 Btuh	0 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		0 Btuh
Total sensible gain on air handling system:		7,030 Btuh

Room space latent gain:	0 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	0 Btuh	
Total latent gain on air handling system:		0 Btuh
Total system sensible and latent gain:		7,030 Btuh

### Check Figures

Total Air Handler Supply Air (based on a 19° TD):	337 CFM
Total Air Handler Vent. Air (0.00% of Supply):	0 CFM
Total Conditioned Air Space:	50 Sq.ft
Supply Air Per Unit Area:	6.7329 CFM/Sq.ft
Area Per Cooling Capacity:	85.4 Sq.ft/Ton
Cooling Capacity Per Area:	0.0117 Tons/Sq.ft
Heating Capacity Per Area:	27.16 Btuh/Sq.ft
Total Heating Required With Outside Air:	1,358 Btuh
Total Cooling Required With Outside Air:	0.59 Tons







## Air Handler #2 - ACU-1 - Total Load Summary

Air Handler Description: ACU-1 Constant Volume - Proportion  
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.10 HP  
 Fan Input: 80% motor and fan efficiency with 0.75 in. water across the fan  
 Sensible Heat Ratio: 1.00 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in August.  
 Outdoor Conditions: Clg: 96° DB, 78° WB, 115.98 grains, Htg: 29° DB  
 Indoor Conditions: Clg: 75° DB, 50% RH, Htg: 70° DB

Summer: Exhaust controls outside air, ---- Winter: Exhaust controls outside air.

Room Space sensible loss:	10,780 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	0 Btuh	0 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		10,780 Btuh

Heating Supply Air: $10,780 / (.999 \times 1.08 \times 25) =$	400 CFM
Winter Vent Outside Air (0.0% of supply) =	0 CFM

Room space sensible gain:	14,112 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	257 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	0 Btuh	
Total sensible gain on supply side of coil:		14,369 Btuh

Cooling Supply Air: $14,369 / (.999 \times 1.1 \times 19) =$	688 CFM
Summer Vent Outside Air (0.0% of supply) =	0 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	0 Btuh	0 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		0 Btuh
Total sensible gain on air handling system:		14,369 Btuh

Room space latent gain:	0 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	0 Btuh	
Total latent gain on air handling system:		0 Btuh
Total system sensible and latent gain:		14,369 Btuh

### Check Figures

Total Air Handler Supply Air (based on a 19° TD):	688 CFM
Total Air Handler Vent. Air (0.00% of Supply):	0 CFM
Total Conditioned Air Space:	1,134 Sq.ft
Supply Air Per Unit Area:	0.6068 CFM/Sq.ft
Area Per Cooling Capacity:	947.0 Sq.ft/Ton
Cooling Capacity Per Area:	0.0011 Tons/Sq.ft
Heating Capacity Per Area:	9.51 Btuh/Sq.ft
Total Heating Required With Outside Air:	10,780 Btuh
Total Cooling Required With Outside Air:	1.20 Tons

3



### Air Handler #3 - ACU-2 - Total Load Summary

Air Handler Description: ACU-2 Constant Volume - Proportion  
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0.03 HP  
 Fan Input: 80% motor and fan efficiency with 0.75 in. water across the fan  
 Sensible Heat Ratio: 1.00 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in July.  
 Outdoor Conditions: Clg: 97° DB, 78° WB, 114.35 grains, Htg: 29° DB  
 Indoor Conditions: Clg: 75° DB, 50% RH, Htg: 70° DB

Summer: Exhaust controls outside air, ---- Winter: Exhaust controls outside air.

Room Space sensible loss:	4,628 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	0 Btuh	0 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		4,628 Btuh

Heating Supply Air: $4,628 / (.999 \times 1.08 \times 25) =$	172 CFM
Winter Vent Outside Air (0.0% of supply) =	0 CFM

Room space sensible gain:	4,812 Btuh
Infiltration sensible gain:	0 Btuh
Draw-thru fan sensible gain:	88 Btuh
Supply duct sensible gain:	0 Btuh
Reserve sensible gain:	0 Btuh
Total sensible gain on supply side of coil:	4,899 Btuh

Cooling Supply Air: $4,899 / (.999 \times 1.1 \times 19) =$	235 CFM
Summer Vent Outside Air (0.0% of supply) =	0 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	0 Btuh	0 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		0 Btuh
Total sensible gain on air handling system:		4,899 Btuh

Room space latent gain:	0 Btuh
Infiltration latent gain:	0 Btuh
Outside air latent gain:	0 Btuh
Total latent gain on air handling system:	0 Btuh
Total system sensible and latent gain:	4,899 Btuh

#### Check Figures

Total Air Handler Supply Air (based on a 19° TD):	235 CFM
Total Air Handler Vent. Air (0.00% of Supply):	0 CFM
Total Conditioned Air Space:	326 Sq.ft
Supply Air Per Unit Area:	0.7197 CFM/Sq.ft
Area Per Cooling Capacity:	798.5 Sq.ft/Ton
Cooling Capacity Per Area:	0.0013 Tons/Sq.ft
Heating Capacity Per Area:	14.20 Btuh/Sq.ft
Total Heating Required With Outside Air:	4,628 Btuh
Total Cooling Required With Outside Air:	0.41 Tons

4