

Project Information

For: Solomon Residence
862 SW Bluff Drive, Fort White, FL 32038

Notes:

Design Information

Weather: Gainesville Regional, FL, US

Winter Design Conditions

Outside db 33 °F
Inside db 70 °F
Design TD 37 °F

Summer Design Conditions

Outside db 92 °F
Inside db 75 °F
Design TD 17 °F
Daily range M
Relative humidity 50 %
Moisture difference 44 gr/lb

Heating Summary

Structure 19240 Btuh
Ducts 3332 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Humidification 0 Btuh
Piping 0 Btuh
Equipment load 22572 Btuh

Sensible Cooling Equipment Load Sizing

Structure 23871 Btuh
Ducts 3956 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Blower 0 Btuh
Use manufacturer's data n
Rate/swing multiplier 0.97
Equipment sensible load 27049 Btuh

Infiltration

Method Simplified
Construction quality Average
Fireplaces 0

Latent Cooling Equipment Load Sizing

Structure 2128 Btuh
Ducts 745 Btuh
Central vent (0 cfm)
(none) 0 Btuh
Equipment latent load 2873 Btuh

	Heating	Cooling
Area (ft²)	2100	2100
Volume (ft³)	16800	16800
Air changes/hour	0.32	0.16
Equiv. AVF (cfm)	90	45

Equipment Total Load (Sen+Lat) 29922 Btuh
Req. total capacity at 0.80 SHR 2.8 ton

Heating Equipment Summary

Make Goodman Mfg.
Trade GOODMAN
Model GSZH503610A
AHRI ref 208511690

Efficiency 7.8 HSPF2
Heating input 34400 Btuh @ 47°F
Heating output 28 °F
Temperature rise 1140 cfm
Actual air flow 0.051 cfm/Btuh
Air flow factor 0.53 in H2O
Static pressure
Space thermostat
Capacity balance point = 24 °F

Backup:
Input = 7 kW, Output = 23159 Btuh, 100 AFUE

Cooling Equipment Summary

Make Goodman Mfg.
Trade GOODMAN
Cond GSZH503610A
Coil AMST36CU1400A
AHRI ref 208511690

Efficiency 12.0 EER2, 15.2 SEER2
Sensible cooling 27360 Btuh
Latent cooling 6840 Btuh
Total cooling 34200 Btuh
Actual air flow 1140 cfm
Air flow factor 0.041 cfm/Btuh
Static pressure 0.53 in H2O
Load sensible heat ratio 0.91

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Project Information

For: Solomon Residence
862 SW Bluff Drive, Fort White, FL 32038

	Heating	Cooling
External static pressure	0.53 in H ₂ O	0.53 in H ₂ O
Pressure losses	0 in H ₂ O	0 in H ₂ O
Available static pressure	0.53 in H ₂ O	0.53 in H ₂ O
Supply / return available pressure	0.375 / 0.155 in H ₂ O	0.375 / 0.155 in H ₂ O
Lowest friction rate	0.286 in/100ft	0.286 in/100ft
Actual air flow	1140 cfm	1140 cfm
Total effective length (TEL)	185 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
BATH 1	h 158	8	4	0.342	4.0	0x0	VIFx	19.7	90.0	st4
BATH 2	h 415	21	9	0.326	4.0	0x0	VIFx	25.3	90.0	st4
BED 1	h 2150	109	91	0.316	6.0	0x0	VIFx	28.7	90.0	st4
BED 2	h 1310	66	63	0.336	5.0	0x0	VIFx	21.8	90.0	st4
DINING	h 2233	113	96	0.301	6.0	0x0	VIFx	34.5	90.0	st3
HALL 1	h 526	27	19	0.313	4.0	0x0	VIFx	30.1	90.0	st3
KITCHEN	c 3598	64	147	0.303	7.0	0x0	VIFx	33.9	90.0	st3
LAUNDRY	h 2122	107	92	0.286	6.0	0x0	VIFx	41.1	90.0	st3
LIVING	c 2496	91	102	0.320	6.0	0x0	VIFx	27.2	90.0	st3
LIVING-A	c 2496	91	102	0.326	6.0	0x0	VIFx	25.3	90.0	st3
M BATH	h 1354	68	39	0.340	5.0	0x0	VIFx	20.4	90.0	st1
M BED	c 2627	99	108	0.332	6.0	0x0	VIFx	23.1	90.0	st1
M BED-A	c 2627	99	108	0.352	6.0	0x0	VIFx	16.5	90.0	st1
M WIC	h 1652	83	35	0.377	6.0	0x0	VIFx	9.6	90.0	st2
OFFICE	c 2905	80	119	0.381	7.0	0x0	VIFx	8.5	90.0	st2
PAN	h 262	13	6	0.311	4.0	0x0	VIFx	30.5	90.0	st4

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st3	Peak AVF	493	559	0.286	523	14.0	0 x 0	VinIFlx	
st4	Peak AVF	217	173	0.311	491	9.0	0 x 0	VinIFlx	
st1	Peak AVF	267	254	0.332	489	10.0	0 x 0	VinIFlx	
st2	Peak AVF	164	154	0.377	469	8.0	0 x 0	VinIFlx	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	0x 0	790	851	42.1	0.367	481	18.0	0x 0		VIFx	
rb2	0x 0	350	289	54.0	0.286	446	12.0	0x 0		VIFx	

Project Information

For: Solomon Residence
862 SW Bluff Drive, Fort White, FL 32038

Cooling Equipment

Design Conditions

Outdoor design DB:	92.2°F	Sensible gain:	27828	Btuh	Entering coil DB:	75.9°F
Outdoor design WB:	75.8°F	Latent gain:	2873	Btuh	Entering coil WB:	62.9°F
Indoor design DB:	75.0°F	Total gain:	30701	Btuh		
Indoor RH:	50%	Estimated airflow:	1140	cfm		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split ASHP				
Manufacturer:	Goodman Mfg.	Model:	GSZH503610A+AMST36CU1400A		
Actual airflow:	1140	cfm			
Sensible capacity:	30753	Btuh	111%	of load	
Latent capacity:	4220	Btuh	147%	of load	
Total capacity:	34973	Btuh	114%	of load	SHR: 88%

Heating Equipment

Design Conditions


Outdoor design DB:	33.2°F	Heat loss:	22572	Btuh	Entering coil DB:	69.6°F
Indoor design DB:	70.0°F					

Manufacturer's Performance Data at Actual Design Conditions


Equipment type:	Split ASHP				
Manufacturer:	Goodman Mfg.	Model:	GSZH503610A+AMST36CU1400A		
Actual airflow:	1140	cfm			
Output capacity:	25662	Btuh	114%	of load	Capacity balance: 24 °F
Supplemental heat required:	0	Btuh			Economic balance: -99 °F

Backup equipment type:	Elec strip				
Manufacturer:		Model:			
Actual airflow:	1140	cfm			
Output capacity:	6.8	kW	103%	of load	Temp. rise: 50 °F

Meets all requirements of ACCA Manual S.



Solomon Residence



Job #: J-9635 - C-1724
Performed by LaTisha Furmon for:
Solomon Residence
862 SW Bluff Drive
Fort White, FL 32038

Scale: 1 : 98
Page 1
Right-Suite® Universal 2022
22.0.06 RSU 11033
2023-Mar-27 15:08:09
...635 - C-1724J-9635 - C-1724.rup