



NOTE:
ALL BEDROOM RECEPTACLES SHALL BE AFCI
(ARC FAULT CIRCUIT INTERRUPT)

ALL SMOKE DETECTORS SHALL HAVE BATTERY BACKUP POWER
AND ALL WIRED TOGETHER SO IF ANY ONE UNIT IS ACTUATED THEY
ALL ACTIVATE.

NOTE!
UFER grounding required per N.E.C.
Arc fault breakers required per N.E.C.
GFCI breakers required per N.E.C.
Tamper resistant receptacles required per N.E.C.



TOTAL AREA	960	S.F.
------------	-----	------

REVISIONS SCHEDULE	

JONES RESIDENCE

MORRIS
263 SW ERIN GLN.
LAKE CITY, FLORIDA
(386) 288 - 1188
jnmorris89@aatt.net

SHEET NAME

P.1

1 SHEETS

