



Britt Surveying and Mapping, LLC

2086 SW Main Blvd Ste 112 • Lake City, FL 32025

386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

12/26/2021

Permit # 000043080

L-28154

Cornerstone Development

Re: Lot 85 Emerald Cove Phase 2

To Whom It May Concern:

The top of the finished slab on said Lot 85 is 105.95 feet. The building permit requires the minimum floor to be 104 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,


L. Scott Britt
LS 5757