

DATE 09/13/2005

Columbia County Building Permit

PERMIT

This Permit Expires One Year From the Date of Issue

000023596

APPLICANT GARY HAMILTON PHONE 758-6755
ADDRESS 513 SW DEPUTY J. DAVIS LANE LAKE CITY FL 32024
OWNER FRANK FISCHER PHONE 386 984-7803
ADDRESS 473 SW BUCHANAN DRIVE LAKE CITY FL 32024
CONTRACTOR BRUCE GOODSON PHONE 623-4308
LOCATION OF PROPERTY 90W, TL ON SISTERS WELCOME RD, TR ON CR 242, TR ON FRIEND-SHIP, TR ON BUCHANAN, LOT ON LEFT, ACROSS FROM 3RD ST DOWN
TYPE DEVELOPMENT MH, UTILITY ESTIMATED COST OF CONSTRUCTION .00
HEATED FLOOR AREA TOTAL AREA HEIGHT .00 STORIES
FOUNDATION WALLS ROOF PITCH FLOOR
LAND USE & ZONING RR MAX. HEIGHT
Minimum Set Back Requirments: STREET-FRONT 25.00 REAR 15.00 SIDE 10.00
NO. EX.D.U. 0 FLOOD ZONE X PP DEVELOPMENT PERMIT NO.

PARCEL ID 22-4S-16-03090-133 SUBDIVISION BLAINE ESTATES
LOT 3 BLOCK PHASE UNIT TOTAL ACRES

000000809 IH0000702
Culvert Permit No. Culvert Waiver Contractor's License Number Applicant/Owner/Contractor
CULVERT 05-0902-N BK HD Y
Driveway Connection Septic Tank Number LU & Zoning checked by Approved for Issuance New Resident

COMMENTS: ONE FOOT ABOVE ROAD,

Check # or Cash 5391

FOR BUILDING & ZONING DEPARTMENT ONLY

(footer/Slab)

Temporary Power date/app. by Foundation date/app. by Monolithic date/app. by
Under slab rough-in plumbing date/app. by Slab date/app. by Sheathing/Nailing date/app. by
Framing date/app. by Rough-in plumbing above slab and below wood floor date/app. by
Electrical rough-in date/app. by Heat & Air Duct date/app. by Peri. beam (Lintel) date/app. by
Permanent power date/app. by C.O. Final date/app. by Culvert date/app. by
M/H tie downs, blocking, electricity and plumbing date/app. by Pool date/app. by
Reconnection date/app. by Pump pole date/app. by Utility Pole date/app. by
M/H Pole date/app. by Travel Trailer date/app. by Re-roof date/app. by

BUILDING PERMIT FEE \$.00 CERTIFICATION FEE \$.00 SURCHARGE FEE \$.00
MISC. FEES \$ 200.00 ZONING CERT. FEE \$ 50.00 FIRE FEE \$ WASTE FEE \$
FLOOD ZONE DEVELOPMENT FEE \$ CULVERT FEE \$ 25.00 TOTAL FEE 275.00

INSPECTORS OFFICE CLERKS OFFICE

NOTICE: IN ADDITION TO THE REQUIREMENTS OF THIS PERMIT, THERE MAY BE ADDITIONAL RESTRICTIONS APPLICABLE TO THIS PROPERTY THAT MAY BE FOUND IN THE PUBLIC RECORDS OF THIS COUNTY. AND THERE MAY BE ADDITIONAL PERMITS REQUIRED FROM OTHER GOVERNMENTAL ENTITIES SUCH AS WATER MANAGEMENT DISTRICTS, STATE AGENCIES, OR FEDERAL AGENCIES.

"WARNING TO OWNER: YOUR FAILURE TO RECORD A NOTICE OF COMMENCEMENT MAY RESULT IN YOUR PAYING TWICE FOR IMPROVEMENTS TO YOUR PROPERTY. IF YOU INTEND TO OBTAIN FINANCING, CONSULT WITH YOUR LENDER OR AN ATTORNEY BEFORE RECORDING YOUR NOTICE OF COMMENCEMENT."

This Permit Must Be Prominently Posted on Premises During Construction

PLEASE NOTIFY THE COLUMBIA COUNTY BUILDING DEPARTMENT AT LEAST 24 HOURS IN ADVANCE OF EACH INSPECTION, IN ORDER THAT IT MAY BE MADE WITHOUT DELAY OR INCONVENIENCE, PHONE 758-1008. THIS PERMIT IS NOT VALID UNLESS THE WORK AUTHORIZED BY IT IS COMMENCED WITHIN 6 MONTHS AFTER ISSUANCE.

The Issuance of this Permit Does Not Waive Compliance by Permittee with Deed Restrictions.

CK# 5391

PERMIT APPLICATION / MANUFACTURED HOME INSTALLATION APPLICATION

For Office Use Only

Zoning Official

BLK 08.09.05

Building Official

ND 9-8-05

AP# 0805-116

Date Received 8-31-05

By JW

Permit # 809/ 23596

Flood Zone R-1

Development Permit

N/A

Zoning RR

Land Use Plan Map Category

Res. U.L. Dec.

Comments

Report on Health Plan

Need spec sheet

Need spec sheet

FEMA Map #

Elevation

Finished Floor

River

In Floodway

☒ Site Plan with Setbacks shown☒

Environmental Health Signed Site Plan

☐

Env. Health Release

☒ Well letter provided☒

Existing Well

Revised 9-23-04

- Property ID 22-48-16-03090-133 Must have a copy of the property deed
- New Mobile Home ☒ Used Mobile Home Year 2006
- Subdivision Information Lot 3 Block 2 Blaine Estates S/D, Lake City, FL
- Applicant Gary Hamilton Homes Phone # (386) 758-6755
- Address 513 SW Deputy J. Davis Lane Lake City, FL 32024
- Name of Property Owner Frank Fischer Phone# (386) 984-7803
- 911 Address 473 SW Buchanan Dr. Lake City, FL 32024
- Circle the correct power company - FL Power & Light - Clay Electric
- (Circle One) - Suwannee Valley Electric - Progressive Energy
- Name of Owner of Mobile Home Frank Fischer Phone # (386) 984-7803
- Address P.O. Box 1033 Lake City, FL 32056
- Relationship to Property Owner Agent / Contractor
- Current Number of Dwellings on Property 0
- Lot Size Total Acreage 1.00 Acre
- Do you : Have an Existing Drive or need a Culvert Permit or a Culvert Waiver Permit
- Driving Directions Hwy 90 West, TL on Sisters Welcome Rd, TR on CR 242, TR on Friendship Way, TR on Buchanan - Prop on left (across from 3rd Street down)
- Is this Mobile Home Replacing an Existing Mobile Home No 275.00
- Name of Licensed Dealer/Installer Bruce B Goodson Phone # (386) 623-4308
- Installers Address 1505 SW CR 252B Lake City, FL 32024
- License Number IH0000702 Installation Decal # 254147

PERMIT WORKSHEET

Installer: Bruce B. Goodson License # TH000702

Address of home
being installed


Manufacturer	Door Valley	Length x width	52 x 32
--------------	-------------	----------------	---------

NOTE:

- if home is a single wide fill out one half of the blocking plan
- if home is a triple or quad wide sketch in remainder of home

I understand Lateral Arm Systems cannot be used on any home (new or used) where the sidewall lies exceed 5 ft 4 in.

Installer's initials



Poured concrete 8" deep 2nd 5 bars steel 16" to 20" wide
 Major 110' V (4)
 ABS pads Perimeter 16x16" 17x22"
 on side

New Home ☒ Used Home ☐
 Home installed to the Manufacturer's Installation Manual
 Home is installed in accordance with Rule 15-C
 Single wide ☐ Wind Zone II ☐ Wind 21
 Double wide ☒ Installation Decal # DIAK10600
 Triple/Quad ☐ Serial #

PIER SPACING TABLE FOR USED HOMES

Load bearing capacity	Footer size (sq in)	16" x 16" (256)	18 1/2" x 18 1/2" (342)	20" x 20" (400)	22" x 22" (484)*	24" X 24" (576)*	26" x 26" (676)
1000 psf		3'	4'	5'	6'	7'	8'
1500 psf		4'6"	6'	7'	8'	8'	8'
2000 psf		6'	8'	8'	8'	8'	8'
2500 psf		7'6"	8'	8'	8'	8'	8'
3000 psf		8'	8'	8'	8'	8'	8'
3500 psf		8'	8'	8'	8'	8'	8'

* interpolated from Rule 15C-1 pier spacing table

PIER PAD SIZES

l-beam pier pad size found on site

Perimeter pier pad size 1' x 2'

Other pier pad sizes 16' x 16'
(required by the mfg.)

 Draw the approximate locations of marriage wall openings 4 foot or greater. Use this symbol to show the piers.

List all marriage wall openings greater than 4 feet and their pier pad sizes below.

ANCHORS

Opening	8'
Pier pad size	17x22

FRAME TIES

TIEDOWN COMPONENTS

Longitudinal Stabilizing Device (LSD)
Manufacturer Quin
Longitudinal Stabilizing Device w/ Lateral Arms
Manufacturer

OTHER TIES

Sidewall	
Longitudinal	
Marriage wall	
Shearwall	

POPULAR PAD SIZES

Pad Size	Sq In
16 x 16	256
16 x 18	288
18.5 x 18.5	342
16 x 22.5	360
17 x 22	374
13 1/4 x 26 1/4	348
20 x 20	400
17 3/16 x 25 3/16	441
17 1/2 x 25 1/2	446
24 x 24	576
26 x 26	676

POCKET PENETROMETER TEST

The pocket penetrometer tests are rounded down to 1500 psf or check here to declare 1000 lb. soil without testing.

x 2000 x 1800 x 2000

POCKET PENETROMETER TESTING METHOD

1. Test the perimeter of the home at 6 locations.
2. Take the reading at the depth of the footer.
3. Using 500 lb. increments, take the lowest reading and round down to that increment.

x 2000 x 1800 x 1800

TORQUE PROBE TEST

The results of the torque probe test is 289 inch pounds or check here if you are declaring 5' anchors without testing . A test showing 275 inch pounds or less will require 4 foot anchors.

Note: A state approved lateral arm system is being used and 4 ft. anchors are allowed at the sidewall locations. I understand 5 ft anchors are required at all centerline tie points where the torque test reading is 275 or less and there the mobile home manufacturer may requires anchors with 4000 lb holding capacity.

BDW Installer's initials

ALL TESTS MUST BE PERFORMED BY A LICENSED INSTALLER

Installer Name Bruce Goodson
Date Tested 8/30/05

Electrical

Connect electrical conductors between multi-wide units, but not to the main power source. This includes the bonding wire between multi-wide units. Pg. ✓

Plumbing

Connect all sewer drains to an existing sewer tap or septic tank. Pg. ✓
Connect all potable water supply piping to an existing water meter, water tap, or other dependent water supply systems. Pg. ✓

Site Preparation

Debris and organic material removed ✓
Water drainage: Natural ✓ Swale Pad Other

Fastening multi wide units

Floor: Type Fastener: 3/16 lag Length: 5" Spacing: 24" o/c
Walls: Type Fastener: #8 screw Length: 4" Spacing: 12" o/c
Roof: Type Fastener: 3/16 lag Length: 6" Spacing: 24" o/c
For used homes: a min. 30 gauge, 8" wide, galvanized metal strip will be centered over the peak of the roof and fastened with galv. roofing nails at 2" on center on both sides of the centerline.

Gasket (weatherproofing requirement)

I understand a properly installed gasket is a requirement of all new and used homes and that condensation, mold, mildew and buckled marriage walls are a result of a poorly installed or no gasket being installed. I understand a strip of tape will not serve as a gasket.

Installer's initials BDW

Type gasket foam with poly coat.
Pg.
Installed: Between Floors Yes ✓
Between Walls Yes ✓
Bottom of ridgebeam Yes ✓

Weatherproofing

The bottomboard will be repaired and/or taped. Yes ✓ Pg.
Siding on units is installed to manufacturer's specifications. Yes ✓
Fireplace chimney installed so as not to allow intrusion of rain water. Yes ✓

Miscellaneous

Skirting to be installed. Yes ✓ No
Dryer vent installed outside of skirting. Yes ✓ N/A
Range downflow vent installed outside of skirting. Yes ✓ N/A
Drain lines supported at 4 foot intervals. Yes ✓
Electrical crossovers protected. Yes ✓
Other:

Installer verifies all information given with this permit worksheet is accurate and true based on the manufacturer's installation instructions and or Rule 15C-1 & 2

Installer Signature Bruce Goodson Date 8/30/05

STEEL BEAM PIER LOADS (LBS.)

ROOF ZONE	SPACING	24'	UNIT WIDTH	
			14'&28'	16'&32'
SOUTH	4' O.C.	-	2562	2748
SOUTH	5' O.C.	-	3203	3435
SOUTH	6' O.C.	-	3844	4122
SOUTH	7' O.C.	-	4484	4809
SOUTH	8' O.C.	-	5125	5496

SIDEWALL OPENING PIER LOADS (LBS)

OPENING WIDTH	ROOF ZONE	24'	UNIT WIDTH	
			14'&28'	16'&32'
4'	SOUTH	-	475	510
6'	SOUTH	-	713	765
8'	SOUTH	-	950	1020
10'	SOUTH	-	1188	1275
12'	SOUTH	-	1426	1530
14'	SOUTH	-	1663	1785
16'	SOUTH	-	1901	2040

- NOTES: (1) OPENING WIDTH = opening width of the door and/or window opening in sidewall; if the same pier supports loads from two adjacent openings add the adjacent opening widths together before using the chart above.
- (2) The table is applicable to the nominal home widths when constructed from the module dimensions specified below:
- 24': N/A
 - 28': 166" floor with 12" max. roof overhang
 - 32': 180" floor with 12" max. roof overhang
 - 14': N/A
 - 16': N/A
- (3) The table is applicable to floor systems which do not require perimeter blocking.



Aug. 24. 2005 8:58AM Abstract & Title

No. 6610 P. 2

Prepared by:
Michael H. Harrell
Abstract & Title Services, Inc.
111 East Howard Street
Live Oak, Florida 32064

AT9# 16148

Inst:2005010413 Date:08/03/2005 Time:09:58

Doc Stamp-Deed : 245.00

DC, P. DeWitt Cason, Columbia County B: 1053 P: 2008

Warranty Deed

Individual to Individual

THIS WARRANTY DEED made the 29th day of July, 2005, Daniel Crapps and L. James Cherry, as Trustees of the CR-242 Land Trust, dated November 14, 1998., hereinafter called the grantor, to Frank Fischer, and his wife, Jessie Fischer whose post office address is: SW Buchanan Dr., Lake City, FL 32065 hereinafter called the grantee;

(Wherever used herein the terms "grantor" and "grantee" include all the parties to this instrument and the heirs, legal representatives and assigns of individuals, and the successors and assigns of corporation)

Witnesseth: That the grantor, for and in consideration of the sum of \$10.00 and other valuable considerations, receipt whereof is hereby acknowledged, hereby grants, bargains, sells, aliens, remises, releases, conveys, and confirms unto the grantee, all that certain land situate in COLUMBIA County, Florida, viz: Parcel ID# Part of 03090-000

Lot 3, Block 2, Blaine Estates Phase II, a subdivision according to the plat thereof, recorded in Plat Book 7, Pages 147-1748, Public Records of Columbia County, Florida.

Neither the Grantor, nor any Member of the Grantor's Family, resides on, or adjacent to, the above-described property.

TOGETHER with all tenements, hereditaments and appurtenances thereto belonging or in anywise appertaining.

TO HAVE AND TO HOLD, the same in fee simple forever.

AND the grantor hereby covenants with said grantee that the grantor is lawfully seized of said land in fee simple; that the grantor has good right and lawful authority to sell and convey said land; that the grantor hereby fully warrants the title to said land and will defend the same against the lawful claims of all persons whomsoever, and that said land is free of all encumbrances, except taxes accruing subsequent to December 31, 2004.

IN WITNESS WHEREOF, the said grantor has signed and sealed these presents the day and year first above written.

Signed, sealed and delivered in our presence:

[Signature]
Witness:

[Signature]
Witness:

[Signature]
Daniel Crapps

STATE OF FLORIDA
COUNTY OF COLUMBIA

The foregoing instrument was acknowledged before me this 29th day of July, 2005 by DANIEL CRAPPS, AS TRUSTEE OF THE CR-242 LAND TRUST, DATED NOVEMBER 14, 1998, personally known to me or, if not personally known to me, who produced Driver's License No. _____ for identification and who did not take an oath.

[Signature]
Notary Public

(Notary Seal)



Vera Lisa Hicks
My Commission DD131707
Expires August 23, 2006

COLUMBIA COUNTY 9-1-1 ADDRESSING

263 NW Lake City Ave. • P. O. Box 1787 • Lake City, FL 32056-1787
PHONE: (386) 758-1125 • FAX: (386) 758-1363 • Email: ron_croft@columbiacountyfla.com

Addressing Maintenance

To maintain the Countywide Addressing Policy you must make application for a 9-1-1 Address at the time you apply for a building permit. The established standards for assigning and posting numbers to all principal buildings, dwellings, businesses and industries are contained in Columbia County Ordinance 2001-9. The addressing system is to enable Emergency Service Agencies to locate you in an emergency, and to assist the United States Postal Service and the public in the timely and efficient provision of services to residents and businesses of Columbia County.

DATE ISSUED: August 22, 2005

ENHANCED 9-1-1 ADDRESS:

473 SW BUCHANAN DR (LAKE CITY, FL 32024)

Addressed Location 911 Phone Number: NOT AVAIL.

OCCUPANT NAME: NOT AVAIL.

OCCUPANT CURRENT MAILING ADDRESS: _____

PROPERTY APPRAISER PARCEL NUMBER: 22-48-16-03090-133

Other Contact Phone Number (if any): _____

Building Permit Number (if known): _____

REMARKS: LOT 3, BLOCK 2, BLAINE ESTATES, PHASE 2, S/D

Address Issued By

[Signature]
Columbia County 9-1-1 Addressing / GIS Department

NOTICE: THIS ADDRESS WAS ISSUED BASED ON LOCATION INFORMATION RECEIVED FROM THE REQUESTER. SHOULD AT A LATER DATE, THE LOCATION INFORMATION BE FOUND TO BE IN ERROR, THIS ADDRESS IS SUBJECT TO CHANGE.


COLUMBIA COUNTY
9-1-1 ADDRESSING
APPROVED

Application for Onsite Sewage Disposal System Construction Permit. Part II Site Plan

Permit Application Number: _____

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH UNIT

FISCHER/CR 05-3046



Site Plan Submitted By _____ Date _____
Plan Approved _____ Not Approved _____ Date _____

By _____ CPHU

Notes: _____

RON E. BIAS WELL DRILLING

Route 2, Box 5340
Ft. White, Florida 32038
(386) 497-1045
Mobile: 364-9233

Private Well Affidavit

Customer:

FRANK Fischer

Address:

Lake City, FL 32024

Size of Pump Motor:

1 HP

Size of Pressure Tank:

120 Press. Tank

Cycle Stop Value:

☒ Yes

Or

No

Other:

1 1/4 Drop 20 GPM

RON E. BIAS WELL DRILLING

X

Ron E. Bias


Ron E. Bias

Application for Onsite Sewage Disposal System Construction Permit. Part II Site Plan

Permit Application Number: 05-0902N

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH UNIT

FISCHER/CR 05-3046



Site Plan Submitted By Paul L. [Signature] Date 8/30/05
 Plan Approved [Signature] Not Approved _____ Date 09/01/05
 By [Signature] FSH Columbia CPHU

Notes: _____

STEEL BEAM PIER LOADS (LBS.)

ROOF ZONE	SPACING	24'	UNIT WIDTH	
			14'&28'	16'&32'
SOUTH	4' O.C.	-	2562	2748
SOUTH	5' O.C.	-	3203	3435
SOUTH	6' O.C.	-	3844	4122
SOUTH	7' O.C.	-	4484	4809
SOUTH	8' O.C.	-	5125	5496

SIDEWALL OPENING PIER LOADS (LBS)

OPENING WIDTH	ROOF ZONE	24'	UNIT WIDTH	
			14'&28'	16'&32'
4'	SOUTH	-	475	510
6'	SOUTH	-	713	765
8'	SOUTH	-	950	1020
10'	SOUTH	-	1188	1275
12'	SOUTH	-	1426	1530
14'	SOUTH	-	1663	1785
16'	SOUTH	-	1901	2040

- NOTES: (1) OPENING WIDTH = opening width of the door and/or window opening in sidewall; if the same pier supports loads from two adjacent openings add the adjacent opening widths together before using the chart above.
- (2) The table is applicable to the nominal home widths when constructed from the module dimensions specified below:

24': N/A

28': 166" floor with 12" max.
roof overhang

32': 180" floor with 12" max.
roof overhang


14': N/A

16': N/A

- (3) The table is applicable to floor systems which do not require perimeter blocking.



TYPICAL FOOTING SPECIFICATIONS




16" x 16"

- (1) 16" x 16" x 4" PRECAST FOOTING OR
- (2) 16" x 8" x 4" PRECAST FOOTING OR
- (1) 16" x 16" x 6" POURED-IN-PLACE FOOTING

SINGLE OR DOUBLE TIERED PIERS

MAXIMUM PIER LOADS	1773 LB	2659 LB	3546 LB	4432 LB
SOIL CAPACITY (PSF)	1000	1500	2000	2500




24" x 16"

- (3) 16" x 8" x 4" PRECAST FOOTING OR
- (1) 24" x 16" x 6" POURED-IN-PLACE FOOTING

SINGLE OR DOUBLE TIERED PIERS

MAXIMUM PIER LOADS	2666 LB	3999 LB	5332 LB	6665 LB
SOIL CAPACITY (PSF)	1000	1500	2000	2500



24" x 24"

- (5) 16" x 8" x 4" PRECAST FOOTING (SHOWN) OR
- (1) 24" x 24" x 6" POURED-IN-PLACE FOOTING


DOUBLE TIERED PIERS ONLY

MAXIMUM PIER LOADS	4000 LB	6000 LB	8000 LB	10000 LB
SOIL CAPACITY (PSF)	1000	1500	2000	2500

GENERAL NOTES:

- CONCRETE COMPRESSIVE STRENGTH:
PRECAST = 4000 PSI AT 28 DAYS
POURED-IN-PLACE = 2500 PSI AT 28 DAYS

- POURED-IN-PLACE FOOTINGS MUST BE
POURED OVER (MIN) 4 MIL POLETHYLENE.



THIRD PARTY

REVISIONS



LTR:	BY:	DATE:

DEER VALLEY

SUPPORT SYSTEM
FIELD INSTALLED

DRAWN BY: WJK DAPIA NO.:

14



**Columbia County Building Department
Culvert Permit**

**Culvert Permit No.
000000809**

DATE 09/13/2005 PARCEL ID # 22-4S-16-03090-133
APPLICANT GARY HAMILTON PHONE 758-6755
ADDRESS 513 SW DEPUTY J. DAVIS LANE LAKE CITY FL 32024
OWNER FRANK FISCHER PHONE 386 984-7803
ADDRESS 473 SW BUCHANAN DRIVE LAKE CITY FL 32056
CONTRACTOR BRUCE GOODSON PHONE 623-4308
LOCATION OF PROPERTY 90W, TL ON SISTERS WELCOME ROAD, TR ON CR 242, TR ON FRIENDSHIP WAY,
TR ON BUCHANAN, PROPERTY ON LEFT, ACROSS FROM 3RD ST DOWN)

SUBDIVISION/LOT/BLOCK/PHASE/UNIT BLAINE ESTATES 3

SIGNATURE



INSTALLATION REQUIREMENTS



Culvert size will be 18 inches in diameter with a total length of 32 feet, leaving 24 feet of driving surface. Both ends will be mitered 4 foot with a 4 : 1 slope and poured with a 4 inch thick reinforced concrete slab.

INSTALLATION NOTE: Turnouts will be required as follows:

- a) a majority of the current and existing driveway turnouts are paved, or;
- b) the driveway to be served will be paved or formed with concrete.

Turnouts shall be concrete or paved a minimum of 12 feet wide or the width of the concrete or paved driveway, whichever is greater. The width shall conform to the current and existing paved or concreted turnouts.



Culvert installation shall conform to the approved site plan standards.



Department of Transportation Permit installation approved standards.



Other _____

**ALL PROPER SAFETY REQUIREMENTS SHOULD BE FOLLOWED
DURING THE INSTALLATION OF THE CULVERT.**

135 NE Hernando Ave., Suite B-21
Lake City, FL 32055
Phone: 386-758-1008 Fax: 386-758-2160

Amount Paid 25.00



EXP
9/29/05

COLUMBIA COUNTY
FLORIDA

M/H OCCUPANCY

COLUMBIA COUNTY, FLORIDA

Department of Building and Zoning Inspection

This Certificate of Occupancy is issued to the below named permit holder for the building and premises at the below named location, and certifies that the work has been completed in accordance with the Columbia County Building Code.

Parcel Number 22-4S-16-03090-133

Building permit No. 000023596

Permit Holder BRUCE GOODSON

Owner of Building FRANK FISCHER

Location: 473 SW BUCHANAN DR.(BLAINE EST., LOT 3)

Date: 09/29/2005



Harry Dietz
by *[Signature]* Building Inspector

POST IN A CONSPICUOUS PLACE
(Business Places Only)