

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

May 19, 2023

Mr. Buddy Scott

386.365.1222

wscottconstruction@gmail.com

re: ANCHOR BOLT WASHERS: 8803 SE CR 245, LAKE CITY, FL

The required 3" x 3" x 1/8" washer may be replaced with 2" x 2" x 1/8" washers.

In my professional opinion, this structure meets the structural load and uplift requirement for a residential dwelling per the Florida Building Code 2020, 7th Edition, Residential. Should you have any questions, please don't hesitate to contact me.

Respectfully,

Carol Chadwick, P.E.



Digitally signed
by Carol
Chadwick
DN: c=US,
o=Florida,
dnQualifier=A014
10D0000017EB6D
924CE0005954C,
cn=Carol
Chadwick
Date: 2023.05.19
11:06:20 -04'00'

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

CC Job #FL22118

