



15th FEB 2022

BUILDING OFFICIAL / INSPECTOR
COUNTY BUILDING DEPT.

RE: CODY BARRS RESIDENCE

TO WHOM IT MAY CONCERN:

THE FRAMING HAS BEEN INSPECTED AND MEETS OR EXCEEDS
THE STRUCTURAL REQUIREMENTS SET FORTH IN OUR PROVIDED DRAWINGS.
ONLY THE ROOF GIRDER TRUSSES WILL REQUIRE SIMPSON HOLD-DOWN FASTNERS.
SIMPSON HD3B IS APPROVED ALTERNATE TO HTT5 USING (2) ¼" x 4½" LAG SCREWS
USE SIMPSON HD3B AT GARAGE DOORS OPENINGS & ROOF GIRDER TRUSS POSTS.

BEST REGARDS,

