

December 13, 2021

Melodee Scheffler
586 NE Bridgewater Terrace
Lake City, FL 32055

Subject: Permit # 42004 - Parcel # 24-03-16-02275-113, Lot 13, Cobblestone, Unit 1

Dear Mrs. Scheffler:

Daniel & Gore, LLC has performed a vertical survey on Lot 13, Cobblestone, Unit 1, Columbia County, Florida and have determined the following:

- The Subdivision construction plans requires the minimum finish floor elevation to be 163.0' (NGVD 1929).
- The elevation of the finish floor is at 163.20', being 0.2' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM

