

---

**Britt Surveying and Mapping, LLC**

2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

02/15/2022

Permit # 000042423

L-28310


Family Home Center

Re: Lot 15 Quail Ridge

To Whom It May Concern:

The top of the finished slab on Lot 15 is found to be 79.81 feet. The building permit shows the minimum floor elevation to be 78.9 feet. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,

  
L. Scott Britt  
LS 5757