

DESIGN CRITERIA:

APPLICABLE CODES, REGULATIONS & STANDARDS:

1. THE 2023 FLORIDA BUILDING CODE 8TH EDITION, SPECIFICALLY CHAPTER 16 STRUCTURAL DESIGN, CH. 20 ALUM. & CH. 23 WOOD.
2. AA ASM 35 & SPECIFICATIONS FOR ALUMINUM STRUCTURES, PART 1-A OF THE ALUMINUM DESIGN MANUAL PREPARED BY THE ALUMINUM ASSOCIATION, INC. WASHINGTON D.C. 2005 ED.
3. ASCE 7-22 & SE17
4. NDS NATIONAL DESIGN SPECIFICATION FOR WOOD.
5. ACI318 CONCRETE REFERENCE MANUAL.

WIND LOADS:

1. BUILDING OCCUPANCY CATEGORY, PARAGRAPH 1604.5 & TABLE 1604.5: RISK CATEGORY: I
2. BASIC WIND SPEED, TABLE 1609C, STATE OF FLORIDA DEBRIS REGION & BASIC WIND SPEED, PARAGRAPH 1609.3.1 & TABLE 1609.3.1 EQUIVALENT BASIC WIND SPEED: 120 MPH EXPOSURE CATEGORY, PARAGRAPH 1609.4.3: C
3. WIND LOADS PER FBC TABLE 2002.4 (MWFRS) VULT = 120 MPH & EXPOSURE = C

FOR 20 X 20 X 0.013" MESH SCREEN  
HORIZONTAL PRESSURES ON WINDWARD SURFACES = 25 PSF  
HORIZONTAL PRESSURES ON LEEWARD SURFACES = 19 PSF  
VERTICAL PRESSURES ON SCREEN SURFACES = 7 PSF  
VERTICAL PRESSURES ON SOLID SURFACES = 25 PSF

FOR 18 X 14 X 0.013" MESH SCREEN, APPLIED FACTOR = .88  
FOR ALLOWABLE STRESS DESIGN, APPLIED FACTOR = .6

FOUNDATION DESIGN:

NO ADDITIONAL FOOTING OR FOUNDATION SYSTEM IS REQUIRED BY THE PROPOSED CONSTRUCTION IF A MINIMUM 4" CONCRETE SLAB IS PROVIDED IN SOUND CONDITION, FREE FROM STRUCTURAL CRACKING, SPALLING & OTHER DETERIORATION. EXISTING FOUNDATION/FOOTING UNDER CONCRETE SLAB MINIMUM 8"x8" w/ (1) #5 BAR TO BE VERIFIED BY CONTRACTOR. SEE TYPICAL FOOTING DETAILS FOR NEW FOOTING DESIGN MINIMUM REQUIREMENTS.

MISCELLANEOUS:

1. SCREENED ENCLOSURES CONTAINING SWIMMING POOLS SHALL COMPLY WITH THE APPLICABLE REQUIREMENTS OF FBC R4501.17 RESIDENTIAL SWIMMING BARRIER REQUIREMENTS.
2. ALUMINUM ADDITIONS ARE NOT TO BE INSTALLED ON A MANUFACTURED HOME, TRAILER HOME, OR PRE-FAB HOME. IF THE EXISTING STRUCTURE IS ONE OF THESE, A SEPARATE 4TH WALL SUPPORT SYSTEM IS SO TO BE ENGINEERED SO THAT NO ADDITIONAL LOADING IS PLACED ON THE MANUFACTURED HOME.
3. THE ENGINEERING ON THESE PLANS IS SITE SPECIFIC FOR (1) STRUCTURE ONLY AT THE PROVIDED ADDRESS(ES).

FASTENER SPECIFICATIONS:

1. FASTENERS ARE REQUIRED TO BE SAE GRADE 2 OR BETTER ZINC PLATED. (CONCRETE ANCHORS ARE TO BE 410 S.S. TAPCONS OR BETTER, INSTALLED TO MFG. SPECIFICATIONS)
2. WHERE WOOD DECK IS PRESENT USE 1/4" X 3-1/2" GALV. LAG SCREWS IN LIEU OF MASONRY ANCHORS. UNLESS OTHERWISE SPECIFIED.
3. FOR 1"x2" NON-STRUCTURAL MEMBERS ATTACHED TO HOST
  - a. FOR MASONRY/CONCRETE APPLICATION USE GALVANIZED 1/4" X 2-3/4" TAPCONS 6" FROM ENDS & 24" CENTER TO CENETER.
  - b. FOR WOOD APPLICATION USE # 14 X 2-3/4" WOOD SCREW AT 6" FROM ENDS & 24" CENTER TO CENETER.
  - c. FOR ALUMINUM APPLICATION USE #10 X 1-1/2" SMS OR TEK 6" FROM ENDS & 24" CENTER TO CENETER..
  - d. WHERE 1"x2" INSTALLED THROUGHOUT AN "OPEN VIEW" SPACING SHALL BE REDUCED TO 6" FROM ENDS & 18" C.C.

RESPONSIBILITIES:

1. ALL SITE WORK SHALL BE PERFORMED BY A LICENSED CONTRACTOR IN ACCORDANCE WITH APPLICABLE BUILDING CODES, LOCAL ORDANANCES, AND THE ENGINEER SHALL BE NOTIFIED OF ANY DISCREPANCIES.
2. FOR FASTENERS WHICH ARE NOT VISIBLE AFTER INSTALLATION, THE CONTRACTOR SHALL VERIFY AND ENSURE INSTALLATION HAS BEEN ACCOMPLISHED IN ACCORDANCE WITH MANUFACTURERS SPECIFICATIONS AND IN ACCORDANCE WITH THE ATTACHED DETAILS.
3. CONTRACTOR TO PROVIDE NOA'S & INSTALL ALL MATERIALS AS PER MANUFACTURER'S SPECIFICATIONS.
4. INTEGRITY OF EXISTING/ HOST STRUCTURE SHALL NOT BE COMPROMISED WITH THE ATTACHMENT OF THE PROPOSED STRUCTURE.
5. IT IS THE OWNERS RESPONSIBILITY TO MAINTAIN THE SCREENS & FASTENERS TO MANUFACTURING SPECIFICATIONS.
6. METAL WITHIN 5FT OF THE WATERS EDGE REQUIRE A CONTINUOUS BOND PER NEC NFPA 70: NATIONAL ELECTRIC CODE 680.43(D)(4): ALL METAL SURFACES THAT ARE WITHIN 1.5M (5FT) OF THE INSIDE WALLS OF THE SPA OR HOT TUB AND THAT ARE NOT SEPERATED FROM THE SPA OR HOT TUB AREA BY A PERMANENT BARRIER SHALL BE BONDED TOGETHER.

ALUMINUM SPECIFICATIONS:

1. ALUMINUM EXTRUSIONS SHALL BE 6005 T5 ALLOY UNLESS OTHERWISE NOTED.
2. ALL SELF MATING BEAM SECTIONS ARE TO BE STITCHED WITH
  - a.#14 SCREWS 6" FROM ENDS & 24" CENTER TO CENTER.
  - b. #12 SCREWS 6" FROM ENDS & 18" CENTER TO CENTER.
  - c. #10 SCREW 6" FROM ENDS & 12" CENTER TO CENEIER.
3. ROOF BRACING SHALL BE A MINIMUM 2"x3"x.050".
4. THE MINIMUM NORMAL THICKNESS OF PROTECTOR PANELS (KICKPLATES) SHALL BE AN INDUSTRY STANDARD OF 0.024 INCHES.
5. SCREEN MATERIAL SHALL BE 18/14 SCREEN UNLESS APPROVED BY FLORIDA ENGINEERING LLC.
6. 1"x2" & 1"x3" NON-STRUCTURAL MEMBERS MAY BE USED INTERCHANGEABLY.
7. DOOR LOCATION MAY BE DETERMINED/ RELOCATED BY CONTRACTOR IN THE FIELD. NOT TO AFFECT DESIGN SPANS AND STRUCTURAL MEMEBRS SHOWN

CONCRETE SPECIFICATIONS:

THE FOLLOWING SPECIFICATIONS ARE APPLICABLE TO THIS PROJECT:  
1. WHERE CONCRETE SPECIFICATIONS ARE REQUIRED, WHETHER IN THE SCREEN ENCLOSURE SCOPE OR NOT, BY ONE OR MORE REGULATORY AGENCIES, THE FOLLOWING SPECIFICATIONS ARE APPLICABLE:

- a. CONCRETE SHALL CONFORM TO ASTM C94 FOR THE FOLLOWING COMPONENTS:
    - i. PORTLAND CEMENT TYPE 1 - ASTM C 150
    - ii AGGREGATES - LARGE AGGREGATE 3/4 MAX. - ASTM C 33
    - iii. AIR ENTRAINING +/- 1 % - ASTM C 260
    - iv. WATER REDUCING AGENT - ASTM C 494
    - v. CLEAN POTABLE WATER
    - vi. OTHER ADMIXTURES NOT PERMITTED
  - b. METAL ACCESSORIES SHALL CONFORM TO:
    - i. REINFORCING BARS - ASTM A615, GRADE 60
    - ii. WELDED WIRE FABRIC - ASTM A185
  - c. CONCRETE SLUMP AT DISCHARGE CHUTE NOT LESS THAN 3" OR MORE THAN 5". WATER ADDED AFTER BATCHING IS NOT PERMITTED.
  - d. PREPARE & PLACE CONCRETE PER AMERICAN CONCRETE INSTITUTE MANUAL OF STANDARD PRACTICE, PART 1, 2, & 3 INCLUDING HOT WEATHER RECOMMENDATIONS.
  - e. MOIST CURE OR POLYETHYLENE CURING PERMITTED.
  - f. PRIOR TO PLACING CONCRETE, TREAT THE ENTIRE SUBSURFACE AREA FOR TERMITES IN COMPLIANCE WITH THE FBC. FOR RISK CATEGORY II, III, & IV STRUCTURES ONLY.
  - g. CONCRETE SLAB SHALL BE PLACED OVER A POLYETHYLENE VAPOR BARRIER. (SLAB ONLY)
2. WHEN PAVERS ARE UNDER ALUMINUM MEMBERS, CONTRACTOR SHALL EPOXY TO DECK OR GROUT TO DECK w/ 2000 PSI GROUT WITH BONDING AGENT
  3. WHEN APPLICABLE FOR NEW SLAB ADDITION TO ADJACENT DRILL & EPOXY #4 X 8" REBAR INTO EX. FOUNDATION EMBED 4" MIN W/ NON-SHRINKING SIMPSON EPOXY-TIE (OR EQUAL) 48" O.C. TYP. ALL LOCATIONS
  4. WHEN APPLICABLE FOR NEW FOOTER TO EXISTING, DRILL & EPOXY NEW STEEL INTO EX. FOUNDATION WITH EMBED 6" MIN W/ NON-SHRINKING SIMPSON EPOXY-TIE (OR EQUAL) TYP. ALL LOCATIONS
  5. WHERE PAVERS ARE UNDER ALUMINUM MEMBERS, CONTRACTOR SHALL EPOXY TO DECK OR GROUT TO DECK w/3000 PSI GROUT WITH BONDING AGENT.
  6. MINIMUM CONCRETE STRENGTH 3000 PSI UNLESS OTHERWISE NOTED.

MASONRY SPECIFICATIONS:

1. CONCRETE MASONRY UNITS (CMU) SHALL BE STANDARD HOLLOW UNITS AND SHALL BE 1900 PSI MINIMUM BASED ON TYPE M OR S MORTAR.
2. ALL MORTAR SHALL BE TYPE M OR S.
3. ALL GROUT SHALL BE 1800 PSI MINIMUM AND HAVE MAXIMUM COARSE AGGREGATE SIZE OF 3/8".
4. PROVIDE CLEAN-OUTS FOR REINFORCED CELLS CONTAINING REINFORCEMENT WHEN GROUT POUR EXCEEDS 5'-0" IN HEIGHT.

FOOTER SPECIFICATIONS:

1. PROVIDE 1-1/2" COVERAGE TOP, SIDES, BOTTOM AND 1" BETWEEN ADJACENT REBAR LAPS.
2. PROVIDE MIN. 3" COVERAGE OF REBAR FOR ALL CONCRETE IN CONTACT WITH THE EARTH.
3. FOOTING CONCRETE SHALL BE MIN. 3000 PSI AT 28 DAYS
4. FOOTING REINFORCEMENT SHALL BE MIN. GRADE 60
5. MINIMUM REBAR LAP SPLICE (40d) d= DIAMETER OF REBAR
6. PROVIDE POSITIVE DRAINAGE AWAY FROM STRUCTURE TO CITY / CO. REQUIREMENTS
7. PROVIDE 2500 PSF BEARING (TYPICAL) UNDER FOUNDATION
8. SEE GENERAL NOTES SHEET/01 FOR TYING INTO EXISTING FOUNDATIONS
9. SEE GENERAL NOTES SHEET/01 FOR ADDITIONAL CONCRETE INFORMATION & SPECS.

ALUMINUM MEMBERS DIMENSIONS:

HOLLOW SECTIONS  
2 x 2: 2" x 2" x 0.050"  
2 x 3: 2" x 3" x 0.050"  
2 x 4: 2" x 4" x 0.050"  
2 x 5: 2" x 5" x 0.050"

OPEN BACK SECTIONS  
1 x 2: 1" x 2" x 0.044"  
1 x 3: 1" x 3" x 0.045"

SNAP SECTIONS  
2 x 2 SNAP: 2" x 2" x 0.045"  
2 x 3 SNAP: 2" x 3" x 0.050"  
2 x 4 SNAP: 2" x 4" x 0.045"

SELF MATING (SMB)  
2 x 4 SMB: 2" x 4" x 0.046" x 0.100"  
2 x 5 SMB: 2" x 5" x 0.050" x 0.116"  
2 x 6 SMB: 2" x 6" x 0.050" x 0.120"  
2 x 7 SMB: 2" x 7" x 0.055" x 0.120"  
2 x 8 SMB: 2" x 8" x 0.072" x 0.224"  
2 x 9 SMB: 2" x 9" x 0.072" x 0.224"  
2 x 9(H) SMB: 2" x 9" x 0.082" x 0.306"  
2 x 10 SMB: 2" x 10" x 0.092" x 0.374"

ALL MAY NOT APPLY


DETAIL "A" MEMEBR DIMENSIONS

SHEET NO.	DRAWING INDEX
S/01	GENERAL NOTES
S/02	PLAN/ ELEVATIONS
S/03	DETAILS
S/04	DETAILS
S/05	DETAILS

<b>DESIGN LOADS:</b> 1. DEAD LOADS = 2. LIVE LOADS a. PRIMARY MEMBERS = b. SECONDARY MEMBERS = c. SCREEN ROOF = d. SOLID ROOF =	<i>MEMBER SELF-WEIGHT</i>  300 LB. VERT. LOAD 200 LB. VERT. LOAD 5 PSF 20 PSF
---	--




This item has been digitally signed and sealed by Richard E. Walker, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.



Digitally signed  
by Richard E Walker  
Date:  
2024.12.26  
13:28:28-05'00'

FLORIDA ENGINEERING LLC  
4161 TAMiami TRAIL, UNIT 101  
PORT CHARLOTTE, FLORIDA 33952  
(941) 391-5980  
FLEng.com




Orders@FLEng.com

PROJECT NO. 2435426




CA CERT. #30782

CONTRACTOR: BRITECH CONSTRUCTION CORP 517 VINTAGE WAY BRANDON FL,33511		PROJECT ADDRESS:  MALOY 11829 SE CR 245 LULU FL 32061	
DESIGN DATE:		12/26/2024	
REVISION 1:		DATE	
REVISION 2:		DATE	SHEET:  01
DRAWN BY:		MBG	
SCALE:		NTS	

① TRANSOM @ STRUCT.GUTTER



② TRANSOM @ STRUCT.GUTTER




PROPOSED MANSARD SCREEN ENCLOSURE


HATCH/ SYMBOL LEGEND

HATCH	INDICATES
	EXIST. STRUCTURE


NOTE: ALL MAY NOT APPLY



This item has been digitally signed and sealed by Richard E. Walker, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.



Digitally signed  
by Richard E Walker  
Date:  
2024.12.26  
13:28:28-05'00'



FLORIDA ENGINEERING LLC  
4161 TAMiami TRAIL, UNIT 101  
PORT CHARLOTTE, FLORIDA 33952  
(941) 391-5980  
FLEng.com  
Orders@FLEng.com

PROJECT NO. 2435426

CA CERT. #30782

CONTRACTOR:  
BRITTECH CONSTRUCTION CORP  
517 VINTAGE WAY  
BRANDON FL, 33511

PROJECT ADDRESS:

MALLOY  
11829 SE CR 245  
LULU FL 32061

DESIGN DATE: 12/26/2024

REVISION 1: DATE

REVISION 2: DATE

DRAWN BY: MBG

SCALE: NTS

SHEET:

02



NOTES:  
1. FOR MOMENT CONNECTION SEE DETAIL "K"  
TABLE "B-1"

1"x2" FASTEN TO COL. (INTERNAL)  
w/(2) #10x1-1/2" SMS, FASTEN TO  
EAVE RAILS ABOVE w/#10 1-1/2" SMS  
24" O.C. AND 6" WITHIN COL.


TABLE "D"		
BEAM	QTY/ SIZE EACH SIDE	
2 x 3	(6)/ #10	
2 x 4	(8)/ #10	
2 x 5	(8)/ #10	
2 x 6	(9)/ #10	
2 x 7	(11)/ #10	
2 x 8	(12)/ #12	
2 x 9	(14)/ #12	
2 x 10	(14)/ #12	

MAINTAIN MIN. OF 5/8" SEPERATION  
FROM EDGE OF BEAM SMS O.C.


DETAIL "E" - UPRIGHT TO BEAM  
CONNECTION SCALE: NTS



DETAIL "D" - ROOF BRACING CONNECTION  
SCALE: NTS



RIBBON FOOTING PER PLAN



MONOLITHIC FOOTING PER PLAN



DETAIL "J" REVEAL  
SCALE: NTS

TABLE "B-2" 2"x4" OR LARGER SELF MATING  
UPRIGHT TO DECK DETAIL SPECIFICATIONS


UPRIGHT SIZE	MIN. NUMBER OF TAPCONS INTO CONCRETE EA. SIDE TYP.	# 12 X 3/4" S.M.S. INTO UPRIGHT EA. SIDE TYP.
2 x 4	(2) 1/4" TAPCON	(2) #12 S.M.S
2 x 5	(2) 1/4" TAPCON	(4) #12 S.M.S
2 x 6	(3) 1/4" TAPCON	(5) #12 S.M.S
2 x 7	(3) 1/4" TAPCON	(6) #12 S.M.S
2 x 8	(4) 1/4" TAPCON	(7) #12 S.M.S
2 x 9	(4) 1/4" TAPCON	(8) #12 S.M.S
2 x 10	(5) 1/4" TAPCON	(9) #12 S.M.S

TABLE "B-2" NOTES


NOTES:  
1. WHERE PAVERS ARE PRESENT USE 3/8" DIA. x  
5'-7" LDT TO PENETRATE UNDERLYING  
CONCRETE FOOTING 2-1/4" (MIN.)  
2. CONTRACTOR MAY UTILIZE EQUIVALENT  
ANCHORS IN LIEU OF TAPCONS  
3. SPACING OF TAPCONS/ MASONRY  
ANCHORS PER MFG.  
1/4" DIA. TAPCON MIN. 2" SPACING  
3/8" DIA. LDT's MIN. 3" SPACING




DETAIL "B" - 2"x4" OR LARGER SELF MATING  
UPRIGHT TO DECK DETAILS SCALE: NTS



DETAIL "F" - DOOR JAMB & HEADER  
CONNECTION SCALE: NTS




DETAIL "C" - GIRT OR PURLIN TO BEAM  
OR POST DETAIL SCALE: NTS




DETAIL "G" - SLOPED PURLIN  
CONNECTION SCALE: NTS

This item has been digitally signed  
and sealed by Richard E. Walker,  
P.E. on the date adjacent to the seal.  
Printed copies of this document are  
not considered signed and sealed  
and the signature must be verified on  
any electronic copies.



Digitally signed  
by Richard E  
Walker  
Date:  
2024.12.26  
13:28:29-05'00'

FLORIDA ENGINEERING LLC  
4161 TAMiami TRAIL, UNIT 101  
PORT CHARLOTTE, FLORIDA 33952  
(941) 391-5980  
FLEng.com  
Orders@FLEng.com



CA CERT. #30782

PROJECT NO. 2435426

CONTRACTOR:  
BRITECH CONSTRUCTION CORP  
517 VINTAGE WAY  
BRANDON FL, 33511

PROJECT ADDRESS:

MALLOY  
11829 SE CR 245  
LULU FL 32061

DESIGN DATE: 12/26/2024

REVISION 1: DATE

REVISION 2: DATE

DRAWN BY: MBG

SCALE: NTS


SHEET:

03




GIRT FASTENED INTERNALLY AT EACH END w/ #10x1.5" EACH SCREW GROOVE. FASTEN TO BEAM w/ 2"x2"x1/8" ANGLE (2) #12 SMS INTO BEAM & (2) #10x1.5 THRU ANGLE INTO GUTTER WHERE NO GIRT IS PRESENT, ATTACH ANGLE DIRECTLY TO GUTTER

1"x5"x2" WIDTH EXTRUDED GUTTER BRACKET (THICKNESS OF LEG @ WOOD SCREW SHALL BE 0.125" MIN., LONG LEG SHALL BE 0.072" MIN.) @ EACH BEAM w/(2) #12x3/4" SMS @ 1" SPACING INTO GUTTER LIP. FOR BEAMS ABOVE 2x8 INSTALL GUTTER BRACE AT MIDPOINT BETWEEN BEAMS & INCLUDE 2" GUTTER BRACE AT EACH BEAM LOCATION.




SIDE VIEW



TOP VIEW

DETAIL "H" BEAM TO GUTTER CONNECTION SCALE: NTS




NOTE F  
INSTALL FASTENERS ALONG PERIMETER OF GUSSET -BEAM JOINT 3/8" MIN. FROM EDGE. FASTENERS MAY BE STAGGERED TO INSURE PROPER QUANTITY PER TABLE B-1

FASTENER PATTERN MAY APPEAR DIFFERENT FROM ILLUSTRATION. MAINTAIN 1/2" SEPARATION BETWEEN FASTENERS. MAINTAIN 3/8" MIN. FASTENER SEPARATION FROM BEAM JOINT OR EDGE OF BEAM LAP. FASTENERS MAY BE EVENLY SPACED AROUND EDGE OF GUSSET WITHIN 3/8" OF BEAM JOINT. FASTENERS MAY BE STAGGERED TO INSURE PROPER QUANTITY PER TABLE B-1



DETAIL "K" GUSSET CONNECTION SCALE: NTS

TABLE B-1		
BEAM SIZE	COL. TO BEAM QTY SMS/ SIDE OF COL.	BEAM TO BEAM QTY SMS/ EA. FACE/SIDE
2 x 4	(8) #10	(13) #10
2 x 5	(8) #10	(13) #10
2 x 6	(11) #10	(13) #10
2 x 7	(15) #10	(15) #10
2 x 8	(13) #12	(15) #12
2 x 9	(21) #12	(21) #12
2 x 10	(23) #12	(22) #12


NOTES:  
1. BEAMS FASTEN TO UPRIGHT PER DETAIL "E" SHT 3  
2. PURLINS FASTEN TO UPRIGHT PER DETAIL "G" SHT 3






DETAIL "H-II" UPRIGHT TO GUTTER CONNECTION SCALE: NTS



DETAIL "L" CORNER CONNECTION SCALE: NTS




DETAIL "I-2" CABLE CONNECTION AT CORNER SCALE: NTS




DETAIL "I-1" CABLE CONNECTION AT FOUNDATION SCALE: NTS

This item has been digitally signed and sealed by Richard E. Walker, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.



Digitally signed  
by Richard E Walker  
Date:  
2024.12.26  
13:28:29-05'00'

FLORIDA ENGINEERING LLC  
4161 TAMiami TRAIL, UNIT 101  
PORT CHARLOTTE, FLORIDA 33952  
(941) 391-5980  
FLEng.com  
Orders@FLEng.com



CA CERT. #30782

PROJECT NO. 2435426

CONTRACTOR:  
BRITCH CONSTRUCTION CORP  
517 VINTAGE WAY  
BRANDON FL, 33511

PROJECT ADDRESS:

MALLOY  
11829 SE CR 245  
LULU FL 32061

DESIGN DATE: 12/26/2024



REVISION 1: DATE

REVISION 2: DATE SHEET:


DRAWN BY: MBG

SCALE: NTS


04



ROOF BEAM TO C.B. W/ 2"x2"x1/8" ANGLE TABLE	
BEAM SIZE	QUANTITY/ SIZE SMS
2X4	(4) #12
2X5	(5) #12
2X6	(5) #12
2X7	(6) #14
2X8	(7) #14
2X9	(8) #14
2X10	(9) #14





This item has been digitally signed and sealed by Richard E. Walker, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.



Digitally signed  
by Richard E  
Walker  
Date:  
2024.12.26  
13:28:29-05'00'

2" FOR SINGLE  
HORIZONTAL BEAM  
4" FOR DOUBLE  
HORIZONTAL  
BEAM OR 4"x4"  
6" FOR TRIPLE  
HORIZONTAL  
BEAM OR 6X6



NOTES:

1. 3x3 POST TO HAVE 3/8" RED HEAD - TRUBOLT WEDGE ANCHORS (STAINLESS STEEL, PROVIDE MINIMUM 2" FROM EDGE OF SLAB AND PROVIDE MINIMUM 2" SPACING TO ANY OTHER CONNECTOR. SEE MFG. NOTES FOR INSTALLATION REQUIREMENTS. THREADED ROD REQUIRES 3" MINIMUM EDGE DISTANCE.
2. WHERE 4x4 POST HAVE 1/2" RED HEAD - TRUBOLT WEDGE ANCHORS (STAINLESS STEEL), PROVIDE MINIMUM 3-3/4" FROM EDGE OF SLAB AND PROVIDE MINIMUM 3-3/4" SPACING TO ANY OTHER CONNECTOR. SEE MFG. NOTES FOR INSTALLATION REQUIREMENTS.
3. WHERE PAVERS ARE PRESENT ANCHOR LENGTH SHALL BE INCREASED BY THICKNESS OF PAVENOT TO EXCEED 2-1/2" FOR PAVENOT THICKNESS MORE THAN 2-1/2" SITE SPECIFIC SPECIFICATIONS SHALL BE REQUIRED. PAVERS SHALL BE BONDED TO UNDERLYING CONCRETE FOUNDATION W/ 2000 PSI GORUT.

**FLORIDA ENGINEERING LLC**  
4161 TAMiami TRAIL, UNIT 101  
PORT CHARLOTTE, FLORIDA 33952  
(941) 391-5980  
FLEng.com  
Orders@FLEng.com

TRACTOR:  
BRITECH CONSTRUCTION CORP  
517 VINTAGE WAY  
BRANDON FL,33511

**SUBJECT ADDRESS:**  
**MALLOY**  
**11829 SE CR 245**  
**LULU FL 32061**

PROJECT NO. 2435426

CA CERT. #30782

DESIGN DATE: 12/26/2024

REVISION 1: DATE

REVISION 2:	DATE	SHEET:
-------------	------	--------

DRAWN BY: MBO

SCALE: NTS

05