

Residential System Sizing Calculation

Summary

Project Title:
Ward Residence

Lake City, FL 32025


5/24/2022

| | | | |
|---|-------------------|---------------------------------------|-------------------|
| Location for weather data: Gainesville, FL - Defaults: Latitude(29.7) Altitude(152 ft.) Temp Range(M) | | | |
| Humidity data: Interior RH (50%) Outdoor wet bulb (77F) Humidity difference(51gr.) | | | |
| Winter design temperature(TMY3 99%) | 30 F | Summer design temperature(TMY3 99%) | 94 F |
| Winter setpoint | 70 F | Summer setpoint | 75 F |
| Winter temperature difference | 40 F | Summer temperature difference | 19 F |
| Total heating load calculation | 35327 Btuh | Total cooling load calculation | 19668 Btuh |
| Submitted heating capacity | % of calc Btuh | Submitted cooling capacity | % of calc Btuh |
| Total (Electric Heat Pump) | 100.2 35400 | Sensible (SHR = 0.85) | 104.2 16839 |
| Heat Pump + Auxiliary(0.0kW) | 100.2 35400 | Latent | 84.5 2972 |
| | | Total (Electric Heat Pump) | 100.7 19811 |

WINTER CALCULATIONS

Winter Heating Load (for 2068 sqft)


| Load component | Load | | |
|------------------------|---------------------|-------------|------------|
| Window total | 205 | sqft | 4510 Btuh |
| Wall total | 2201 | sqft | 6802 Btuh |
| Door total | 80 | sqft | 1472 Btuh |
| Ceiling total | 2068 | sqft | 2833 Btuh |
| Floor total | 2068 | sqft | 14066 Btuh |
| Infiltration | 44 | cfm | 1926 Btuh |
| Duct loss | | | 3719 Btuh |
| Subtotal | 35327 | Btuh | |
| Ventilation | Ex:0 cfm; Sup:0 cfm | | 0 Btuh |
| TOTAL HEAT LOSS | 35327 | Btuh | |



SUMMER CALCULATIONS

Summer Cooling Load (for 2068 sqft)

| Load component | Load | | |
|---------------------------------------|---------------------|-------------|-----------|
| Window total | 205 | sqft | 3826 Btuh |
| Wall total | 2201 | sqft | 3572 Btuh |
| Door total | 80 | sqft | 1104 Btuh |
| Ceiling total | 2068 | sqft | 2266 Btuh |
| Floor total | | | 0 Btuh |
| Infiltration | 33 | cfm | 686 Btuh |
| Internal gain | | | 2120 Btuh |
| Duct gain | | | 2579 Btuh |
| Sens.Ventilation | Ex:0 cfm; Sup:0 cfm | | 0 Btuh |
| Blower Load | | | 0 Btuh |
| Total sensible gain | 16153 | Btuh | |
| Latent gain(ducts) | 1577 | Btuh | |
| Latent gain(infiltration) | 1139 | Btuh | |
| Latent gain(ventilation) | 0 | Btuh | |
| Latent gain(internal/occupants/other) | 800 | Btuh | |
| Total latent gain | 3516 | Btuh | |
| TOTAL HEAT GAIN | 19668 | Btuh | |



8th Edition

EnergyGauge® System Sizing
PREPARED BY: _____
DATE: _____