



---

**Britt Surveying and Mapping, LLC**  
2086 SW Main Blvd Ste 112 • Lake City, FL 32025  
386-752-7163 P • 386-752-5573 F • [www.brittsurvey.com](http://www.brittsurvey.com)

10/25/2021

Permit # 000041943

L-28021

Erkinger Construction

Re: Lot 12 Meadow Wood

To Whom It May Concern:

The top of the finished slab on said Lot 9 is 164.54 feet. The highest adjacent grade is 163.40 feet. The building permit requires the minimum floor to be 149.0 feet or 8 inches above highest adjacent grade. The elevations shown hereon are based on NAVD 88 datum.

Sincerely,



L. Scott Britt  
LS 5757