

#41729 - #70

Notice of Prevention for Subterranean Termites (As required by Florida Building Code (FBC) 104.2.6)

17856 U.S. 129 • McALPIN, FLORIDA 32062
(386) 362-3887 • 1-800-771-3887 • Fax: (386) 364-3529

A locally owned
company serving
you since 1972

Live Oak
PEST CONTROL, INC.

Address of Treatment or Lot/Block of Treatment

260 SW Paisley Court Fort White FL 3203

Date

5/27/21

Time

7:05

Applicator

Tim

Product Used

Termise

Chemical used (active ingredient)

Imidacloprid

Number of gallons applied

153.6

Percent Concentration

1%

Area treated (square feet)

2032

Linear feet treated

~2100

Stage of treatment (Horizontal, Vertical, Adjoining Slab, retreat of disturbed area)

Horizontal, Vertical

As per 104.2.6 - If soil chemical barrier method for Subterranean termite prevention is used, final exterior treatment shall be completed prior to final building approval.
The building has received a complete treatment for the prevention of subterranean termites. Treatment is in accordance with rules & laws established by the Florida Department of Agriculture & Consumer Services. Initial and date this line.

If this notice is for the final exterior treatment initial and date this line.