

37778

NORTH FLORIDA PROFESSIONAL SERVICES, INC.

Experience. Quality. Commitment.



April 2, 2019

Rodney Denham
4974 SW 114 Street Road
Ocala, FL 34476

SUBJECT: ELEVATION LETTER
Parcel No. 16-7S-17-10006-237
733 SW Marynik Drive, High Springs, Florida

To Whom It May Concern:

Parcel No. 16-7S-17-10006-237 is located in Flood Zone X. The property naturally slopes north toward SW Marynik Drive. The structure will be elevated on a concrete pad. Stormwater will flow around the structure to the north.

Requirements For Structure To Be Protected from the Base Flood Event:

The finished floor elevation for the foundation of the structure shall be at 62.5 feet NAVD and above the highest adjacent natural grade at the proposed building site. Any disturbed area around the proposed structure shall be graded to direct all runoff to the north.

Sincerely,

Terry R. White, Jr., P.E.
Water Resources Engineer

Attachment

I certify that the finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 9 of the Land Development Regulation.

Terry R. White, Jr., P.E. Date 4/2/19