

Application #54882 Remodel 825 NE AUSGOOD GLN LAKE CITY, FL 32055

Need:

1. FLOOR PLAN SHOWS BEDROOM WITH NO WINDOW: The center bedroom had one window on the east wall. This window will not be replaced. The other bedrooms have two windows, which will be replaced.
2. METHOD OF CLOSING WINDOWS FRAMING, BLOCK ETC. ? The windows will be closed using the following method. The headings will remain in place, 2x4s will be installed on the top, bottom and each side of the window opening, plywood will be attached to the 2x4s toward the interior of the opening, then bricks will be installed from the plywood toward the exterior closing the opening.