





3rd Feb. 2022

BUILDING OFFICIAL / INSPECTOR
COUNTY BUILDING DEPT.

RE: IC CONST. / SCHEFFLER RESIDENCE

TO WHOM IT MAY CONCERN:

DOUBLE BOTTOM PLATES AT GARAGE DOOR WALLS ARE NOT
REQUIRED FOR THIS PROJECT. PLEASE DISREGARD THE DBL BOTTOM
PLATE NOTES ON DETAIL G, PAGE 3.4.



Nicholas Geisler