



HRCD Consulting LLC

PO Box 2999
Stuart, FL 34995
772-215-8521

March 15th, 2023

ENGINEERING INSPECTION LETTER

Project Location: 1786 SE SR100, Lake City, FL DB22-323-NC

Subject: Inspection of Structural Concrete Footers

To whom it may concern,

On March 7th, 2023, visual inspections along with review of photographic evidence were conducted by our office on the existing residence located at the project above.

On sheet 2 of the Engineered Drawings for the building above, PT Wood Posts were specified to be installed into 24" Diameter x 60" Deep Concrete of 3000 psi or better.

Review of installed conditions and in-progress construction photos were used to determine that the footers meet the plans specifications & the 2020 Florida Building Codes. We hereby deem these footers as adequate and request that the Building Department accept this letter of inspection for the project above.

Please feel free to contact me if you have any questions regarding this letter of inspection.

3-15-2023

Adam L. Hart, P.E.
License # 63079
PO Box 2999, Stuart, FL 34995
772-215-8521

