FLORIDA DEPARTMENT OF
Business & Professional Regulation

Product Approval
USER: Public User

FL #	FL28363-R1
Application Type	Affirmation
Code Version	2020
Application Status	Approved
Comments	
Archived	☐
Product Manufacturer	Deep South Metals LLC
Address/Phone/Email	106 Masters Rd
	East Palatka, FL 32131
	(386) 222-4254
	dsmetalsllc@gmail.com
Authorized Signature	Annette Engel
	dsmetalsllc@gmail.com
Technical Representative	Austin Strickland
Address/Phone/Email	106 Masters Rd
	East Palatka, FL 32131
	(386) 972-4460
	dsmetalroofsupply@gmail.com
Quality Assurance Representative	
Address/Phone/Email	
Category	Roofing
Subcategory	Metal Roofing
Compliance Method	Evaluation Report from a Florida Registered Architect or a Licensed Florida Professional Engineer
	☐ Evaluation Report - Hardcopy Received
Florida Engineer or Architect Name who developed the Evaluation Report	Lucas A. Turner, P.E., MBA
Florida License	PE-58201
Quality Assurance Entity	Architectural Testing, Inc., an Intertek Company
Quality Assurance Contract Expiration Date	12/31/2020
Validated By	Gary Hartman, P.E.
	☐ Validation Checklist - Hardcopy Received
Certificate of Independence	FL28363_R1_COI_EvalReport-SouthRib-Battens.pdf

Referenced Standard and Year (of Standard)	**Standard**	**Year**
	ASTM E1592	2012
	UL 1897	2012

Equivalence of Product Standards Certified By	
Sections from the Code	

☑ I affirm that there are no changes in the new Florida Building

Code which affect my product(s) and my product(s) are in compliance with the new Florida Building Code.

Documentation from approved Evaluation or Validation Entity	○ Yes ○ No ○ N/A

[FL28363_R1_COC_7thEdFBC-FL28363.pdf](#)

Product Approval Method	Method 1 Option D

Date Submitted	11/04/2020
Date Validated	11/04/2020
Date Pending FBC Approval	
Date Approved	11/05/2020

Summary of Products

FL #	Model, Number or Name	Description
28363.1	South Rib	26ga and 29ga 36" panel over 1x4 battens
Limits of Use **Approved for use in HVHZ:** No **Approved for use outside HVHZ:** Yes **Impact Resistant:** N/A **Design Pressure:** +N/A/-45 **Other:** See evaluation report for limits of use.		**Installation Instructions** [FL28363_R1_II_FPA-SouthRibBat.pdf](#) Verified By: Lucas A. Turner PE-58201 Created by Independent Third Party: Yes **Evaluation Reports** [FL28363_R1_AE_EvalReport-SouthRib-Battens.pdf](#) Created by Independent Third Party: Yes
28363.2	South Rib	26ga and 29ga 36" panel over 15/32" plywood
Limits of Use **Approved for use in HVHZ:** No **Approved for use outside HVHZ:** Yes **Impact Resistant:** N/A **Design Pressure:** +N/A/-52.5 **Other:** See evaluation report for limits of use.		**Installation Instructions** [FL28363_R1_II_FPA-SouthRibPly.pdf](#) Verified By: Lucas A. Turner PE-58201 Created by Independent Third Party: Yes **Evaluation Reports** [FL28363_R1_AE_EvalReport-SouthRib-Plywood.pdf](#) Created by Independent Third Party: Yes

[Back] [Next]