



STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM (OSTDS)

PERMIT NO. 24-0417
DATE PAID: 5/17/24
FEE PAID: 205.00
RECEIPT #: 2071532

APPLICATION FOR CONSTRUCTION PERMIT

APPLICATION FOR:

☐ New System
☒ Repair

☐ Existing System
☐ Abandonment

☐ Holding Tank
☐ Temporary

☐ Innovative
☒ Modification

switched to repair

APPLICANT: Ronald Weston

EMAIL: liveoakspoiled@aol.com

AGENT: Suwannee Septic and Site work

TELEPHONE: 239-910-7555

MAILING ADDRESS: 18081 185th Rd Live Oak, FL 32060

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3) (m) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION

OSTDS REMEDIATION PLAN? [Y / ☒]

LOT: _____ BLOCK: _____ SUBDIVISION: _____ PLATTED: Unk

PROPERTY ID #: 23-4S-16-03096-001 ZONING: res I/M OR EQUIVALENT: [☐ / ☒]

PROPERTY SIZE: 1.0 ACRES WATER SUPPLY: [☒] PRIVATE PUBLIC [☐] <=2000GPD [☐] >2000GPD

IS SEWER AVAILABLE AS PER 381.0065, FS? [Y / ☒] DISTANCE TO SEWER: 1000+ FT

PROPERTY ADDRESS: XX SW Tunsil St. Lake City FL 32024

DIRECTIONS TO PROPERTY: Head West on NE Franklin St. Turn left on N. Marion Ave. Turn right on Hwy 90. Turn left on Sisters Welcome Rd. Turn right on SW Tunsil St. Property will be on the right. Long private driveway just after sharp right curve in road.

BUILDING INFORMATION

☒ RESIDENTIAL

☐ COMMERCIAL

Unit No	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table I, Chapter 62-6, FAC
1	<u>Manufactured home</u>	<u>4</u>	<u>1560</u>	<u>New</u>
2	<u>Old home</u>	<u>2</u>	<u>962</u>	<u>To be demolished</u>
3				
4				

[] Floor/Equipment Drains [] Other (Specify) _____

SIGNATURE: Dale Watts DATE: 05/08/2024



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM

PERMIT #: 12-SC-2901708
APPLICATION #: AP2071532
DATE PAID: 5/17/24
FEE PAID: 205.00
RECEIPT #: _____
DOCUMENT #: PR2084355

CONSTRUCTION PERMIT FOR: OSTDS Existing Repair
APPLICANT: RONALD**24-0417 WESTON
PROPERTY ADDRESS: SW TUNSIL Lake City, FL 32024
LOT: _____ BLOCK: _____ SUBDIVISION: _____
PROPERTY ID #: 03096-001 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [1,050] GALLONS / GPD New Multi-Chambered Septic CAPACITY
A [0] GALLONS / GPD _____ CAPACITY
N [0] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]
K [] GALLONS DOSING TANK CAPACITY [] GALLONS @ [] DOSES PER 24 HRS #Pumps []

D [500] SQUARE FEET Drainfield SYSTEM
R [0] SQUARE FEET _____ SYSTEM

A TYPE SYSTEM: [x] STANDARD [] FILLED [] MOUND []
I CONFIGURATION: [x] TRENCH [] BED []

F LOCATION OF BENCHMARK: Nail with orange paint in tree NW of proposed system site

I ELEVATION OF PROPOSED SYSTEM SITE [24.00] [INCHES / FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT

E BOTTOM OF DRAINFIELD TO BE [47.00] [INCHES / FT] [ABOVE / BELOW] BENCHMARK/REFERENCE POINT

D FILL REQUIRED: [0.00] INCHES EXCAVATION REQUIRED: [] INCHES

O The system is sized for 4 bedrooms with a maximum occupancy of 8 persons (2 per bedroom), for a total estimated flow of 400 gpd.
T PSE has requested system be updated to new standards. Minimum requirements are 300sqft of drainfield at 50" below BM
H due to system original installation in 1956.

SPECIFICATIONS BY: Matthew Baker TITLE: OSTDS Private Inspector; Private Site

APPROVED BY: Sean P Havens TITLE: Environmental Specialist I Columbia CHD

DATE ISSUED: 05/20/2024 EXPIRATION DATE: 08/18/2024

DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)
Incorporated 62-6.004, FAC

KK

24-0417

Ronald Weston
XX SW Tunsil St
Lake City, FL 32024
23-45-16-03102-000

Home w/
Septic &
well

Neighbors
, well

Dirt
driveway

4
N
1"=30'

210'

old
home

old system

Bm

1-2%
slope

5162

Proposed
500 sq ft
drainfield

Proposed
1050 gallon tank

4 Bd
MH

210'

well

210'

All offsite features
within 75'

Dale Wata
5/10/24

ES2
Columbia 5/20/24