

COLUMBIA COUNTY INSPECTION SHEET

APPLICATION # 36566

DATE: 5/2/2018 TAKEN BY _____ INSPECTION DATE: 5/7/2018

BUILDING PERMIT # 000036289 CULVERT/WAIVER PERMIT # 000002538 WAIVER N

PARCEL ID: 21-4S-16-03081-213 ZONING _____

TYPE OF DEVELOPMENT Culvert

SETBACKS FRONT _____ REAR _____ SIDE _____ HEIGHT _____

FLOOD ZONE _____ SEPTIC _____ NO. EXISTING D.U. _____

SUBDIVISION WINGATE ESTATES Lot 13 Block _____ Unit _____ Phase _____

OWNER M. FOREST BUTLER PHONE 770.639.3904

ADDRESS 312 SW GRANITE CT
LAKE CITY FL 32024

CONTRACTOR MARK BAUER PHONE _____

LOCATION 90-W TOSR. 247-S, TL TO C-242, TL TO GRANITE, TL AND IT'S STRAIGHT AHEAD TOWARDS CUL-DE-SAC ON L.

COMMENTS

INSTALL MIN 24'X18" CORR METAL CULVERT W/CONCRETE MITERED
ENDS W/6"X6" WELDED WIRE, REBAR OR CULVERT BOLTS.
DAVID MCCORMICK

SPECIAL INSTRUCTIONS

PRIOR INSPECTIONS

<u>Inspection</u>	<u>By</u>
Driveway Opening Inspection	DM

<u>Date</u>
02/14/2018

REQUESTED INSPECTIONS

<u>Date</u>	<u>Inspection Request</u>
05/07/2018	Engineering/Final Driveway

David McCormick

INSPECTORS

APPROVED _____ NOT APROVED _____ BY _____ POWER CO _____

Phone: 3522832002 Fax: _____

0580 5-8-18