

CAROL CHADWICK, P.E.

Civil Engineer

1208 S.W. Fairfax Glen

Lake City, FL 32025

307.680.1772

ccpewyo@gmail.com

www.carolchadwickpe.com

July 8, 2022

Troy Crews

Columbia County Building and Zoning

386.758.1040

troy_crews@columbiacountyfla.com

re: ELEVATION LETTER – Lake City Self Storage

As requested, I reviewed the finished slab elevation at the above referenced site. Per the letter by Britt Surveying and Mapping dated May 20, 2022, the finished slab elevation of the south building is 189.20 and the finished slab elevation of the two northern buildings is 188.76. The finished slab elevations are sufficient to protect the building against water damage.

I certify that the finished slab elevations listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Should you have any questions, please don't hesitate to contact me.

Respectfully,



Digitally signed by
Carol Chadwick
DN: c=US,
o=Florida,
dnQualifier=A01410
D0000017EB6D924
CE0005954C,
cn=Carol Chadwick
Date: 2022.07.08 09:05:55 -04'00'

Carol Chadwick, P.E.

Attachment: Elevation Letter by Britt Surveying and Mapping dated May 20, 2022