

March 4, 2021

Precision Alignment
8480 SW CR 232
Trenton, FL 32693

Subject: Permit # 40434 – Parcel # 05080-000

Dear Chuck:

Daniel & Gore, LLC has performed a vertical survey on Parcel # 05080-000, Columbia County, Florida from a benchmark being a concrete monument, FDOT 2904003 BM 5 on the East property line (elevation – 168.08', NAVD 1988) and have determined the following:

- The Construction Plans by Gmuer Engineering requires the finish floor elevation of the proposed building to be 172.50'.
- The finish floor elevation of the building is at 172.51', being 0.01' above the finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM

