



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM
APPLICATION FOR CONSTRUCTION PERMIT

PERMIT NO. 22-0276
DATE PAID: 4/1/22
FEE PAID: 310.00
RECEIPT #: 1814791

APPLICATION FOR:

☒ New System ☐ Existing System ☐ Holding Tank ☐ Innovative
☐ Repair ☐ Abandonment ☐ Temporary ☐

APPLICANT: Hilario Salmeron

AGENT: Jeff Hardee

TELEPHONE: 352-949-0592

MAILING ADDRESS: 6450 NW 72 Ln Chiefland FL 32626

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3) (m) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION

LOT: 39 BLOCK: SUBDIVISION: Bicentennial Acres PLATTED:

PROPERTY ID #: 11-7-17-09983-034 ZONING: I/M OR EQUIVALENT: ☐ No ☒

PROPERTY SIZE: 5.05 ACRES WATER SUPPLY: ☒ PRIVATE PUBLIC ☐ ≤ 2000 GPD ☐ > 2000 GPD

IS SEWER AVAILABLE AS PER 381.0065, FS? ☐ No ☒ DISTANCE TO SEWER: NA FT

PROPERTY ADDRESS: 274 SE Jefferson GLN High Springs

DIRECTIONS TO PROPERTY: Hwy 41 South TL on Adams TR Browley TL on Jefferson GLN to lot on right.

BUILDING INFORMATION

☒ RESIDENTIAL ☐ COMMERCIAL

Unit No	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table 1, Chapter 64E-6, FAC
1	SFR	5	2022	
2				
3				
4				

☐ Floor/Equipment Drains ☐ Other (Specify)

SIGNATURE: John H. L.

DATE: 3-30-22



STATE OF FLORIDA
DEPARTMENT OF HEALTH
ONSITE SEWAGE TREATMENT AND DISPOSAL
SYSTEM

PERMIT #: 12-SC-2483681
APPLICATION #: AP1814791
DATE PAID: 4/1/23
FEE PAID: 310.25
RECEIPT #:
DOCUMENT #: PR1749315

CONSTRUCTION PERMIT FOR: OSTDS New
APPLICANT: HILARIO**22-0276 SALMERON
PROPERTY ADDRESS: 274 SE JEFFERSON High Springs, FL 32643
LOT: 39 BLOCK: SUBDIVISION:
PROPERTY ID #: 09983-034 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [1,200] GALLONS / GPD Septic Tank CAPACITY
A [] GALLONS / GPD N/A CAPACITY
N [] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]
K [] GALLONS DOSING TANK CAPACITY [] GALLONS @ [] DOSES PER 24 HRS #Pumps []

D [575] SQUARE FEET Drainfield SYSTEM
R [] SQUARE FEET N/A SYSTEM
A TYPE SYSTEM: [X] STANDARD [] FILLED [] MOUND []
I CONFIGURATION: [X] TRENCH [] BED []

F LOCATION OF BENCHMARK: Nail in tree SW of site.

I ELEVATION OF PROPOSED SYSTEM SITE [30.00] [INCHES] FT [] ABOVE / BELOW BENCHMARK/REFERENCE POINT
E BOTTOM OF DRAINFIELD TO BE [60.00] [INCHES] FT [] ABOVE / BELOW BENCHMARK/REFERENCE POINT

L
D FILL REQUIRED: [0.00] INCHES EXCAVATION REQUIRED: [0.00] INCHES

O The system is sized for 5 bedrooms with a maximum occupancy of 10 persons (2 per bedroom), for a total estimated flow of 460 gpd.

SPECIFICATIONS BY: Jeff Arledge TITLE: CEH

APPROVED BY: Dustin W. Jones TITLE: Environmental Specialist II Columbia CHD

DATE ISSUED: 04/13/2022 EXPIRATION DATE: 10/13/2023

DH 4016, 08/09 (Obsoletes all previous editions which may not be used)

Incorporated: 64E-6.003, FAC

STATE OF FLORIDA
DEPARTMENT OF HEALTH
APPLICATION FOR CONSTRUCTION PERMIT

Permit Application Number

22-0276

Salmon


1" = 100'

PART II - SITEPLAN

50' Bld



N



Notes:

Rock Boulder on lot - Remove if encounter

Site Plan submitted by:

Plan Approved

By

Not Approved

Columbia CHD

Date

County Health Department

ALL CHANGES MUST BE APPROVED BY THE COUNTY HEALTH DEPARTMENT