

D
G Daniel & Gore, LLC
Professional Surveying and Mapping

P.O. Box 1501
Lake City, Florida 32056

June 3, 2020

Aaron Simque Homes
333 SW Rosemary Drive
Lake City, FL 32025

Subject: Permit # 37867 - Lot 10, Preserve at Laurel Lake, Unit 1

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lot 10, Preserve at Laurel Lake, Unit 1, Columbia County, Florida from a benchmark being a 60d nail at the common lot line between Lots 8 & 9 (elevation – 116.12', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 116.4'.
- The finish floor elevation of the residence is at 117.6', being 1.2' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,

Scott Daniel, PSM

Scott Daniel, PSM • Cell: (386) 208-4176 • E-mail: sdaniel@dgsurveying.com

David Gore • Cell: (386) 365-0298 • E-mail: dgore@dgsurveying.com

Ph: (386) 752-9019 Fax: (904) 339-9229