

FLORIDA ENERGY EFFICIENCY CODE FOR BUILDING CONSTRUCTION

Florida Department of Business and Professional Regulation - Residential Performance Method

Project Name: Smith Residence
 Street: 530 SW Tiny Gln
 City, State, Zip: Lake City, FL, 32024-
 Owner: Smith
 Design Location: FL, Gainesville

Builder Name: Little and Williams, Inc.
 Permit Office:
 Permit Number:
 Jurisdiction:

1. New construction or existing	New (From Plans)	
2. Single family or multiple family	Single-family	
3. Number of units, if multiple family	1	
4. Number of Bedrooms	3	
5. Is this a worst case?	No	
6. Conditioned floor area above grade (ft ²)	1556	
Conditioned floor area below grade (ft ²)	0	
7. Windows(133.0 sqft.)	Description	Area
a. U-Factor:	DbI, U=0.45	133.00 ft ²
SHGC:	SHGC=0.31	
b. U-Factor:	N/A	ft ²
SHGC:		
c. U-Factor:	N/A	ft ²
SHGC:		
d. U-Factor:	N/A	ft ²
SHGC:		
Area Weighted Average Overhang Depth:		2.962 ft.
Area Weighted Average SHGC:		0.310
8. Floor Types (1556.0 sqft.)	Insulation	Area
a. Slab-On-Grade Edge Insulation	R=0.0	1556.00 ft ²
b. N/A	R=	ft ²
c. N/A	R=	ft ²

9. Wall Types(1310.0 sqft.)	Insulation	Area
a. Frame - Wood, Exterior	R=13.0	1310.00 ft ²
b. N/A	R=	ft ²
c. N/A	R=	ft ²
d. N/A	R=	ft ²
10. Ceiling Types (1556.0 sqft.)	Insulation	Area
a. Under Attic (Vented)	R=30.0	1556.00 ft ²
b. N/A	R=	ft ²
c. N/A	R=	ft ²
11. Ducts		R ft ²
a. Sup: Attic, Ret: Attic, AH: Main		6 311.2
12. Cooling systems	kBtu/hr	Efficiency
a. Central Unit	35.0	SEER:13.00
13. Heating systems	kBtu/hr	Efficiency
a. Electric Heat Pump	33.6	HSPF:8.00
14. Hot water systems		
a. Electric		Cap: 50 gallons
		EF: 0.960
b. Conservation features		
None		
15. Credits		CF, Pstat

Glass/Floor Area: 0.085

Total Proposed Modified Loads: 28.99
 Total Standard Reference Loads: 36.38

PASS

I hereby certify that the plans and specifications covered by this calculation are in compliance with the Florida Energy Code.

PREPARED BY: [Signature]DATE: 5/15/13

I hereby certify that this building, as designed, is in compliance with the Florida Energy Code.

OWNER/AGENT: _____

DATE: _____

Review of the plans and specifications covered by this calculation indicates compliance with the Florida Energy Code. Before construction is completed this building will be inspected for compliance with Section 553.908 Florida Statutes.




BUILDING OFFICIAL: _____

DATE: _____

- Compliance requires completion of a Florida Air Barrier and Insulation Inspection Checklist

Ronald E. Miller, Jr.
 Certified Commercial Energy Rater #960



PROJECT

Title: Smith Residence	Bedrooms: 3	Address Type: Street Address
Building Type: User	Conditioned Area: 1556	Lot #
Owner: Smith	Total Stories: 1	Block/SubDivision:
# of Units: 1	Worst Case: No	PlatBook:
Builder Name: Little and Williams, Inc.	Rotate Angle: 0	Street: 530 SW Tiny Gln
Permit Office:	Cross Ventilation:	County: Columbia
Jurisdiction:	Whole House Fan:	City, State, Zip: Lake City , FL , 32024-
Family Type: Single-family		
New/Existing: New (From Plans)		
Comment:		

CLIMATE

✓	Design Location	TMY Site	IECC Zone	Design Temp 97.5 %	Design Temp 2.5 %	Int Design Temp Winter	Int Design Temp Summer	Heating Degree Days	Design Moisture	Daily Temp Range
✓	FL, Gainesville	FL_GAINESVILLE_REGI	2	32	92	70	75	1305.5	51	Medium

BLOCKS

Number	Name	Area	Volume
1	Block1	1556	12448

SPACES

Number	Name	Area	Volume	Kitchen	Occupants	Bedrooms	Infil ID	Finished	Cooled	Heated
1	Main	1556	12448	Yes	3	3	1	Yes	Yes	Yes

FLOORS

✓	#	Floor Type	Space	Perimeter	R-Value	Area	Tile	Wood	Carpet
✓	1	Slab-On-Grade Edge Insulatio	Main	163.75 ft	0	1556 ft²	----	0	0 1

ROOF

✓	#	Type	Materials	Roof Area	Gable Area	Roof Color	Solar Absor.	SA Tested	Emitt	Emitt Tested	Deck Insul.	Pitch (deg)
✓	1	Gable or shed	Composition shingles	1740 ft²	390 ft²	Dark	0.96	No	0.9	No	0	26.6

ATTIC

✓	#	Type	Ventilation	Vent Ratio (1 in)	Area	RBS	IRCC
✓	1	Full attic	Vented	300	1556 ft²	N	N

CEILING

✓	#	Ceiling Type	Space	R-Value	Area	Framing Frac	Truss Type
✓	1	Under Attic (Vented)	Main	30	1556 ft²	0.11	Wood

WALLS

✓ #	Ornt	Adjacent To	Wall Type	Space	Cavity R-Value	Width Ft	In	Height Ft	In	Area	Sheathing R-Value	Framing Fraction	Solar Absor	Below Grade%
✓ 1	N	Exterior	Frame - Wood	Main	13	30		8		240 ft²		0.23	0.75	0
✓ 2	E	Exterior	Frame - Wood	Main	13	51	10.5	8		415 ft²		0.23	0.75	0
✓ 3	S	Exterior	Frame - Wood	Main	13	30		8		240 ft²		0.23	0.75	0
✓ 4	W	Exterior	Frame - Wood	Main	13	51	10.5	8		415 ft²		0.23	0.75	0

DOORS

✓ #	Ornt	Door Type	Space	Storms	U-Value	Width Ft	In	Height Ft	In	Area
✓ 1	E	Insulated	Main	None	0.460000	3		6	8	20 ft²
✓ 2	W	Insulated	Main	None	0.460000	3		6	8	17.77777
✓ 3	W	Insulated	Main	None	0.460000	3		6	8	20 ft²

WINDOWS

Orientation shown is the entered, Proposed orientation.

✓ #	Ornt	Wall ID	Frame	Panes	NFRC	U-Factor	SHGC	Area	Overhang Depth	Separation	Int Shade	Screening
✓ 1	N	1	Vinyl	Low-E Double	Yes	0.45	0.31	10 ft²	1 ft 0 in	4 ft 0 in	Drapes/blinds	None
✓ 2	W	4	Vinyl	Low-E Double	Yes	0.45	0.31	15 ft²	10 ft 0 in	1 ft 0 in	Drapes/blinds	None
✓ 3	W	4	Vinyl	Low-E Double	Yes	0.45	0.31	10 ft²	10 ft 0 in	1 ft 0 in	Drapes/blinds	None
✓ 4	W	4	Vinyl	Low-E Double	Yes	0.45	0.31	4 ft²	10 ft 0 in	1 ft 0 in	Drapes/blinds	None
✓ 5	S	3	Vinyl	Low-E Double	Yes	0.45	0.31	9 ft²	1 ft 0 in	4 ft 0 in	Drapes/blinds	None
✓ 6	S	3	Vinyl	Low-E Double	Yes	0.45	0.31	20 ft²	1 ft 0 in	4 ft 0 in	Drapes/blinds	None
✓ 7	E	2	Vinyl	Low-E Double	Yes	0.45	0.31	20 ft²	1 ft 0 in	1 ft 0 in	Drapes/blinds	None
✓ 8	E	2	Vinyl	Low-E Double	Yes	0.45	0.31	30 ft²	1 ft 0 in	1 ft 0 in	Drapes/blinds	None
✓ 9	N	1	Vinyl	Low-E Double	Yes	0.45	0.31	15 ft²	1 ft 0 in	1 ft 0 in	Drapes/blinds	None

INFILTRATION

#	Scope	Method	SLA	CFM 50	ELA	EqLA	ACH	ACH 50
1	Wholehouse	Best Guess	0.000500	2040.7	112.03	210.69	0.3850	9.8363

HEATING SYSTEM

✓ #	System Type	Subtype	Efficiency	Capacity	Block	Ducts
✓ 1	Electric Heat Pump	SPVHP(COP)	HSPF: 8	33.6 kBtu/hr	1	sys#1

COOLING SYSTEM

✓ #	System Type	Subtype	Efficiency	Capacity	Air Flow	SHR	Block	Ducts
✓ 1	Central Unit	Split	SEER: 13	35 kBtu/hr	1050 cfm	0.75	1	sys#1

HOT WATER SYSTEM

✓	#	System Type	SubType	Location	EF	Cap	Use	SetPnt	Conservation
✓	1	Electric	None	Main	0.96	50 gal	60 gal	120 deg	None

SOLAR HOT WATER SYSTEM

✓	FSEC Cert #	Company Name	System Model #	Collector Model #	Collector Area	Storage Volume	FEF
✓	None	None			ft²		

DUCTS

✓	#	Location	--- Supply --- R-Value Area	--- Return --- Location Area	Leakage Type	Air Handler CFM 25	Percent Leakage QN	RLF	HVAC # Heat Cool
✓	1	Attic	6 311.2 ft	Attic 77.8 ft²	Default Leakage	Main (Default)	(Default) %		1 1

TEMPERATURES

Programable Thermostat: Y

Ceiling Fans:

Cooling	☐ Jan	☐ Feb	☐ Mar	☐ Apr	☐ May	☒ Jun	☒ Jul	☒ Aug	☒ Sep	☐ Oct	☒ Nov	☒ Dec
Heating	☒ Jan	☒ Feb	☒ Mar	☒ Apr	☐ May	☐ Jun	☐ Jul	☐ Aug	☐ Sep	☒ Oct	☐ Nov	☐ Dec
Venting	☐ Jan	☐ Feb	☐ Mar	☐ Apr	☐ May	☐ Jun	☐ Jul	☐ Aug	☐ Sep	☐ Oct	☐ Nov	☐ Dec

Thermostat Schedule: HERS 2006 Reference

Schedule Type		1	2	3	4	5	6	7	8	9	10	11	12
Cooling (WD)	AM	78	78	78	78	78	78	78	78	80	80	80	80
	PM	80	80	78	78	78	78	78	78	78	78	78	78
Cooling (WEH)	AM	78	78	78	78	78	78	78	78	78	78	78	78
	PM	78	78	78	78	78	78	78	78	78	78	78	78
Heating (WD)	AM	66	66	66	66	66	68	68	68	68	68	68	68
	PM	68	68	68	68	68	68	68	68	68	68	66	66
Heating (WEH)	AM	66	66	66	66	66	68	68	68	68	68	68	68
	PM	68	68	68	68	68	68	68	68	68	68	66	66

Florida Code Compliance Checklist

Florida Department of Business and Professional Regulations
Residential Whole Building Performance Method

ADDRESS: 530 SW Tiny Gln
Lake City, FL, 32024-

PERMIT #:

MANDATORY REQUIREMENTS SUMMARY - See individual code sections for full details.

COMPONENT	SECTION	SUMMARY OF REQUIREMENT(S)	CHECK
Air leakage	402.4	To be caulked, gasketed, weatherstripped or otherwise sealed. Recessed lighting IC-rated as meeting ASTM E 283. Windows and doors = 0.30 cfm/sq.ft. Testing or visual inspection required. Fireplaces: gasketed doors & outdoor combustion air. Must complete envelope leakage report or visually verify Table 402.4.2.	☒
Thermostat & controls	403.1	At least one thermostat shall be provided for each separate heating and cooling system. Where forced-air furnace is primary system, programmable thermostat is required. Heat pumps with supplemental electric heat must prevent supplemental heat when compressor can meet the load.	☒
Ducts	403.2.2	All ducts, air handlers, filter boxes and building cavities which form the primary air containment passageways for air distribution systems shall be considered ducts or plenum chambers, shall be constructed and sealed in accordance with Section 503.2.7.2 of this code.	☒
	403.3.3	Building framing cavities shall not be used as supply ducts.	☒
Water heaters	403.4	Heat trap required for vertical pipe risers. Comply with efficiencies in Table 403.4.3.2. Provide switch or clearly marked circuit breaker (electric) or shutoff (gas). Circulating system pipes insulated to = R-2 + accessible manual OFF switch.	☒
Mechanical ventilation	403.5	Homes designed to operate at positive pressure or with mechanical ventilation systems shall not exceed the minimum ASHRAE 62 level. No make-up air from attics, crawlspaces, garages or outdoors adjacent to pools or spas.	☒
Swimming Pools & Spas	403.9	Pool pumps and pool pump motors with a total horsepower (HP) of = 1 HP shall have the capability of operating at two or more speeds. Spas and heated pools must have vapor-retardant covers or a liquid cover or other means proven to reduce heat loss except if 70% of heat from site-recovered energy. Off/timer switch required. Gas heaters minimum thermal efficiency=78% (82% after 4/16/13). Heat pump pool heaters minimum COP= 4.0.	N/A
Cooling/heating equipment	403.6	Sizing calculation performed & attached. Minimum efficiencies per Tables 503.2.3. Equipment efficiency verification required. Special occasion cooling or heating capacity requires separate system or variable capacity system. Electric heat >10kW must be divided into two or more stages.	☒
Ceilings/knee walls	405.2.1	R-19 space permitting.	☒



Load Short Form
Entire House
Dependable Heating and Air

Job: 13-025-01
Date: May 15, 2013
By: Ron Miller

Project Information

For: Smith Residence
530 SW Tiny Glenn, Lake City, FL 32024

Design Information

	Htg	Clg	Infiltration	
Outside db (°F)	33	92	Method	Simplified
Inside db (°F)	70	75	Construction quality	Average
Design TD (°F)	37	17	Fireplaces	0
Daily range	-	M		
Inside humidity (%)	30	50		
Moisture difference (gr/lb)	11	52		

HEATING EQUIPMENT

Make Goodman Mfg.
Trade GOODMAN, JANITROL, AMANA DISTI...
Model GSH130361B*
AHRI ref 4692017

Efficiency 7.7 HSPF
Heating input
Heating output 31400 Btuh @ 47°F
Temperature rise 25 °F
Actual air flow 1127 cfm
Air flow factor 0.071 cfm/Btuh
Static pressure 0 in H2O
Space thermostat

COOLING EQUIPMENT

Make Goodman Mfg.
Trade GOODMAN, JANITROL, AMANA DISTI...
Cond GSH130361B*
Coil AR*F374316B*
AHRI ref 4692017

Efficiency 11.0 EER, 13 SEER
Sensible cooling 23660 Btuh
Latent cooling 10140 Btuh
Total cooling 33800 Btuh
Actual air flow 1127 cfm
Air flow factor 0.053 cfm/Btuh
Static pressure 0 in H2O
Load sensible heat ratio 0.85

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Master Bedroom	221	2718	3587	193	192
Master Bath/CL	185	2094	1439	149	77
Great Room	284	2456	4696	174	251
Kitchen/Dining	281	1976	3993	140	213
Guest Bath	101	1333	704	95	38
Bedroom 2	156	1909	2589	136	138
Hall Closet	20	256	136	18	7
Bedroom 3	156	2084	2637	148	141
Utility	81	966	1221	69	65
Hallway	52	77	98	5	5

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2012 12.0.13 RSU17328

...ng Solutions\2013\Dependable H and A\Smith Residence\smithrup Calc = MJ8 Front Door faces:

2013-May-15 14:46:02

Page 1

Entire House	d	1538	15870	21100	1127	1127
Other equip loads			0	0		
Equip. @ 0.97 RSM				20467		
Latent cooling				3779		
TOTALS		1538	15870	24246	1127	1127

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Loads for Multiple Orientations
Entire House
Dependable Heating and Air

Job: 13-025-01
Date: May 15, 2013
By: Ron Miller

Project Information


For: Smith Residence
530 SW Tiny Glenn, Lake City, FL 32024

Design Conditions

Location:		Indoor:		Heating	Cooling
Gainesville, FL, US		Indoor temperature (°F)		70	75
Elevation: 151 ft		Design TD (°F)		37	17
Latitude: 30°N		Relative humidity (%)		30	50
		Moisture difference (gr/lb)		10.6	52.0
Outdoor:	Heating	Cooling	Infiltration:		
Dry bulb (°F)	33	92			
Daily range (°F)	-	19 (M)			
Wet bulb (°F)	-	77			
Wind speed (mph)	15.0	7.5			

Front Door	North	Northeast	East	Southeast	South	Southwest	West	Northwest
Sensible Load (Btuh)	20467	20467	20467	20467	20467	20467	20467	20467
Latent Load (Btuh)	3779	3779	3779	3779	3779	3779	3779	3779
Total Load (Btuh)	24246	24246	24246	24246	24246	24246	24246	24246
Heating AVF (cfm)	1127	1127	1127	1127	1127	1127	1127	1127
Cooling AVF (cfm)	1127	1127	1127	1127	1127	1127	1127	1127

Building Orientation Cooling Load



Current Orientation: Front Door faces East
Highest Cooling Load: Front Door faces North

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2012 12.0.13 RSU17328

...ng Solutions\2013\Dependable H and A\Smith Residence\smith.rup Calc = MJ8 Front Door faces:

2013-May-15 14:46:02

Page 1

Project Information


For: Smith Residence
 530 SW Tiny Glenn, Lake City, FL 32024

Design Conditions

Location:		Indoor:		Heating	Cooling
Gainesville, FL, US		Indoor temperature (°F)		70	75
Elevation: 151 ft		Design TD (°F)		37	17
Latitude: 30°N		Relative humidity (%)		30	50
		Moisture difference (gr/lb)		10.6	52.0
Outdoor:		Infiltration:			
Dry bulb (°F)		Method		Simplified	
Daily range (°F)		Construction quality		Average	
Wet bulb (°F)		Fireplaces		0	
Wind speed (mph)					


Heating

Component	Btuh/ft²	Btuh	% of load
Walls	3.4	4057	25.6
Glazing	17.4	2678	16.9
Doors	22.2	932	5.9
Ceilings	1.2	1821	11.5
Floors	0	0	0
Infiltration	2.3	3264	20.6
Ducts		3117	19.6
Piping		0	0
Humidification		0	0
Ventilation		0	0
Adjustments		0	0
Total		15870	100.0



Cooling

Component	Btuh/ft²	Btuh	% of load
Walls	2.2	2648	12.6
Glazing	30.6	4705	22.3
Doors	17.5	735	3.5
Ceilings	1.7	2591	12.3
Floors	0	0	0
Infiltration	0.6	789	3.7
Ducts		4022	19.1
Ventilation		0	0
Internal gains		5610	26.6
Blower		0	0
Adjustments		0	0
Total		21100	100.0



Latent Cooling Load = 3779 Btuh
 Overall U-value = 0.057 Btuh/ft²·°F

Data entries checked.

Project Information

For: Smith Residence
530 SW Tiny Glenn, Lake City, FL 32024

Design Conditions

Location:				Indoor:		Heating	Cooling
Gainesville, FL, US				Indoor temperature (°F)		70	75
Elevation: 151 ft				Design TD (°F)		37	17
Latitude: 30°N				Relative humidity (%)		30	50
				Moisture difference (gr/lb)		10.6	52.0
Outdoor:	Heating	Cooling		Infiltration:			
Dry bulb (°F)	33	92		Method	Simplified		
Daily range (°F)	-	19 (M)		Construction quality	Average		
Wet bulb (°F)	-	77		Fireplaces	0		
Wind speed (mph)	15.0	7.5					

Construction descriptions

	Or	Area ft²	U-value Btu/ft²·°F	Insul R ft²·°F/Btu	Htg HTM Btu/ft²	Loss Btu	Clg HTM Btu/ft²	Gain Btu
Walls								
12C-0sw: Frm wall, vnl ext, 1/2" wood shth, r-13 cav ins, 1/2" gypsum board int fnsh, 2"x4" wood frm	n	334	0.091	13.0	3.37	1125	2.20	734
	e	329	0.091	13.0	3.37	1108	2.20	723
	s	219	0.091	13.0	3.37	737	2.20	481
	w	323	0.091	13.0	3.37	1088	2.20	710
	all	1205	0.091	13.0	3.37	4057	2.20	2648
Partitions (none)								
Windows								
4A3-2ow: 2 glazing, clr low-e outr, argon gas, wd frm mat, clr innr, 1/4" gap, 1/8" thk	n	10	0.470	0	17.4	174	16.5	165
4A3-2ov: 2 glazing, clr low-e outr, argon gas, vnl frm mat, clr innr, 1/4" gap, 1/8" thk; 1 ft overhang (5 ft window ht, 1 ft sep.)	e	65	0.470	0	17.4	1130	47.3	3077
4A3-2ov: 2 glazing, clr low-e outr, argon gas, vnl frm mat, clr innr, 1/4" gap, 1/8" thk; NFRC rated (SHGC=0.41); 1 ft overhang (5 ft window ht, 4 ft sep.)	s	29	0.470	0	17.4	504	18.5	536
4A3-2ov: 2 glazing, clr low-e outr, argon gas, vnl frm mat, clr innr, 1/4" gap, 1/8" thk; 10 ft overhang (5 ft window ht, 1 ft sep.)	w	46	0.470	0	17.4	800	16.5	760
4A3-2ov: 2 glazing, clr low-e outr, argon gas, vnl frm mat, clr innr, 1/4" gap, 1/8" thk; NFRC rated (SHGC=0.41); 50% drapes, loose/dark; 1 ft overhang (2 ft window ht, 1 ft sep.)	w	4	0.470	0	17.4	70	41.7	167
Doors								
11J0: Door, mtl fbrgl type	e	21	0.600	6.3	22.2	466	17.5	367
	w	21	0.600	6.3	22.2	466	17.5	367
	all	42	0.600	6.3	22.2	932	17.5	735
Ceilings								
16B-30ad: Attic ceiling, asphalt shingles roof mat, r-30 ceil ins, 1/2" gypsum board int fnsh		1538	0.032	30.0	1.18	1821	1.68	2591

Floors
(none)



wrightsoft®

Right-Suite® Universal 2012 12.0.13 RSU17328

2013-May-15 14:46:03

Page 2

...ng Solutions\2013\Dependable H and A\Smith Residence\smith.rup Calc = MJ8 Front Door faces:



Project Summary
Entire House
Dependable Heating and Air

Job: 13-025-01
Date: May 15, 2013
By: Ron Miller

Project Information

For: Smith Residence
530 SW Tiny Glenn, Lake City, FL 32024

Notes:

Design Information

Weather: Gainesville, FL, US

Winter Design Conditions

Outside db	33 °F
Inside db	70 °F
Design TD	37 °F

Summer Design Conditions

Outside db	92 °F
Inside db	75 °F
Design TD	17 °F
Daily range	M
Relative humidity	50 %
Moisture difference	52 gr/lb

Heating Summary

Structure	12753 Btuh
Ducts	3117 Btuh
Central vent (0 cfm)	0 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	15870 Btuh

Sensible Cooling Equipment Load Sizing

Structure	17078 Btuh
Ducts	4022 Btuh
Central vent (0 cfm)	0 Btuh
Blower	0 Btuh
Use manufacturer's data	n
Rate/swing multiplier	0.97
Equipment sensible load	20467 Btuh

Infiltration

Method	Simplified
Construction quality	Average
Fireplaces	0

Latent Cooling Equipment Load Sizing

Structure	2892 Btuh
Ducts	887 Btuh
Central vent (0 cfm)	0 Btuh
Equipment latent load	3779 Btuh
Equipment total load	24246 Btuh
Req. total capacity at 0.70 SHR	2.4 ton

	Heating	Cooling
Area (ft ²)	1538	1538
Volume (ft ³)	12731	12731
Air changes/hour	0.38	0.20
Equiv. AVF (cfm)	81	42

Heating Equipment Summary

Make	Goodman Mfg.
Trade	GOODMAN, JANITROL, AMANA DISTI...
Model	GSH130361B*
AHRI ref	4692017

Efficiency	7.7 HSPF
Heating input	
Heating output	31400 Btuh @ 47°F
Temperature rise	25 °F
Actual air flow	1127 cfm
Air flow factor	0.071 cfm/Btuh
Static pressure	0 in H2O
Space thermostat	

Cooling Equipment Summary

Make	Goodman Mfg.
Trade	GOODMAN, JANITROL, AMANA DISTI...
Cond	GSH130361B*
Coil	AR*F374316B*
AHRI ref	4692017
Efficiency	11.0 EER, 13 SEER
Sensible cooling	23660 Btuh
Latent cooling	10140 Btuh
Total cooling	33800 Btuh
Actual air flow	1127 cfm
Air flow factor	0.053 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0.85

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



wrightsoft

Right-Suite® Universal 2012 12.0.13 RSU17328

...ng Solutions\2013\Dependable H and A\Smith Residence\smith.rup Calc = MJ8 Front Door faces:

2013-May-15 14:46:03

Page 1



AED Assessment
Entire House
Dependable Heating and Air

Job: 13-025-01
Date: May 15, 2013
By: Ron Miller

Project Information


For: Smith Residence
530 SW Tiny Glenn, Lake City, FL 32024

Design Conditions

Location:		Indoor:		Heating	Cooling
Gainesville, FL, US		Indoor temperature (°F)		70	75
Elevation: 151 ft		Design TD (°F)		37	17
Latitude: 30°N		Relative humidity (%)		30	50
Outdoor:		Moisture difference (gr/lb)		10.6	52.0
		Heating	Cooling	Infiltration:	
Dry bulb (°F)		33	92		
Daily range (°F)		-	19 (M)		
Wet bulb (°F)		-	77		
Wind speed (mph)		15.0	7.5		

Test for Adequate Exposure Diversity

Hourly Glazing Load



Maximum hourly glazing load exceeds average by 23.6%.

House has adequate exposure diversity (AED), based on AED limit of 30%.

AED excursion: 0 Btuh



Right-Suite® Universal 2012 12.0.13 RSU17328

...ng Solutions\2013\Dependable H and A\Smith Residence\smith.rup Calc = MJ8 Front Door faces:

2013-May-15 14:46:03

Page 1

Right-J® Worksheet

Entire House

Dependable Heating and Air

Job: 13-025-01
Date: May 15, 2013
By: Ron Miller

1 2 3 4 5	Room name		Exposed wall		Room height		Room dimensions		Room area		Entire House		Master Bedroom	
	8.3 ft		161.6 ft		d		8.0 ft		29.8 ft		1538.1 ft²		15.8 x 14.0 ft	
	221.2 ft²		heat/cool											
6	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)	
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool
11	W	12C-0sw	0.091	n	3.37	2.20	344	334	1125	734	0	0	0	0
	G	4A3-2ow	0.470	n	17.39	16.52	10	0	174	165	0	0	0	0
	W	12C-0sw	0.091	e	3.37	2.20	415	329	1108	723	112	92	310	202
	G	4A3-2ov	0.470	e	17.39	47.34	65	0	1130	3077	20	0	348	947
	D	11J0	0.600	e	22.20	17.49	21	21	466	367	0	0	0	0
	W	12C-0sw	0.091	s	3.37	2.20	248	219	737	481	127	107	360	235
	G	4A3-2ov	0.470	s	17.39	18.47	29	16	504	536	20	6	348	369
	G	4A3-2ov	0.470	s	0.00	0.00	0	0	0	0	0	0	0	0
	W	12C-0sw	0.091	w	3.37	2.20	394	323	1088	710	0	0	0	0
	G	4A3-2ov	0.470	w	17.39	16.52	46	92	800	760	0	0	0	0
	G	4A3-2ov	0.470	w	17.39	41.69	4	0	70	167	0	0	0	0
C	D	11J0	0.600	w	22.20	17.49	21	21	466	367	0	0	0	0
	F	16B-30ad	0.032	-	1.18	1.68	1538	1538	1821	2591	221	221	262	373
		22A-tpl	0.989	-	0.00	0.00	1538	0	0	0	221	0	0	0
6	c) AED excursion									0				-317
	Envelope loss/gain								9489	10679			1628	1809
12	a) Infiltration								3264	789			557	135
	b) Room ventilation								0	0			0	0
13	Internal gains:		Occupants @	230			7			1610	2			460
			Appliances/other							4000				500
	Subtotal (lines 6 to 13)								12753	17078			2184	2903
	Less external load								0	0			0	0
	Less transfer								0	0			0	0
	Redistribution								0	0			0	0
14	Subtotal								12753	17078			2184	2903
15	Duct loads						24%	24%	3117	4022	24%	24%	534	684
	Total room load								15870	21100			2718	3587
	Air required (cfm)								1127	1127			193	192

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Right-J® Worksheet

Entire House

Dependable Heating and Air

Job: 13-025-01
Date: May 15, 2013
By: Ron Miller

1	Room name					Master Bath/CL					Great Room				
2	Exposed wall					27.2 ft					18.0 ft				
3	Room height					8.0 ft					9.5 ft				
4	Room dimensions					14.2 x 13.0 ft					18.0 x 15.8 ft				
5	Room area					184.6 ft²					284.4 ft²				
	Ty	Construction number	U-value (Btuh/ft²·F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12C-0sw	0.091	n	3.37	2.20	0	0	0	0	0	0	0	0	
	G	4A3-2ow	0.470	n	17.39	16.52	0	0	0	0	0	0	0	0	
	W	12C-0sw	0.091	e	3.37	2.20	0	0	0	0	144	93	313	204	
	G	4A3-2ov	0.470	e	17.39	47.34	0	0	0	0	30	0	522	1420	
11	D	11J0	0.600	e	22.20	17.49	0	0	0	0	21	21	466	367	
	W	12C-0sw	0.091	s	3.37	2.20	121	112	377	246	0	0	0	0	
	G	4A3-2ov	0.470	s	17.39	18.47	9	3	157	166	0	0	0	0	
	G	4A3-2ov	0.470	s	0.00	0.00	0	0	0	0	0	0	0	0	
	W	12C-0sw	0.091	w	3.37	2.20	104	100	337	220	0	0	0	0	
	G	4A3-2ov	0.470	w	17.39	16.52	0	0	0	0	0	0	0	0	
	G	4A3-2ov	0.470	w	17.39	41.69	4	0	70	167	0	0	0	0	
	D	11J0	0.600	w	22.20	17.49	0	0	0	0	0	0	0	0	
	C	16B-30ad	0.032	-	1.18	1.68	185	185	219	311	284	284	337	479	
	F	22A-tpl	0.989	-	0.00	0.00	185	0	0	0	284	0	0	0	
6	c) AED excursion									-72				-211	
	Envelope loss/gain								1158	1038			1638	2260	
12	a) Infiltration								524	127			335	81	
	b) Room ventilation								0	0			0	0	
13	Internal gains:			Occupants @	230		0			0	2			460	
				Appliances/other						0				1000	
	Subtotal (lines 6 to 13)								1683	1165			1973	3801	
	Less external load								0	0			0	0	
	Less transfer								0	0			0	0	
	Redistribution								0	0			0	0	
14	Subtotal								1683	1165			1973	3801	
15	Duct loads						24%	24%	411	274	24%	24%	482	895	
	Total room load								2094	1439			2456	4696	
	Air required (cfm)								149	77			174	251	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Right-J® Worksheet

Entire House

Dependable Heating and Air

Job: 13-025-01
Date: May 15, 2013
By: Ron Miller

1	Room name					Kitchen/Dining					Guest Bath				
2	Exposed wall					18.5 ft					7.8 ft				
3	Room height					8.0 ft					8.0 ft				
4	Room dimensions					18.5 x 15.2 ft					7.8 x 13.0 ft				
5	Room area					281.2 ft²					101.4 ft²				
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12C-0sw	0.091	n	3.37	2.20	0	0	0	0	104	104	350	229	
11	G	4A3-2ow	0.470	n	17.39	16.52	0	0	0	0	0	0	0	0	
	W	12C-0sw	0.091	e	3.37	2.20	0	0	0	0	63	63	212	138	
	G	4A3-2ov	0.470	e	17.39	47.34	0	0	0	0	0	0	0	0	
	D	11J0	0.600	e	22.20	17.49	0	0	0	0	0	0	0	0	
	W	12C-0sw	0.091	s	3.37	2.20	0	0	0	0	0	0	0	0	
	G	4A3-2ov	0.470	s	17.39	18.47	0	0	0	0	0	0	0	0	
	G	4A3-2ov	0.470	s	0.00	0.00	0	0	0	0	0	0	0	0	
	W	12C-0sw	0.091	w	3.37	2.20	144	113	380	248	0	0	0	0	
	G	4A3-2ov	0.470	w	17.39	16.52	31	31	539	512	0	0	0	0	
	G	4A3-2ov	0.470	w	17.39	41.69	0	0	0	0	0	0	0	0	
	D	11J0	0.600	w	22.20	17.49	0	0	0	0	0	0	0	0	
C	16B-30ad	0.032	-	1.18	1.68	281	281	333	474	101	101	120	171		
F	22A-tpl	0.989	-	0.00	0.00	281	0	0	0	101	0	0	0		
6	c) AED excursion								687				-62		
	Envelope loss/gain							1253	1921			682	476		
12	a) Infiltration							335	81			389	94		
	b) Room ventilation							0	0			0	0		
13	Internal gains: Occupants @ 230					1			230	0			0	0	
	Appliances/other								1000				0	0	
	Subtotal (lines 6 to 13)							1588	3232			1071	570		
14	Less external load							0	0			0	0		
	Less transfer							0	0			0	0		
	Redistribution							0	0			0	0		
	Subtotal							1588	3232			1071	570		
15	Duct loads					24%	24%	388	761	24%	24%	262	134		
	Total room load							1976	3993			1333	704		
	Air required (cfm)							140	213			95	38		

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-J® Worksheet

Entire House

Dependable Heating and Air

Job: 13-025-01
Date: May 15, 2013
By: Ron Miller

1	Room name					Bedroom 2					Hall Closet				
2	Exposed wall					25.0 ft					4.0 ft				
3	Room height					8.0 ft					8.0 ft				
4	Room dimensions					13.0 x 12.0 ft					4.0 x 5.0 ft				
5	Room area					156.0 ft²					20.0 ft²				
	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)		Load (Btuh)		
					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool	
6	W	12C-0sw	0.091	n	3.37	2.20	104	104	350	229	32	32	108	70	
11	G	4A3-2ow	0.470	n	17.39	16.52	0	0	0	0	0	0	0	0	
	W	12C-0sw	0.091	e	3.37	2.20	96	81	273	178	0	0	0	0	
	G	4A3-2ov	0.470	e	17.39	47.34	15	0	261	710	0	0	0	0	
	D	11J0	0.600	e	22.20	17.49	0	0	0	0	0	0	0	0	
	W	12C-0sw	0.091	s	3.37	2.20	0	0	0	0	0	0	0	0	
	G	4A3-2ov	0.470	s	17.39	18.47	0	0	0	0	0	0	0	0	
	G	4A3-2ov	0.470	s	0.00	0.00	0	0	0	0	0	0	0	0	
	W	12C-0sw	0.091	w	3.37	2.20	0	0	0	0	0	0	0	0	
	G	4A3-2ov	0.470	w	17.39	16.52	0	0	0	0	0	0	0	0	
	G	4A3-2ov	0.470	w	17.39	41.69	0	0	0	0	0	0	0	0	
	D	11J0	0.600	w	22.20	17.49	0	0	0	0	0	0	0	0	
C	16B-30ad	0.032	-	1.18	1.68	156	156	185	263	20	20	24	34		
F	22A-tpl	0.989	-	0.00	0.00	156	0	0	0	20	0	0	0		
6	c) AED excursion								-127				-12		
	Envelope loss/gain							1068	1253			131	92		
12	a) Infiltration							466	113			75	18		
	b) Room ventilation							0	0			0	0		
13	Internal gains:		Occupants @	230		1			230	500	0			0	
			Appliances/other											0	
	Subtotal (lines 6 to 13)								1534	2095			206	110	
	Less external load								0	0			0	0	
	Less transfer								0	0			0	0	
	Redistribution								0	0			0	0	
14	Subtotal								1534	2095			206	110	
15	Duct loads							24%	24%	375	493	24%	24%	50	26
	Total room load								1909	2589			256	136	
	Air required (cfm)								136	138			18	7	

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-J® Worksheet

Entire House

Dependable Heating and Air

Job: 13-025-01
Date: May 15, 2013
By: Ron Miller

1	Room name				Bedroom 3				Utility			
	Exposed wall				25.0 ft				6.3 ft			
	Room height				8.0 ft				8.0 ft			
2	Room dimensions				13.0 x 12.0 ft				6.3 x 13.0 ft			
3	Room area				156.0 ft²				81.3 ft²			
4	Ty	Construction number	U-value (Btuh/ft²·°F)	Or	HTM (Btuh/ft²)		Area (ft²) or perimeter (ft)		Load (Btuh)		Area (ft²) or perimeter (ft)	
5					Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S
6	W	12C-0sw	0.091	n	3.37	2.20	104	94	316	207	0	0
	G	4A3-2ow	0.470	n	17.39	16.52	10	0	174	165	0	0
	W	12C-0sw	0.091	e	3.37	2.20	0	0	0	0	0	0
	G	4A3-2ov	0.470	e	17.39	47.34	0	0	0	0	0	0
11	D	11J0	0.600	e	22.20	17.49	0	0	0	0	0	0
	W	12C-0sw	0.091	s	3.37	2.20	0	0	0	0	0	0
	G	4A3-2ov	0.470	s	17.39	18.47	0	0	0	0	0	0
	G	4A3-2ov	0.470	s	0.00	0.00	0	0	0	0	0	0
	W	12C-0sw	0.091	w	3.37	2.20	96	81	273	178	50	29
	G	4A3-2ov	0.470	w	17.39	16.52	15	15	261	248	0	0
	G	4A3-2ov	0.470	w	17.39	41.69	0	0	0	0	0	0
	D	11J0	0.600	w	22.20	17.49	0	0	0	0	21	21
	C	16B-30ad	0.032	-	1.18	1.68	156	156	185	263	81	81
	F	22A-tpl	0.989	-	0.00	0.00	156	0	0	0	81	0
6	c) AED excursion									232		
	Envelope loss/gain								1209	1292		660
12	a) Infiltration								466	113		116
	b) Room ventilation								0	0		0
13	Internal gains: Occupants @ 230						1			230	0	
	Appliances/other									500		0
	Subtotal (lines 6 to 13)								1675	2135		777
	Less external load								0	0		0
	Less transfer								0	0		0
	Redistribution								0	0		0
14	Subtotal								1675	2135		777
15	Duct loads						24%	24%	409	503	24%	190
	Total room load								2084	2637		966
	Air required (cfm)								148	141		69

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



[illegible]

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.